

## Test Documents for Vacuum Circuit-Breaker 3AE5065-1Z "E16" (7,2 kV, 31,5 kA, 800 A)

The vacuum circuit-breakers of type 3AE were type tested in accordance with

IEC Publication 62271-1, Edition 1.1, 2011-08,  
IEC Publication 62271-100, Edition 2.1, 2012-09 and the relevant harmonisation documents.

For vacuum circuit-breaker 3AE5065-1Z "E16" the following test documents are valid:

Type Tests	Rated Values	Test Documents
Dielectric tests	$U_P = 75 \text{ kV}$ $U_d = 32 \text{ kV}$	14-054-MH
Temperature-rise tests	$I_r = 800 \text{ A}$	14-061-ME
Mechanical operation test at ambient temperature, Low and high temperature tests	10.000 op. Cycles -5 / +40 °C	14-067-MM 14-055-MM
Short-time withstand current and peak withstand current tests	$I_{sc} = 31,5 \text{ kA/3s}$ $I_{ma} = 80 \text{ kA}$	14-041-MS
Short-circuit making and breaking tests	$I_{sc} = 31,5 \text{ kA}$ $I_{ma} = 80 \text{ kA}$	14-050-MS

Siemens Aktiengesellschaft

*i.v. Freundt*  
Dr. Freundt  
IC LMV MS R&D OC



*i.v. Röhling*  
Mr. Röhling  
IC LMV MS R&D OC 1

Berlin, August 01, 2014

**Siemens AG**  
Infrastructure & Cities Sector; Leitung: Roland Busch  
Low and Medium Voltage Division; Leitung: Ralf Christian  
Medium Voltage & Systems; Leitung: Stephan May

Nonnendammallee 104  
13629 Berlin  
Deutschland

Tel.: +49 (30) 386 0


Siemens Aktiengesellschaft; Vorsitzender des Aufsichtsrats: Gerhard Cromme; Vorstand: Joe Kaeser, Vorsitzender; Roland Busch, Klaus Helmrich, Hermann Requardt, Siegfried Russwurm, Ralf P. Thomas  
Sitz der Gesellschaft: Berlin und München, Deutschland; Registergericht: Berlin Charlottenburg, HRB 12300, München, HRB 6684  
WEEE-Reg.-Nr. DE 23691322

Test Documents  
for Vacuum Circuit-Breaker  
3AE5065-1Z "E16"  
(7,2 kV, 31,5 kA, 800 A)

If a test is carried out with a vacuum circuit-breaker with different order number, the validity of the test document is given by the following statements:

The listed test documents for the mentioned vacuum circuit-breaker are valid in respect to familiar design of the vacuum circuit-breakers, as the construction of the main current path and mechanical driving mechanism is nearly identical.

Siemens Aktiengesellschaft

  
Dr. Freundt  
IC LMV MS R&D OC



  
Mr. Röhling  
IC LMV MS R&D OC 1

Berlin, August 01, 2014

**Siemens AG**  
Infrastructure & Cities Sector; Leitung: Roland Busch  
Low and Medium Voltage Division; Leitung: Ralf Christian  
Medium Voltage & Systems; Leitung: Stephan May

Nonnendammallee 104  
13629 Berlin  
Deutschland

Tel.: +49 (30) 386 0


Siemens Aktiengesellschaft; Vorsitzender des Aufsichtsrats: Gerhard Cromme; Vorstand: Joe Kaeser, Vorsitzender;  
Roland Busch, Klaus Helmrich, Hermann Requardt, Siegfried Russwurm, Ralf P. Thomas  
Sitz der Gesellschaft: Berlin und München, Deutschland; Registergericht: Berlin Charlottenburg, HRB 12300, München, HRB 6684  
WEEE-Reg.-Nr. DE 23691322

**Test Documents**  
**for Vacuum Circuit-Breaker**  
**3AE5065-1Z "E16"**  
**(7,2 kV, 31,5 kA, 800 A)**


In addition to the type tests in accordance with IEC 62271-1 and IEC 62271-100 the following tests were carried out:

Type Tests	Test Documents
Single-phase and double earth fault tests	14-050-MS
Capacitive current switching tests: -cable-charging current breaking tests -single capacitor bank switching tests	14-047-MS
Out-of-phase making and breaking tests	14-050-MS

Siemens Aktiengesellschaft

  
**Dr. Freundt**  
 IC LMV MS R&D OC



  
**Mr. Röhling**  
 IC LMV MS R&D OC 1

Berlin, August 01, 2014

**Siemens AG**  
 Infrastructure & Cities Sector; Leitung: Roland Busch  
 Low and Medium Voltage Division; Leitung: Ralf Christian  
 Medium Voltage & Systems; Leitung: Stephan May

Nonnendammallee 104  
 13629 Berlin  
 Deutschland

Tel.: +49 (30) 386 0

Siemens Aktiengesellschaft: Vorsitzender des Aufsichtsrats: Gerhard Cromme; Vorstand: Joe Kaeser, Vorsitzender;  
 Roland Busch, Klaus Helmrich, Hermann Requardt, Siegfried Russwurm, Ralf P. Thomas  
 Sitz der Gesellschaft: Berlin und München, Deutschland; Registergericht: Berlin Charlottenburg, HRB 12300, München, HRB 6684  
 WEEE-Reg.-Nr. DE 23691322