

## Prüfbescheinigung / Test – Certificate

Erzeugnis / Product: **Solid-State Relay, Solid-State Contactor**

Typ: **3RF20, 3RF21, 3RF22,**  
Type: **3RF23, 3RF24, 3RF29**

Tech. Daten:  **$U_e / U_i = 600 \text{ V}$**   
Specification:  **$I_e (AC51) = 7,5 - 88 \text{ A}$**

Hersteller: **Siemens AG**  
Manufacturer: **I IA CE**

Art der Prüfung / Type of test: **Type Test**

Prüfer / **I IA CE CP R&D-VI 2 / Mr. Zimmerer**  
Tested by:

Labor / **LOVAG registered and DAkkS accredited**  
Laboratory: **Testing Laboratory**  
**Siemens AG, Amberg**

Angewandte Prüfbestimmungen / Test specifications applied:

**IEC 60947-4-3, Edition 1.2: 2011-07**

**IEC 60947-5-1, Edition 3.1: 2009-07**

Durchgeführte Prüfungen / Tests conducted:

**According to IEC 60947-4-3: Test Sequences I, II, III, IV, EMC Emission, EMC Immunity**

**According to IEC 60947-5-1: Test Sequences II, III, IV**

Prüfergebnis / Test results:

**All requirements of the test specification are met.**

Bemerkungen / Remarks: **Issued: 2006-05-12**

**Index a, dated 2009-07-01: Standards updated; EMC test report added.**

**Index b, dated 2013-06-11: Standards updated**

**Covers all solid-state switching devices for resistive loads type 3RF2 and accessories type 3RF29.**

Unterschrift / Signature



Gegengezeichnet / Released by:



**I IA CE CP R&D-VI Mr. Schweiger**



**I IA CE CP R&D-EN Mr. Knauer**

**SIEMENS AG**

**Industry Sector**

**S. Russwurm (Head)**

## Test summary

Manufacturer: **Siemens AG / IA CE Amberg  
Werner-von-Siemens-Str. 48, 92220 Amberg**

Test device: **Solid state relay and contactors**

Type: **3RF2..**

Test specification: **IEC 60947-4-3 (2011-07), IEC 60947-1 (2011-03),  
IEC 60947-5-1 (2009-07)**

Test report No.: **03045TE + 03074TEI + 03076TEI + 03091TEI + 05115TEI + 08021TEI  
+ 12045ENI01 + 13030ENI01  
A&D ATS 6 / 03-M235a + 06-M0602199-A1 + 09-E003873-BM-A01**

### Test report No.: 03045TE

Test-sequence and sub-clause	Test	Tested Device
<b>IEC 60947-4-3</b> Test-sequence I 9.3.3.3 9.3.3.4	Verification of temperature-rise Verification of dielectric properties	3RF2310-1AA24 3RF2320-2AA24 3RF2330-1AA26 3RF2340-1AA24 3RF2350-1AA26 3RF2370-3AA06 3RF2390-3AA06 3RF2340-1AA14 3RF2340-1AA34 3RF2120-1AA24 3RF2130-1AA04 3RF2150-1AA04 3RF2170-3AA04 3RF2190-3AA06
Test-sequence II 9.3.3.6.1. 9.3.3.6.2. 9.3.3.6.3.	Verification of thermal stability Verification of overload capability Verification of blocking and commutating, including verification of operating and operating limits	3RF2310-1AA24 3RF2320-1AA24 3RF2330-1AA26 3RF2340-1AA24 3RF2350-1AA26 3RF2370-3AA26 3RF2390-3AA06 3RF2120-1AA24 3RF2130-1AA04 3RF2150-1AA04 3RF2170-3AA06 3RF2190-3AA06

**Certificate no.: 2768b**

Test-sequence III 9.3.4	Performance under short-circuit conditions	3RF2310-1AA04 3RF2320-1AA26 3RF2330-1AA04 3RF2340-1AA26 3RF2350-1AA26 3RF2370-3AA06 3RF2120-1AA04 3RF2130-1AA04 3RF2150-3AA06 3RF2170-3AA06
Test-sequence IV IEC 60 947-1 8.2.4	Mechanical properties of terminals	3RF2310-1AA26 3RF2320-2AA24 3RF2330-1AA26 3RF2340-1AA26 3RF2350-1AA26 3RF2370-1BA06 3RF2390-3AA06 3RF2120-1AA04 3RF2120-2AA24 3RF2190-2AA06 3RF2190-2AA04
<b>IEC 60947-4-3</b>  EMC Emission test 9.3.5.1.1 9.3.5.1.2	See Test report no.: A&D ATS 6 / 03-M235 EMC-Laboratory Erlangen  Conducted radiofrequency emission test Radiated radio-frequency emission test	3RF2310-1AA02 3RF2330-1BA14 3RF2370-3AA22 3RF2030-1AA02 3RF2070-1AA24 3RF2330-1AA42 3RF2320-1CA02 3RF2320-1CA14 3RF2900-0EA18 3RF2920-0FA08 3RF2920-0GA36 3RF2920-0HA13
EMC Immunity test  9.3.5.2.1 9.3.5.2.2 9.3.5.2.3 9.3.5.2.4	See Test report no.: A&D ATS 6 / 03-M235 EMC-Laboratory Erlangen  Electrostatic discharge Radiofrequency electromagnetic field Fast transient (5/50 ns) Surge (1,2/50µs – 8/20µs)	see EMC Emission test
<b>IEC 60947-5-1</b>  Test-sequence II  8.3.3.5.2  8.3.3.5.5.b	Making and breaking capacities of switching elements under normal conditions Dielectric properties	3RF2310-1BA06 3RF2310-1BA04 3RF2320-1BA06 3RF2340-1BA06 3RF2340-1BA04 3RF2370-1BA06 3RF2390-1BA06

**Certificate no.: 2768b**

Test-sequence III		3RF2310-1BA06 3RF2310-1BA04 3RF2320-1BA06 3RF2340-1BA06 3RF2340-1BA04 3RF2370-1BA06 3RF2390-1BA06
8.3.3.5.3	Making and breaking capacities of switching elements under abnormal conditions	
8.3.3.5.5.b	Dielectric properties	

**Test report No.: 03074TEI**

Test-sequence and sub-clause	Test	Tested Device
<b>IEC 60947-4-3</b>		
Test-sequence I		
9.3.3.3	Verification of temperature-rise	3RF2900-0EA18 tested with
9.3.3.4	Verification of dielectric properties	3RF2340-1BA06  3RF2920-0FA08 tested with 3RF2320-1BA06

**Test report No.: 03076TEI**

Test-sequence and sub-clause	Test	Tested Device
<b>IEC 60947-4-3</b>		
Test-sequence I		
9.3.3.3	Verification of temperature-rise	3RF2050-1AA04
9.3.3.4	Verification of dielectric properties	
Test-sequence III		
9.3.4	Performance under short-circuit conditions	3RF2020-1AA24 3RF2030-1AA04 3RF2050-1AA04
IEC 60 947-1		
Test-sequence IV		
8.2.4	Mechanical properties of terminal	3RF2050-1AA04

**Test report No.: 03091TEI**

Test-sequence and sub-clause	Test	Tested Device
<b>IEC 60947-4-3</b> Test-sequence I 9.3.3.3 9.3.3.4	Verification of temperature-rise Verification of dielectric properties	3RF2950-0GA36 tested with 3RF2350-1AA26  3RF2950-0HA16 tested with 3RF2350-1BA04
EMC Emission test 9.3.5.1.1 9.3.5.1.2	See Test report no.: 03045TE Conducted radiofrequency emission test Radiated radiofrequency emission test	3RF2920-0GA36 3RF2920-0HA13
EMC Immunity test 9.3.5.2.1 9.3.5.2.2 9.3.5.2.3 9.3.5.2.4	See Test report no.: 03045TE Electrostatic discharge Radiofrequency electromagnetic field Fast transients (5/50 ns) Surges (1,2/50 µs – 8/20 µs)	3RF2920-0GA36 3RF2920-0HA13
<b>IEC 60947-5-1</b> Test-sequence II 8.3.3.5.2 8.3.3.5.5 b)	Making and breaking capacities of switching elements under normal conditions Dielectric properties	3RF2990-0GA13 3RF2990-0GA36
Test-sequence IV 8.3.4 8.3.3.5.5 b)	Performance under conditional short circuit current Dielectric properties	3RF2990-0GA33

Test report No.: 05115TEI

IEC 60947-4-3		Test sequence			
Test sample	Rating	I	II	III	IV
3RF2230-1AB45 3RF2255-3AB45 3RF2230-1AC45 3RF2255-3AC45	$I_{th} = 30 \text{ A}$ $I_{th} = 55 \text{ A}$ $I_{th} = 30 \text{ A}$ $I_{th} = 55 \text{ A}$				
3RF2410-1AB05 3RF2420-2AB45 3RF2430-1AB35 3RF2440-1AB45 3RF2450-3AB55	$I_{th} = 7 \text{ A}$ $I_{th} = 15 \text{ A}$ $I_{th} = 22 \text{ A}$ $I_{th} = 30 \text{ A}$ $I_{th} = 38 \text{ A}$	<b>X</b>			
3RF2410-1AC05 3RF2420-1AC15 3RF2430-1AC35 3RF2440-1AC45 3RF2450-1AC45	$I_{th} = 7 \text{ A}$ $I_{th} = 15 \text{ A}$ $I_{th} = 22 \text{ A}$ $I_{th} = 30 \text{ A}$ $I_{th} = 38 \text{ A}$ $U_i = 600 \text{ V}$ $U_{imp} = 6 \text{ kV}$				
3RF2230-1AB45 3RF2255-3AB45 3RF2230-1AC45 3RF2255-3AC45	$X = 1,1;$ $T_x = 60;$ $F = 50;$ $S = 30;$				
3RF2410-1AB45 3RF2420-1AB45 3RF2430-1AB55 3RF2440-3AB45 3RF2450-3AB55	$X = 1,5 / 1,9;$ $T_x = 300 / 10;$ $F = 50$ $S = 6 / 180$		<b>X</b>		
3RF2410-2AC45 3RF2420-1AC45 3RF2430-1AC55 3RF2440-1AC45 3RF2450-1AC55					
3RF2230-1AB45  3RF2410-1AB45 3RF2420-1AB45 3RF2430-1AB45 3RF2450-1AB45	Coordination type 1: $I_q = 50 \text{ kA}$ $U_{test} = 550 \text{ V}$ Cylindrical fuse: gL/gG 3NW6210-1; 25A  3NW6210-1; 25A 3NW6217-1; 40A 3NW6117-1; 40A 3NW6117-1; 40A			<b>X</b>	

IEC 60947-4-3		Test sequence			
Test sample	Rating	I	II	III	IV
3RF2410-1AC45 3RF2420-1AC45 3RF2430-1AC45 3RF2450-1AC45	3NW6210-1; 25A 3NW6217-1; 40A 3NW6117-1; 40A 3NW6117-1; 40A			X	
3RF2230-1AB45  3RF2410-1AB45 3RF2420-1AB45 3RF2430-1AB45 3RF2450-1AB45  3RF2410-1AC45 3RF2420-1AC45 3RF2430-1AC45 3RF2440-1AC45	Coordination type 1: Iq=50kA Utest=660V LV HRC fuse: gL/gG 3NA6810-6; 25A  3NA6810-6; 25A 3NA6817-6; 40A 3NA6817-6; 40A 3NA6817-6; 40A  3NA6810-6; 25A 3NA6817-6; 40A 3NA6817-6; 40A 3NA6817-6; 40A			X	
3RF2230-1AC45 3RF2410-2AC45 3RF2230-2AC45	IP 20				X

**Remark to the test sequence III: 9.3.4 Performance under short-circuit conditions**

The device 20 A, two phase and three phase controlled contactor (3RF2420-1AB/C..) is identical with 55 A, two phase and three phase controlled relay (3RF2255-1AB/C..), therefore only 3RF2420-1AB/C.. was tested.

The device 10 A, three phase controlled contactor (3RF2410-1AC..) is identical with 30 A, three phase controlled relay (3RF2230-1AC..), therefore only 3RF2410-1AC.. was tested.

The device 40 A, two phase and three phase controlled contactor (3RF2440-1AB/C..) is identical with 50 A, two phase and three phase controlled contactor (3RF2450-1AB/C..), therefore one time 3RF2450-1AB45 was tested, other time 3RF2440-1AC45 was tested.

**Test report No.: 08021TEI**

Test-sequence and sub-clause	Test	Tested Device
<b>IEC 60 947-4-3</b>		
Test-sequence I		
9.3.3.3	Verification of temperature-rise	3RF2340-1DA04-0KNO
9.3.3.4	Verification of dielectric properties	
Test-sequence II		
9.3.3.6.1.	Verification of thermal stability	3RF2340-1DA04-0KNO
9.3.3.6.2.	Verification of overload capability	
9.3.3.6.3.	Verification of blocking and commutating, including verification of operating and operating limits	

**Test report No.: 12045ENI01**

Test sequence I			
Sample No.	Test sample	Date code	Rating
12045EN001	3RF2330-2DA64	G/120420	$I_{th} = 22A$ , $U_s = 110V$ dc $U_i = 600V$ , $U_{imp} = 6kV$
Test sequence II			
12045EN002	3RF2320-1AA65	G/120420	$X = 1,7$ $T_x = 10;$ $F = 50;$ $S = 180$

**Test report No.: 13030ENI01**

Sample No.	Test sample	Date code	Rating
13030EN001 up to 13030EN006	3RF2420-2AB45*	G/130219, E01	Electrical terminal test, main circuit
13030EN010 up to 13030EN025	3RF2420-2AB45*	G/130219, E01	Electrical terminal test, control circuit

\*The Tests carried out with 3RF2420-2AB45 are representative for the whole series, because of identical terminals.



# SIEMENS



**Certificate no.: 2768b**

The tests were carried out on devices, representative for the whole series, fixed on page 9 and 13.

The tests were carried out in the

**Type Test Center Siemens AG I IA CE Amberg**  
**Werner-von-Siemens-Str. 48, 92220 Amberg**  
Accredited-No.: **D-PL-11055-04-01**

The EMC-Tests were carried out in the accredited laboratory of

**Siemens AG, EMV-Zentrum Erlangen**  
**Günther-Scharowsky-Str. 21, 91058 Erlangen**  
Accredited-No.: **D-PL-11055-13-01**

## Nomenclature Breakdown

### Series: 3RF2

3RF2    1    20    -    1    A    A    0    2  
I        II        III        IV        V        VI        VII        VIII

**I**    Basic unit designation:  
solid state relay and contactors

**II**    Kind of device:

- 0 - SSR Solid State Relay single phase 45 mm
- 1 - SSR Solid State Relay single phase 22,5 mm
- 2 - SSR Solid State Relay three phase
- 3 - SSC Solid State Contactor single phase
- 4 - SSC Solid State Contactor three phase

**III**    Size SSR

- 20 - 20 A
- 30 - 30 A
- 50 - 50 A
- 55 - 55 A
- 70 - 70 A
- 90 - 90 A

**III**    Size SSC

- 10 - 10 A
- 20 - 20 A
- 30 - 30 A
- 40 - 40 A
- 50 - 50 A
- 70 - 70 A
- 90 - 90 A

**IV**    Type of terminals:

- 1 - main terminal screw, aux terminal screw
- 2 - main terminal cage clamp, aux terminal cage clamp
- 3 - main terminal ring lug, aux terminal screw
- 4 - main terminal screw, aux terminal cage clamp

**V**    Special function:

- A - zero point switching
- B - instantaneous switch
- C - low noise, zero point switching
- D - zero point switching, high inrush

## Continuation: Nomenclature breakdown

**VI** Number of the controlled phases:

- A - not use
- B - two-phase controlled
- C - three phase controlled

**VII** Rated control supply voltage,  $U_c$ :

- 0 - DC 24 V
- 1 - UC 24 V
- 2 - AC 110...230 V
- 3 - AC 110 V
- 4 - TTL 4...30 V
- 5 - AC 230 V
- 6 - DC 110 V

**VIII** Rated voltage,  $U_e$ :

- 2 - 24...230 V
- 4 - 48...460 V
- 5 - 48...600 V (1200 V reverse voltage)
- 6 - 48...600 V (1600 V reverse voltage)

### **3RF2340-1DA04-0KN0:**

Special version of solid state contactor with  $I_e = 36A$ , control circuit with  $I_{th} < 10mA$  at the rated control voltage.

## Continuation: Nomenclature breakdown

### Series: 3RF29

3RF2    9    00    -    0    E    A    1    8  
I        II        III        IV        V        VI        VII        VIII

- I     Basic unit designation:  
solid state relay and contactors
  
- II    Kind of device:  
  
9    - Accessories/option modules
  
- III   Size SSR, SSC  
  
00 - All  
04 - 4 A  
06 - 6 A  
16 - 16 A  
20 - 20 A  
32 - 32 A  
50 - 50 A  
90 - 90 A
  
- IV   Type of terminals:  
  
0    - no main terminals, for option moduls
  
- V    Special function:  
  
E    - Converter  
F    - Load monitor Basic  
G    - Load monitoring  
J    - Load monitoring  
H    - Power controller / Regulator  
K    - Power controller / Controller
  
- VI   Number of the controlled phases:  
  
A    - not used or NO for Load monitor basic  
B    - NC for Load monitor basic
  
- VII   Rated control supply voltage, Uc:  
  
0    - DC 24 V  
1    - UC 24 V  
3    - AC 110 V

## Continuation: Nomenclature breakdown

- VIII**      Rated Voltage, U<sub>e</sub>:
- 3    -   110 – 230 V
  - 6    -   400 – 600 V
  - 8    -   Option modules, access to main voltage

## Remarks

### Test report: 03045TEI

#### IEC 60947-4-3 seq II

9.3.3.6.3 Verification of blocking and commutating capability, including operation and operation limits.

Table 7:

Test values:  $1,1 \cdot U_e = 440 \text{ V}$ ,  $I_e = 10 \text{ A}$ ,  $\cos \phi = 0,8$

Every device was tested with the values above, representative for the whole series.

#### IEC 60947-5-1 seq II, III

#### Utilization category: AC 15

Making and breaking capacities of switching elements under normal and abnormal conditions

Tested device:	$I_e$ (AC15)	$U_e$	Devices covered by the tested devices (same semiconductor)
3RF2310-1BA06	6 A	600 V	
3RF2310-1BA04	6 A	400 V	3RF2310-.BA.2 $U_e = 230 \text{ V}$
3RF2320-1BA06	15 A	600 V	3RF2320-.BA.. $I_e$ (AC15) =12 A, every rated voltage
			3RF2330-.BA.. $I_e$ (AC15)=15 A, every rated voltage
3RF2340-1BA06	25 A	600 V	3RF2340-.BA.. $I_e$ (AC15) =20 A, every rated voltage
			3RF2350-.BA.. $I_e$ (AC15) =25 A, every rated voltage
3RF2340-1BA04	20 A	400 V	3RF2340-.BA.2 $I_e$ (AC15)=20 A, $U_e$ 230 V
3RF2370-1BA06	27,5 A	600 V	3RF2370-.BA.. $I_e$ (AC15) =27,5A, every rated voltage
3RF2390-1BA06	30 A	600 V	3RF2390-.BA.. $I_e$ (AC15) =300 A, every rated voltage

**Test report: 03074TEI**

Tests for accessory converter and load monitoring.

**Test report: 03091TEI**

Tests for accessory (45mm) load monitoring and power controller.

**Test report: 03076TEI**

The solid state relay 3RF20.. is constructed identically to 3RF21.. and 3RF23.  
For Test sequence II (IEC 60947-4-3) and IV (IEC 60947-1) see test report no.: 03045TE

**Test sequence II**

9.3.3.6.1 Verification of thermal stability

9.3.3.6.2 Verification of overload capability

9.3.3.6.3 Verification of blocking and commutating capability,  
including operation and operation limits.

Was carried out with 3RF21.., 3RF23..

**Test sequence IV**

8.2.4 Mechanical properties of terminals

To test the mechanical stability, only the test of mechanical strength of terminals (8.2.4.2),  
was carried out.

**Test report: 08021TEI**

Test of special version of solid state contactor. Therefore only sequence I and II is conducted. For other  
test sequences see Test report 03045TEI.

**Test report No.: 12045ENI01**

Additional tests were made for new control supply voltage 110V DC.

**Test report No.: 13030ENI01**

Electrical terminal test for screwless type clamping units was conducted.

AuBerg, 2013-05-24

Location, Date



Signature  
(Authorized representative)  
Mr. Stadlbauer



Reviewed  
(Laboratory manager)  
Mr. Bogner