

## Test Documents for Vacuum Circuit-Breaker 3AE5254-2 (17,5 kV, 25 kA, 1250 A)

The vacuum circuit-breakers of type 3AE were type tested in accordance with

IEC Publication 62271-1, Edition 1.1, 2011-08,  
IEC Publication 62271-100, Edition 2.1, 2012-09 and the relevant harmonisation documents.

For vacuum circuit-breaker 3AE5254-2 the following test documents are valid:

Type Tests	Rated Values	Test Documents
Dielectric tests	$U_p = 95 \text{ kV}$ $U_d = 38 \text{ kV}$	14-049-MH
Temperature-rise tests	$I_r = 1250 \text{ A}$	14-061-ME
Mechanical operation test at ambient temperature, Low and high temperature tests	10.000 op. Cycles -5 / +40 °C	14-067-MM 14-055-MM
Short-time withstand current and peak withstand current tests	$I_{sc} = 25 \text{ kA/3s}$ $I_{ma} = 63 \text{ kA}$	14-041-MS
Short-circuit making and breaking tests	$I_{sc} = 25 \text{ kA}$ $I_{ma} = 63 \text{ kA}$	14-040-MS

Siemens Aktiengesellschaft

*i.V. Freundt*  
Dr. Freundt  
IC LMV MS R&D OC



*i.V. Röhling*  
Mr. Röhling  
IC LMV MS R&D OC 1

Berlin, August 04, 2014

**Siemens AG**  
Infrastructure & Cities Sector; Leitung: Roland Busch  
Low and Medium Voltage Division; Leitung: Ralf Christian  
Medium Voltage & Systems; Leitung: Stephan May

Nonnendammallee 104  
13629 Berlin  
Deutschland

Tel.: +49 (30) 386 0

Siemens Aktiengesellschaft; Vorsitzender des Aufsichtsrats: Gerhard Cromme; Vorstand: Joe Kaeser, Vorsitzender;  
Roland Busch, Klaus Helmrich, Hermann Requardt, Siegfried Russwurm, Ralf P. Thomas  
Sitz der Gesellschaft: Berlin und München, Deutschland; Registergericht: Berlin Charlottenburg, HRB 12300, München, HRB 6684  
WEEE-Reg.-Nr. DE 23691322

Test Documents  
for Vacuum Circuit-Breaker  
3AE5254-2  
(17,5 kV, 25 kA, 1250 A)

If a test is carried out with a vacuum circuit-breaker with different order number, the validity of the test document is given by the following statements:

The listed test documents for the mentioned vacuum circuit-breaker are valid in respect to familiar design of the vacuum circuit-breakers, as the construction of the main current path and mechanical driving mechanism is nearly identical.

Siemens Aktiengesellschaft

*i.v. Freundt*

Dr. Freundt  
IC LMV MS R&D OC



*i.v. Röhling*

Mr. Röhling  
IC LMV MS R&D OC 1

Berlin, August 04, 2014

**Siemens AG**  
Infrastructure & Cities Sector; Leitung: Roland Busch  
Low and Medium Voltage Division; Leitung: Ralf Christian  
Medium Voltage & Systems; Leitung: Stephan May

Nonnendammallee 104  
13629 Berlin  
Deutschland

Tel.: +49 (30) 386 0

Siemens Aktiengesellschaft: Vorsitzender des Aufsichtsrats: Gerhard Cromme; Vorstand: Joe Kaeser, Vorsitzender; Roland Busch, Klaus Helmrich, Hermann Requardt, Siegfried Russwurm, Ralf P. Thomas  
Sitz der Gesellschaft: Berlin und München, Deutschland; Registergericht: Berlin Charlottenburg, HRB 12300, München, HRB 6684  
WEEE-Reg.-Nr. DE 23691322

## Test Documents for Vacuum Circuit-Breaker 3AE5254-2 (17,5 kV, 25 kA, 1250 A)

In addition to the type tests in accordance with IEC 62271-1 and IEC 62271-100 the following tests were carried out:

Type Tests	Test Documents
Single-phase and double earth fault tests	14-040-MS
Capacitive current switching tests: -cable-charging current breaking tests -single capacitor bank switching tests	14-047-MS
Out-of-phase making and breaking tests	14-040-MS

Siemens Aktiengesellschaft

*i.v. Freundt*

Dr. Freundt  
IC LMV MS R&D OC



*i.v. Röhling*

Mr. Röhling  
IC LMV MS R&D OC 1

Berlin, August 04, 2014

**Siemens AG**  
Infrastructure & Cities Sector; Leitung: Roland Busch  
Low and Medium Voltage Division; Leitung: Ralf Christian  
Medium Voltage & Systems; Leitung: Stephan May

Nonnendammallee 104  
13629 Berlin  
Deutschland

Tel.: +49 (30) 386 0

Siemens Aktiengesellschaft; Vorsitzender des Aufsichtsrats: Gerhard Cromme; Vorstand: Joe Kaeser, Vorsitzender; Roland Busch, Klaus Helmrich, Hermann Requardt, Siegfried Russwurm, Ralf P. Thomas  
Sitz der Gesellschaft: Berlin und München, Deutschland; Registergericht: Berlin Charlottenburg, HRB 12300, München, HRB 6684  
WEEE-Reg.-Nr. DE 23691322