

TYPE-TEST-CERTIFICATE

NO. 2567/6094

Regensburg, 2003-10-01

Customer: User		Order-No. Dispatch Note No.
		Copy: 1x
Item	Quantity	Equipment
		LV HRC fuse links, aM, AC 690V, (size 000 and size 00, AC 500V) 3ND1 8.. size 000 and size 00 3ND2 1.. size 1 3ND2 2.. size 2 3ND2 3.. size 3 (315 A, 355 A and 400 A) 3ND1 3.. size 3 (500 A and 630 A)
The equipment is manufactured according to the specifications VDE 0636, Part 10, 20, 201 and 2011. The corresponding quality is superintended by off-hand samples taken by our testing-department. The equipment furthermore corresponds to the specifications IEC 60269 and EN 60269.		

Siemens Aktiengesellschaft



Birkel



Albrecht

Electrical Installation Technology Division

Division President: Godehardt Schneider

Postal Address: Siemens AG
QM P2

Name:
Albrecht
Office Address:

Telephone +49 941 790 - 01 (Switchboard)
Direct Tel. 2199
Fax +49 941 790 - 2714

P. O. Box 10 09 53
D - 93009 Regensburg

Siemensstr. 10
D - 93055 Regensburg

Siemens Aktiengesellschaft - Chairman of the Supervisory Board: Karl-Hermann Baumann - Managing Board: Heinrich v. Pierer, Chairman, President and Chief Executive Officer - Members: Volker Jung, Edward G. Krubasik, Rudi Lamprecht, Heinz-Joachim Neubürger, Peter Pribilla, Jürgen Radomski, Erich R. Reinhardt, Urel J. Sharef, Claus Weyrich, Klaus Wucherer

Registered Offices: Berlin and München - Commercial Registries: Berlin-Charlottenburg, HRB 12300; München, HRB 6684