



# 中国国家强制性产品认证证书

证书编号：2012010302567947

委托人名称、地址

Siemens AG Low Voltage  
Siemensstrasse 10, 93055 Regensburg, Germany

生产者（制造商）名称、地址

Siemens AG Low Voltage  
Siemensstrasse 10, 93055 Regensburg, Germany

生产企业名称、地址

Siemens AG Low Voltage  
Siemensstrasse 10, D-93055 Regensburg, Germany

产品名称和系列、规格、型号

隔离开关

5TE2515-1 Ui:1000V;Ith:63A;DC-21B;Ue:DC1000V;Ie:63A;  
Ics:760A/1s;Icm:500A(峰值);4 极串联

产品标准和技术要求

GB/T14048.3-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，  
特发此证。

发证日期：2017 年 07 月 31 日 有效期至：2022 年 07 月 31 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2012 年 09 月 14 日

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任：



## 中国质量认证中心



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

**CERTIFICATE NO.:** 2012010302567947

## **NAME AND ADDRESS OF THE APPLICANT**

Siemens AG Low Voltage  
Siemensstrasse 10, 93055 Regensburg, Germany

## **NAME AND ADDRESS OF THE MANUFACTURER**

Siemens AG Low Voltage  
Siemensstrasse 10, 93055 Regensburg, Germany

## **NAME AND ADDRESS OF THE FACTORY**

Siemens AG Low Voltage  
Siemensstrasse 10, D-93055 Regensburg, Germany

## **PRODUCT NAME, MODEL AND SPECIFICATION**

Switch-disconnectors  
5TE2515-1 Ui:1000V;lth:63A;DC-21B;Ue:DC1000V;Ie:63A; Ics:760A/1s;lcm:500A(peak);four poles in series

## **THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.3-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

**Valid from:** Jul.31,2017

**Valid until:** Jul.31,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Sep.14,2012

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



## **CHINA QUALITY CERTIFICATION CENTRE**