

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Programmable Controller**with type designation(s)
Programmable Logical Controller SIMATIC S7 - 400

Issued to

**Siemens AG SIMATIC Type Test Karlsruhe
Karlsruhe, Germany**is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Location classes:****Temperature B****Humidity B****Vibration A****EMC A****Enclosure Required protection according to the Rules shall be provided upon installation on board.**Issued at **Hamburg** on **2019-04-29**for **DNV GL**This Certificate is valid until **2024-04-28**.DNV GL local station: **Augsburg**Approval Engineer: **Heinz Scheffler****Joannis Papanuskas
Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Programmable Logical Controller SIMATIC S7 – 400:

- 6ES7-412-417: CPU
- 6ES7-440: communication processor CP 440 RS 422/485
- 6ES7-441: communication module with 1 or 2 variable interface
- 6ES7-443: communications processor CP 443 / PROFIBUS and Ethernet
- 6ES7-400/ 401/ 403: mounting rack
- 6ES7-405/407: power supply, input 24, 48, 60 V DC/120; 230 V AC, out: 4, 10, 20 A DC
- 6ES7-408: fan assembly with 3 fans
- 6ES7-421/422: 16, 32 digital inputs/ 8, 16, 32 digital outputs
- 6ES7-431/432: 8, 16 analog inputs / 8 analog outputs
- 6ES7-450-453: Counter; rapid positioning; cam controller; positioning module
- 6ES7-455: Closed loop control module with 16 channels
- 6ES7-460/461: Interface module
- 6ES7-952: Memory card
- 6ES7-962-964: Interface modules

Software Version: V7.0.x dated 19.11.2015

Application/Limitation

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNVGL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNVGL Rules for Ships Pt.4 Ch.9 Control and Monitoring Systems.

If the control system is intended for remote software maintenance the functionality shall be part of the system documentation as required in DNV GL Rules for Ships Pt.4 Ch.9 Control and Monitoring Systems.

Product certificate

If specified in the Rules, ref. Pt.4 Ch.9 Sec.1, the control and monitoring system in which the above listed hardware is used shall be delivered with a product certificate. For each such delivery the certification test is to be performed at the manufacturer of the application system before the system is shipped to the yard. The test shall be done according to an approved test program. After the certification the clause for application software control will be put into force.

Clause for application software control

All changes in software are to be recorded as long as the system is in use on board. The records of all changes are to be forwarded to DNVGL for evaluation and approval. Major changes in the software are to be approved before being installed in the computer.

Type Approval documentation

Test Report: 19-E008022-BM-B01 List of Test Reports S7-400, dated 09.04.2019

Documents: 19-E008022-BM-A01 List of Technical datasheets equipment manuals S7-400, dated 09-04-2019

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, November 2016.

Job Id: **262.1-027908-1**
Certificate No: **TAA00001UJ**

Marking of product

The products to be marked with:

- Model name
- Manufacturer name
- Serial number

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE