

DNP3 SPECIFICATION

DEVICE PROFILE

Version 2016

April 2016

DISCLAIMER STATEMENT

DNP Users Group documents and publications are not consensus documents. Information contained in this and other works has been obtained from sources believed to be reliable, and reviewed by credible members of the DNP Users Group and/or the DNP Users Group Technical Committee. Neither the DNP Users Group nor any authors/developers of DNP documentation guarantee, and each such person expressly disclaims responsibility for ensuring, the accuracy or completeness of any information published herein, and neither the DNP Users Group nor its authors/developers shall be responsible for any errors, omissions, or damages arising out of use of this document.

Likewise, while the author/developer and publisher believe that the information and guidance given in this work serves as an enhancement to users, all parties must rely upon their own skill and judgment when making use of it. Neither the author nor the publisher assumes any liability to anyone for any loss or damage caused by any error or omission in the work, whether such error or omission is the result of negligence or any other cause. Any and all such liability is disclaimed.

This statement was developed by the DNP Users Group Technical Committee and represents the considered judgment of a group of software developers with expertise in the subject field. The DNP Users Group is a global forum for users and implementers of the protocol and promotes implementers and developer information and interaction exchange. This work is published with the understanding that the DNP Users Group and its authors/developers are supplying information through this publication, not attempting to render engineering or other professional services. If such services are required, the assistance of an appropriate professional should be sought. The DNP Users Group is not responsible for any statements and/or opinions advanced in this publication.

NOTICE OF RIGHTS - DNP USERS GROUP

The contents of this manual are the property of the DNP Users Group. Revisions or additions to the definition and functionality of the DNP Protocol cannot be made without express written agreement from the DNP Users Group or its duly authorized party. In addition, no part of this document may be altered or revised or added to in any form or by any means, except as permitted by written agreement with the DNP Users Group or a Party duly authorized by the DNP Users Group.

The DNP Users Group has made every reasonable attempt to ensure the completeness and accuracy of this document. However, the information contained in this manual is subject to change without notice, and does not represent a commitment on the part of the DNP Users Group. Copies of the latest documentation are available through the DNP Users web site at www.dnp.org.

TRADEMARK AND COPYRIGHT NOTICES

DNP is a trademark of the DNP Users Group. Any brand and product names mentioned in this document are trademarks or registered trademarks of their respective companies.

Copyright © 1991 – 2016 DNP Users Group. All rights reserved.

REVISION HISTORY

(Applies to this entire document)

Version	Date	Reason for Changes
2.00	4-Jan-2007	Adapted from original DNP3 Subset Definitions and completely rewritten.
2.01	3-Feb-2007	Changed DNP User Group to DNP Users Group and footer at bottom of page. Added serial port name. Formatting changes.
2.02	20-Feb-2007	Changed the description of Device Profile table entry 1.1.12
2.03	30-May-2007	Updated 1.1.8 and 1.7.8 to indicate support for Function Code 31, Activate Configuration.
2.04	14-Nov-2008	Removed object 0 from 1.1.8, and added secure authentication to the list. Added new section 1.7.8 (re-numbering old 1.7.8 to 1.7.9) to show details of OS requesting CON on last fragment of a multi-fragment response. Added new sections 1.6.4 and 1.6.5 to show the action of the Master with control requests to off-line and off-scan devices. Removed the reference to retry of control messages from 1.6.2 Added new sections 1.6.6 and 1.6.7 to describe the Master behaviour with respect to retries of control select messages. Added new sections 1.6.8 and 1.6.9 for details of the master time accuracy of issuing freeze requests. Added section 1.6.10 for details of Master freeze time affected by polling or control requests. Added new section 1.6.11 for details of how the Master schedules different requests. Added new section 1.12 to show secure authentication parameters.
2.05	8-Dec-2008	Added explanation of the use of the capabilities and current value columns to section 1. Added details of identifying secure authentication version number to section 1.12.1 Split section 1.12.4 into two sections to specify if devices “issue” aggressive mode requests and if devices “accept” aggressive mode requests. Added FC 129 and FC130 to the table in 1.12.15
2.06	4-May-2009	Added capabilities cell to 1.3.12 Added capabilities cells to 1.10.1 and 1.10.3 to 1.10.8 Changed the reference to 1.10.1 in section 1 to 1.6.8 Changed section 3.5.3 as agreed at the Washington TC Meeting Added references throughout the document to parameters that map to Device Attributes (Object Group 0). Changed 1.1.8 topic “Self Address Reservation” to “Self Address Support”. Added clarification note to 1.7.2 and a cross-reference to 1.10.2 Extended the capabilities of 1.7.2 to include a range of values. Changed the presentation of Device Profile section 1.2.4 Added Level 4 for Masters to section 1.1.7

2.07	23-Feb-2010	Added the option of level 4 to section 1.1.7 Added details of device behavior with frozen analog and frozen counter objects to section 3 (see 3.4.4, 3.4.8 and new sections 3.5.7 to 3.5.10) Created new part (5) to show details of Outstation Database Points, moving the relevant sections from part 3 to this new part. Added new parts to 1.2.6
2012 (2.08)	July-2012	Minor corrections to descriptions in sections 1.5.1, 1.5.3, 1.5.5, 1.5.6, 1.5.7, 1.8.4, 1.10.2, 3.1.3, 3.1.4, 3.2.3, 3.2.4, 3.3.3, 3.4.3, 3.4.7, 3.5.4, 3.5.9, 3.6.2, 3.7, 3.8.2 and 5.11.3. Added new section 1.13 describing broadcast functionality Section 2 (Mapping between DNP3 and IEC 61850) re-worked. Updates to section 1.12 to reflect Secure Authentication V5 changes Changes to section 3 to descriptions of variation 0 requests Added notes to section 3 capabilities to leave blank if not supported
2013 (2.09)	Nov-2013	Added section 1.1.14 (Conformance Testing Details). Added section 1.5.9, to define control status codes supported by the device. Added details to 1.7.6 (Event Buffer Organization), which also affect details in part 3. Added section 1.7.10, to define the signature algorithm associated with the new object Group 0, variations 200 and 201. Added section 1.7.11 (Requests Application Confirmation). Added elements to the end of section 1.12 to meet the requirements of the Secure Authentication test procedures. Revised text in section 3 to align with IEEE 1815-2012.
2014 (2.10)	Nov-2014	Removed a note from 1.13 and added sections 3.4.13 and 3.8.4. Added “group” column to table in section 5.8. Updates to the XML suite as detailed in TB2014-005 with minor corrections to the example XML device profile file.
2016 (2.11)	April-2016	Added a mandatory new element to describe the DP type (capabilities, configuration or both) Removed SA supported from 1.12.1 (it is already in 1.1.8) Removed bracketed text from 1.3.2 Added Timer Disabled to 1.3.10 Revised the description of the last element of 1.3.14 Added new element to 1.5.2 Added new element to 1.5.5, 1.5.6 and 1.5.7 Amended text in 1.6.3 Removed sections 1.6.8 to 1.6.11 Added 1.7.12 (support for clock management) Changed 1.8.1 support for unsolicited mode to yes/no options rather than a single element of “supported” Changed word “infinite” to “unlimited” in section 1.8.4 Added new element to 1.9.5, 1.9.6 and 1.9.7 Added sections 1.11.5 to 1.11.8 Changed max number of users in 1.12.2 to allow a “range” Re-worked 1.12.8 as SAv2 only and added 1.12.21 for SAv5 Added 1.12.19 (Secure Authentication enabled) Added 1.12.20 (length of challenge data) Re-worked 3.7.1 as File Transfer support is already in section 1.1.8 Made “Point Index” an optional element in the data points list in section 5 (all other elements are optional) Changed xslt visualization to show headings of all sections, even when the section is not present in the xml file Corrected analog and counter points lists in section 5 Minor corrections to the schema file:

		• Use of g110/g114 made consistent • Removed redundant code from 3.8 (octet string data points) • Added missing control status codes • Use of N/A made consistent

INTRODUCTION

Vendors must produce a **Device Profile Document** for each device they manufacture implementing DNP3. The Device Profile Document clearly identifies any deviations from the implementation levels described in this document and any other issues that may arise when determining the device's compatibility with another device.

The instructions for completing Device Profile Forms and information are given in Clause 14 of the specification - Interoperability.

Note: there are empty "placeholder" sections in the Device Profile document. These are intentionally blank, being used so that section numbering does not change when entries are deleted from the document. Likewise, to ensure existing section numbers do not change, all new entries are added at the end of the relevant section.

The remainder of this page left blank intentionally.

Contents

1 Device Properties 14
1.1 DEVICE IDENTIFICATION 15
1.1.1 Device Function: 15
1.1.2 Vendor Name: 15
1.1.3 Device Name: 15
1.1.4 Device manufacturer's hardware version string: 15
1.1.5 Device manufacturer's software version string: 15
1.1.6 Device Profile Document Version Number: 15
1.1.7 DNP Levels Supported for: 16
1.1.8 Supported Function Blocks: 16
1.1.9 Notable Additions: 16
1.1.10 Methods to set Configurable Parameters: 17
1.1.11 DNP3 XML files available On-Line: 17
1.1.12 External DNP3 XML files available Off-line: 17
1.1.13 Connections Supported: 17
1.1.14 Conformance Testing: 18
1.2 SERIAL CONNECTIONS 18
1.3 IP NETWORKING 19
1.3.1 Port Name: 19
1.3.2 Type of End Point: 19
1.3.3 IP Address of this Device: 19
1.3.4 Subnet Mask: 19
1.3.5 Gateway IP Address: 19
1.3.6 Accepts TCP Connections or UDP Datagrams from: 19
1.3.7 IP Address(es) from which TCP Connections or UDP Datagrams are accepted: 19
1.3.8 TCP Listen Port Number: 19
1.3.9 TCP Listen Port Number of remote device: 20
1.3.10 TCP Keep-alive timer: 20
1.3.11 Local UDP port: 20
1.3.12 Destination UDP port for DNP3 Requests (Masters only): 20
1.3.13 Destination UDP port for initial unsolicited null responses (UDP only Outstations): 20
1.3.14 Destination UDP port for responses (UDP only Outstations): 20
1.3.15 Multiple outstation connections (Masters only): 21
1.3.16 Multiple master connections (Outstations Only): 21
1.3.17 Time synchronization support: 21
1.4 LINK LAYER 22
1.4.1 Data Link Address: 22
1.4.2 DNP3 Source Address Validation: 22
1.4.3 DNP3 Source Address(es) expected when Validation is Enabled: 22
1.4.4 Self Address Support using address 0xFFFC: 22
1.4.5 Sends Confirmed User Data Frames: 22
1.4.6 Data Link Layer Confirmation Timeout: 22
1.4.7 Maximum Data Link Retries: 23
1.4.8 Maximum number of octets Transmitted in a Data Link Frame: 23
1.4.9 Maximum number of octets that can be Received in a Data Link Frame: 23
1.5 APPLICATION LAYER 24
1.5.1 Maximum number of octets Transmitted in an Application Layer Fragment other than File Transfer: 24
1.5.2 Maximum number of octets Transmitted in an Application Layer Fragment containing File Transfer: 24
1.5.3 Maximum number of octets that can be Received in an Application Layer Fragment: 24
1.5.4 Timeout waiting for Complete Application Layer Fragment: 24
1.5.5 Maximum number of objects allowed in a single control request for CROB (group 12): 25
1.5.6 Maximum number of objects allowed in a single control request for Analog Outputs (group 41): 25
1.5.7 Maximum number of objects allowed in a single control request for Data Sets (groups 85, 86, 87): 25

1.5.8 Supports mixing object groups (AOBs, CROBs and Data Sets) in the same control request: 25
1.5.9 Control Status Codes Supported: 26
1.6 FILL OUT THE FOLLOWING ITEMS FOR MASTERS ONLY 27
1.6.1 Timeout waiting for Complete Application Layer Response(ms): 27
1.6.2 Maximum Application Layer Retries for Request Messages: 27
1.6.3 Timeout waiting for First or Next Fragment of an Application Layer Response: 27
1.6.4 Issuing controls to off-line devices: 27
1.6.5 Issuing controls to off-scan devices: 27
1.6.6 Maximum Application Layer Retries for Control Select Messages (same sequence number): 27
1.6.7 Maximum Application Layer Retries for Control Select Messages (new sequence number): 28
1.6.8 Item deleted 28
1.6.9 Item deleted 28
1.6.10 Item deleted 28
1.6.11 Item deleted 28
1.7 FILL OUT THE FOLLOWING ITEMS FOR OUTSTATIONS ONLY 29
1.7.1 Timeout waiting for Application Confirm of solicited response message: 29
1.7.2 How often is time synchronization required from the master: 29
1.7.3 Device Trouble Bit IIN1.6: 29
1.7.4 File Handle Timeout: 29
1.7.5 Event Buffer Overflow Behavior: 29
1.7.6 Event Buffer Organization: 30
1.7.7 Sends Multi-Fragment Responses: 30
1.7.8 Last Fragment Confirmation: 30
1.7.9 DNP Command Settings preserved through a device restart: 31
1.7.10 Supports configuration signature: 31
1.7.11 Requests Application Confirmation: 31
1.7.12 Supports Clock Management 31
1.8 OUTSTATION UNSOLICITED RESPONSE SUPPORT 32
1.8.1 Supports Unsolicited Reporting: 32
1.8.2 Master Data Link Address: 32
1.8.3 Unsolicited Response Confirmation Timeout: 32
1.8.4 Number of Unsolicited Retries: 32
1.9 OUTSTATION UNSOLICITED RESPONSE TRIGGER CONDITIONS 33
1.9.1 Number of class 1 events: 33
1.9.2 Number of class 2 events: 33
1.9.3 Number of class 3 events: 33
1.9.4 Total number events from any class: 33
1.9.5 Hold time after class 1 event: 33
1.9.6 Hold time after class 2 event: 33
1.9.7 Hold time after class 3 event: 34
1.9.8 Hold time after event assigned to any class: 34
1.9.9 Retrigger Hold Timer: 34
1.9.10 Other Unsolicited Response Trigger Conditions: 34
1.10 OUTSTATION PERFORMANCE 35
1.10.1 Maximum Time Base Drift (milliseconds per minute): 35
1.10.2 When does outstation set IIN1.4: 35
1.10.3 Maximum Internal Time Reference Error when set via DNP (ms): 35
1.10.4 Maximum Delay Measurement error (ms): 35
1.10.5 Maximum Response time (ms): 35
1.10.6 Maximum time from start-up to IIN 1.4 assertion (ms): 36
1.10.7 Maximum Event Time-tag error for local Binary and Double-bit I/O (ms): 36
1.10.8 Maximum Event Time-tag error for local I/O other than Binary and Double-bit data types (ms): 36
1.11 INDIVIDUAL FIELD OUTSTATION PARAMETERS: 37
1.11.1 User-assigned location name or code string (same as g0v245): 37
1.11.2 User-assigned ID Code/number string (same as g0v246): 37
1.11.3 User-assigned name string for the outstation (same as g0v247): 37

1.11.4 Device Serial Number string (same as g0v248): 37
1.11.5 User-assigned secondary operator name (same as g0v206): 37
1.11.6 User-assigned primary operator name (same as g0v207): 37
1.11.7 User-assigned system name (same as g0v208): 37
1.11.8 User-assigned owner name (same as g0v244): 37
1.12 SECURITY PARAMETERS 38
1.12.1 DNP3 device support for secure authentication: 38
1.12.2 Maximum number of users: 38
1.12.3 Security message response timeout: 38
1.12.4 Aggressive mode of operation (receive): 38
1.12.5 Aggressive mode of operation (issuing): 39
1.12.6 Session Key change interval: 39
1.12.7 Session Key change message count: 39
1.12.8 Maximum error count (SAv2 only): 39
1.12.9 MAC algorithm requested in a challenge exchange: 40
1.12.10 Key-wrap algorithm to encrypt session keys: 40
1.12.11 Cipher Suites used with DNP implementations using TLS: 40
1.12.12 Change cipher request timeout: 41
1.12.13 Number of Certificate Authorities supported: 41
1.12.14 Certificate Revocation check time: 41
1.12.15 Additional critical function codes: 41
1.12.16 Other critical fragments: 42
1.12.17 Support for remote update key changes: 42
1.12.18 "Default" user credentials are permitted to expire: 42
1.12.19 Secure Authentication enabled: 42
1.12.20 Length of the challenge data: 43
1.12.21 Maximum statistic counts (SAv5): 43
2 Capabilities and Current Settings for Device Database (Outstations Only) 44
2.1 BINARY INPUTS 44
2.1.1 Static Variation reported when variation 0 requested or in response to Class polls: 44
2.1.2 Event Variation reported when variation 0 requested or in response to Class polls: 44
2.1.3 Event reporting mode: 44
2.1.4 Binary Inputs included in Class 0 response: 44
2.1.5 Binary Inputs Event Buffer Organization: 44
2.2 DOUBLE-BIT BINARY INPUTS 45
2.2.1 Static Variation reported when variation 0 requested or in response to Class polls: 45
2.2.2 Event Variation reported when variation 0 requested or in response to Class polls: 45
2.2.3 Event reporting mode: 45
2.2.4 Double-bit Binary Inputs included in Class 0 response: 45
2.2.5 Double-bit Binary Inputs Event Buffer Organization: 45
2.3 BINARY OUTPUT STATUS AND CONTROL RELAY OUTPUT BLOCK 46
2.3.1 Minimum pulse time allowed with Trip, Close, and Pulse On commands: 46
2.3.2 Maximum pulse time allowed with Trip, Close, and Pulse On commands: 46
2.3.3 Binary Output Status included in Class 0 response: 46
2.3.4 Reports Output Command Event Objects: 46
2.3.5 Static Variation reported when variation 0 requested or in response to Class polls: 46
2.3.6 Event Variation reported when variation 0 requested or in response to Class polls: 46
2.3.7 Command Event Variation reported when variation 0 requested or in response to Class polls: 46
2.3.8 Event reporting mode: 46
2.3.9 Command Event reporting mode: 47
2.3.10 Maximum Time between Select and Operate: 47
2.3.11 Binary Outputs Event Buffer Organization: 47
2.3.12 Binary Output Commands Event Buffer Organization: 47
2.4 COUNTERS / FROZEN COUNTERS 48
2.4.1 Static Counter Variation reported when variation 0 requested or in response to Class polls: 48
2.4.2 Counter Event Variation reported when variation 0 requested or in response to Class polls: 48

2.4.3 Counters included in Class 0 response: 48
2.4.4 Counter Event reporting mode: 48
2.4.5 Static Frozen Counter Variation reported when variation 0 requested or in response to Class polls: 48
2.4.6 Frozen Counter Event Variation reported when variation 0 requested or in response to Class polls: 49
2.4.7 Frozen Counters included in Class 0 response: 49
2.4.8 Frozen Counter Event reporting mode: 49
2.4.9 Counters Roll Over at: 49
2.4.10 Counters frozen by means of: 49
2.4.11 Counters Event Buffer Organization: 49
2.4.12 Frozen Counters Event Buffer Organization: 50
2.4.13 Reports counter events for change of value: 50
2.5 ANALOG INPUTS / FROZEN ANALOG INPUTS 51
2.5.1 Static Variation reported when variation 0 requested or in response to Class polls: 51
2.5.2 Event Variation reported when variation 0 requested or in response to Class polls: 51
2.5.3 Event reporting mode: 51
2.5.4 Analog Inputs Included in Class 0 response: 51
2.5.5 How Deadbands are set: 52
2.5.6 Analog Deadband Algorithm: 52
2.5.7 Static Frozen Analog Input Variation reported when variation 0 requested or in response to Class polls: 52
2.5.8 Frozen Analog Input Event Variation reported when variation 0 requested or in response to Class polls: 53
2.5.9 Frozen Analog Inputs included in Class 0 response: 53
2.5.10 Frozen Analog Input Event reporting mode: 53
2.5.11 Analog Inputs Event Buffer Organization: 53
2.5.12 Frozen Analog Inputs Event Buffer Organization: 54
2.6 ANALOG OUTPUTS / ANALOG OUTPUT COMMANDS 55
2.6.1 Static Analog Output Status Variation reported when variation 0 requested or in response to Class polls: 55
2.6.2 Analog Output Status Included in Class 0 response: 55
2.6.3 Reports Output Command Event Objects: 55
2.6.4 Event Variation reported when variation 0 requested or in response to Class polls: 55
2.6.5 Command Event Variation reported when variation 0 requested or in response to Class polls: 55
2.6.6 Event reporting mode: 56
2.6.7 Command Event reporting mode: 56
2.6.8 Maximum Time between Select and Operate: 56
2.6.9 Analog Outputs Event Buffer Organization: 56
2.6.10 Analog Output Commands Event Buffer Organization: 56
2.7 FILE CONTROL 57
2.7.1 File Transfer Supported: 57
2.7.2 File Authentication: 57
2.7.3 File Append Mode: 57
2.7.4 Permissions Support: 57
2.7.5 Multiple Blocks in a Fragment: 57
2.7.6 Max number of Files Open at one time: 57
2.8 OCTET STRING & EXTENDED OCTET STRING POINTS 58
2.8.1 Event reporting mode: 58
2.8.2 Octet Strings Included in Class 0 response: 58
2.8.3 Octet Strings Event Buffer Organization: 58
2.8.4 Object Group Selection 58
2.9 VIRTUAL TERMINAL PORT NUMBERS (POINTS) 58
2.9.1 Virtual Terminals Event Buffer Organization: 58
2.10 DATA SET PROTOTYPE 59
2.11 DATA SET DESCRIPTOR CONTENTS AND CHARACTERISTICS 59
3 IMPLEMENTATION TABLE 60
4 DATA POINTS LIST (OUTSTATIONS ONLY) 69
4.1 Definition of Binary Input Point List: 69
4.2 Definition of Double-bit Input Point List: 70
4.3 Definition of Binary Output Status/Control relay output block (CROB) Point List: 71

4.4 Definition of Counter/Frozen Counter Point List: 72
4.5 Definition of Analog Input Point List: 73
4.6 Definition of Analog Output Status/Analog Output Block Point List: 74
4.7 Definition of File Names that may be read or written: 75
4.8 Definition of Octet String and Extended Octet String Point List: 76
4.9 Definition of Virtual Terminal Port Numbers: 77
4.10 Definition of Data Set Prototypes: 78
4.11 Definition of Data Set Descriptors: 79
4.11.1 Data Set Properties: 79
4.11.2 Event Class Assigned: 79
4.11.3 Static Data Set included in Class 0 response: 79
4.12 Data Set Descriptor – Point Index Attributes 80

The following pages show the Device Profile.



DNP3 Device Profile
Based on DNP XML Schema version 2.11.00

Document Name: CP 1243-1 PDF File

Document Description: Device Profile for the CP 1243-1

Showing both the Device's Capabilities and its Current Configuration

Revision History

Date	Time	Version	Reason for change	Edited by
2010-07-01		1	Initial release	I IS IN OC OL A SIC
2010-11-10		2	Data link address range corrected	I IS IN OC OL A SIC
2010-11-17		3	Time synchronization request cycle is configurable	I IS IN OC OL A SIC
2013-08-27		4	Some modifications	I IA SC CI RD2
2013-12-05		5	Update of XML Schema from V2.06.00 to V2.08.00	I IA SC CI RD2
2014-03-12		6	Changed supported counter type and time-tag error	I IA SC CI RD2
2015-03-12		7	Changed some wrong parameter ranges	PD PA CI RD2
2016-06-07		8	Update of XML Schema from V2.08.00 to V2.11.00	PD PA CI RD2
2017-05-03		9	Update to the latest CP 1243-1 version	PD PA CI RD2

REFERENCE DEVICE:

1 Device Properties

This document is intended to be used for several purposes, including:

- Identifying the capabilities of a DNP3 device (Master Station or Outstation)
- Recording the settings of a specific instance of a device (parameter settings for a specific instance of the device in the user's total DNP3 estate)
- Matching user requirements to product capabilities when procuring a DNP3 device

The document is therefore structured to show, for each technical feature, the capabilities of the device (or capabilities required by the device when procuring).

It is also structured to show the current value (or setting) of each of the parameters that describe a specific instance of the device. This "current value" may also show a functional limitation of the device. For example when implementing secure authentication it is not required that all DNP3 devices accept aggressive mode requests during critical exchanges (see Device Profile 1.12.4), in which case a vendor would mark this current value as "No – does not accept aggressive mode requests".

Additionally, the current value may sometimes be used to show a value that a device can achieve because of hardware or software dependencies. Users should note that if an entry in the capabilities column of the Device Profile is grayed-out then there may be information in the current value column that is pertinent to the device's capabilities.

Unless otherwise noted, multiple boxes in the second column below should be selected for each parameter to indicate all capabilities supported or required. Parameters without checkboxes in the second column do not have capabilities and are included so the current value may be shown in the third column.

The items listed in the capabilities column below may be configurable to any of the options selected, or set to a fixed value when the device was designed. Item 1.1.10 contains a list of abbreviations for the possible ways in which the configurable parameters may be set. Since some parameters may not be accessible by each of these methods supported, an abbreviation for the configuration methods supported by each parameter is shown in the fourth column of the tables below.

If this document is used to show the current values, the third column should be filled in even if a fixed parameter is selected in the capabilities section ("N/A" may be entered for parameters that are Not Applicable).

If this document is used to show the current value of parameters, then column 3 applies to a single connection between a master and an outstation.

1.1 DEVICE IDENTIFICATION	Capabilities	Current Value	If configurable, list methods
1.1.1 Device Function: *Masters send DNP requests, while Outstations send DNP responses. If a single physical device can perform both functions, a separate Device Profile Document must be provided for each function.*	O Master ● Outstation	O Master ● Outstation	
1.1.2 Vendor Name: *The name of the organization producing the device.* *Note: The current value of this outstation parameter is available remotely using protocol object Group 0 Variation 252.*		*SIEMENS AG*	
1.1.3 Device Name: *The model and name of the device, sufficient to distinguish it from any other device from the same organization.* *Note: The current value of this outstation parameter is available remotely using protocol object Group 0 Variation 250.*		*CP 1243-1*	
1.1.4 Device manufacturer's hardware version string: *Note: The current value of this outstation parameter is available remotely using protocol object Group 0 Variation 243.*		*6GK7 243-1BX30 0XE0*	
1.1.5 Device manufacturer's software version string: *Note: The current value of this outstation parameter is available remotely using protocol object Group 0 Variation 242.*		*3.0*	
1.1.6 Device Profile Document Version Number: *Version of the Device Profile Document is indicated by a whole number incremented with each new release. This should match the latest version shown in the Revision History at the beginning of this document.*		*9.0*	

1.1 DEVICE IDENTIFICATION	Capabilities	Current Value	If configurable, list methods
1.1.7 DNP Levels Supported for: *Indicate each DNP3 Level to which the device conforms fully. For Masters, requests and responses can be indicated independently.*	Masters only Requests Responses ☐ ☐ None ☐ ☐ Level 1 ☐ ☐ Level 2 ☐ ☐ Level 3 ☐ ☐ Level 4 Outstations Only Requests and Responses ☐ None ☑ Level 1 ☑ Level 2 ☑ Level 3 ☐ Level 4	*Level 3*	*Proprietary File via Other Mechanism*
1.1.8 Supported Function Blocks:	☐ Self-Address Support ☐ Data Sets ☐ File Transfer ☐ Virtual Terminals ☐ Mapping to IEC 61850 Object Models defined in a DNP3 XML file ☐ Function code 31, activate configuration ☑ Authentication (if checked then see 1.12)		
1.1.9 Notable Additions: *A brief description intended to quickly identify (for the reader) the most obvious features the device supports in addition to the Highest DNP Level Supported. The complete list of features is described in the Implementation Table.*			

1.1 DEVICE IDENTIFICATION	Capabilities	Current Value	If configurable, list methods
1.1.10 Methods to set Configurable Parameters:	☐ XML – Loaded via DNP3 File Transfer ☐ XML – Loaded via other transport mechanism ☐ Terminal – ASCII Terminal Command Line ☐ Software – Vendor software named _____ ☐ Proprietary file loaded via DNP3 file transfer ☑ Proprietary file loaded via other transport mechanism ☐ Direct – Keypad on device front panel ☐ Factory – Specified when device is ordered ☐ Protocol – Set via DNP3 (e.g. assign class) ☐ Other, explain _____		
1.1.11 DNP3 XML files available On-Line: *XML configuration files names that can be read or written through DNP3 File Transfer to a device.* *A device's currently running configuration is returned by DNP3 on-line XML file read from the device.* *DNP3 on-line XML file write to a device will update the device's configuration when the Activate Configuration (function code 31) is received.*	Rd Wr Filename Description of Contents ☐ dnpDP.xml Complete Device Profile ☐ dnpDPcap.xml Device Profile Capabilities ☐ dnpDPcfg.xml Device Profile config. values		
1.1.12 External DNP3 XML files available Off-line: *XML configuration file names that can be read or written from an external system, typically from a system that maintains the outstation configuration.* *External off-line XML file read permits an XML definition of a new configuration to be supplied from off-line configuration tools.* *External off-line XML file write permits an XML definition of a new configuration to be supplied to off-line configuration tools.*	Rd Wr Filename Description of Contents ☐ ☐ dnpDP.xml Complete Device Profile ☐ ☐ dnpDPcap.xml Device Profile Capabilities ☐ ☐ dnpDPcfg.xml Device Profile config. values		
1.1.13 Connections Supported:	☐ Serial (complete section 1.2) ☑ IP Networking (complete section 1.3) ☐ Other, explain _____	*IP Networking*	*Proprietary File via Other Mechanism*

1.1 DEVICE IDENTIFICATION	Capabilities	Current Value	If configurable, list methods
1.1.14 Conformance Testing: *Where conformance testing has been completed for the outstation or master station, specify the version of the published DNP3 test procedures that was successfully passed. If independently tested, identify the organization that performed the test.*	☐ Self-tested, version _____ ☐ Independently tested, version V 3.0.9 Test organization name KEMA		

1.2 SERIAL CONNECTIONS	Capabilities	Current Value	If configurable, list methods

1.3 IP NETWORKING	Capabilities	Current Value	If configurable, list methods
1.3.1 Port Name: *Name used to reference the communication port defined in this section.*		*eth0*	
1.3.2 Type of End Point:	☐ TCP Initiating ☑ TCP Listening ☐ TCP Dual ☑ UDP Datagram	*TCP Listening* *UDP Datagram*	*Proprietary File via Other Mechanism*
1.3.3 IP Address of this Device:		*.*.*.*	*Proprietary File via Other Mechanism*
1.3.4 Subnet Mask:		*.*.*.*	*Proprietary File via Other Mechanism*
1.3.5 Gateway IP Address:		*.*.*.*	*Proprietary File via Other Mechanism*
1.3.6 Accepts TCP Connections or UDP Datagrams from:	☐ Allows all (show as *.*.*.* in 1.3.7) ☐ Limits based on an IP address ☑ Limits based on list of IP addresses ☐ Limits based on a wildcard IP address ☐ Limits based on list of wildcard IP addresses ☐ Other, explain_____	*List of IP addresses*	
1.3.7 IP Address(es) from which TCP Connections or UDP Datagrams are accepted:		*.*.*.*	*Proprietary File via Other Mechanism*
1.3.8 TCP Listen Port Number: *If Outstation or dual end point Master, port number on which to listen for incoming TCP connect requests. Required to be configurable for Masters and recommended to be configurable for Outstations.*	☐ Not Applicable (Master w/o dual end point) ☐ Fixed at 20,000 ☑ Configurable, range 1024 to 65535 ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____	20000	*Proprietary File via Other Mechanism*

1.3 IP NETWORKING	Capabilities	Current Value	If configurable, list methods
1.3.9 TCP Listen Port Number of remote device: *If Master or dual end point Outstation, port number on remote device with which to initiate connection. Required to be configurable for Masters and recommended to be configurable for Outstations.*	☐ Not Applicable (Outstation w/o dual end point) ☐ Fixed at 20,000 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		
1.3.10 TCP Keep-alive timer: *The time period for the keep-alive timer on active TCP connections.*	☐ Timer disabled ☐ Fixed at _____ms ☑ Configurable, range 1 to 65535000 ms ☐ Configurable, selectable from ____,____,____ms ☐ Configurable, other, describe_____	*180000 ms*	*Proprietary File via Other Mechanism*
1.3.11 Local UDP port: *Local UDP port for sending and/or receiving UDP datagrams. Master may let system choose an available port. Outstation must use one that is known by the master.*	☐ Fixed at 20,000 ☑ Configurable, 1024 to 65535 ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____ ☑ Let system choose (Masters only)	20000	
1.3.12 Destination UDP port for DNP3 Requests (Masters only):	☐ Fixed at 20,000 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		
1.3.13 Destination UDP port for initial unsolicited null responses (UDP only Outstations): *The destination UDP port for sending initial unsolicited Null response.*	☐ None ☐ Fixed at 20,000 ☑ Configurable, range 1024 to 65535 ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____	20000	
1.3.14 Destination UDP port for responses (UDP only Outstations): *The destination UDP port for sending all responses other than initial unsolicited Null Response.*	☐ None ☐ Fixed at 20,000 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____ ☑ Use local port number (as specified in 1.3.11)	*Source port number*	

1.3 IP NETWORKING	Capabilities	Current Value	If configurable, list methods
1.3.15 Multiple outstation connections (Masters only): *Indicates whether multiple outstation connections are supported.*	☐ Supports multiple outstations (Masters only)		
1.3.16 Multiple master connections (Outstations Only): *Indicates whether multiple master connections are supported and the method that can be used to establish connections.*	☑ Supports multiple masters (Outstations only) If supported, the following methods may be used: ☑ Method 1 (based on IP address) - required ☐ Method 2 (based on IP port number) - recommended ☐ Method 3 (browsing for static data) - optional	*IP address*	*Proprietary File via Other Mechanism*
1.3.17 Time synchronization support:	☑ DNP3 LAN procedure (function code 24) ☑ DNP3 Write Time (not recommended over LAN) ☐ Other, explain _____ ☐ Not Supported	*LAN procedure* *Write Time*	*Proprietary File via Other Mechanism*

1.4 LINK LAYER	Capabilities	Current Value	If configurable, list methods
1.4.1 Data Link Address: *Indicates if the link address is configurable over the entire valid range of 0 to 65,519. Data link addresses 0xFFF0 through 0xFFFF are reserved for broadcast or other special purposes.*	☐ Fixed at_____ ☑ Configurable, range 0 to 65519 ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____	*4*	*Proprietary File via Other Mechanism*
1.4.2 DNP3 Source Address Validation: *Indicates whether the device will filter out messages not from a specific source address.*	☐ Never ☐ Always, one address allowed (shown in 1.4.3) ☑ Always, any one of multiple addresses allowed (each selectable as shown in 1.4.3) ☐ Sometimes, explain_____	*Always - multiple address*	
1.4.3 DNP3 Source Address(es) expected when Validation is Enabled: *Selects the allowed source address(es).*	☐ Configurable to any 16 bit DNP Data Link Address value ☑ Configurable, range 0 to 65519 ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		*Proprietary File via Other Mechanism*
1.4.4 Self Address Support using address 0xFFFC: *If an Outstation receives a message with a destination address of 0xFFFC it shall respond normally with its own source address. It must be possible to disable the feature if supported.*	☐ Yes (only allowed if configurable) ☑ No	*No*	
1.4.5 Sends Confirmed User Data Frames: *A list of conditions under which the device transmits confirmed link layer services (TEST_LINK_STATES, RESET_LINK_STATES, CONFIRMED_USER_DATA).*	☑ Never ☑ Sometimes, explain _____ ☑ Always	*Never*	*Proprietary File via Other Mechanism*
1.4.6 Data Link Layer Confirmation Timeout: *This timeout applies to any secondary data link message that requires a confirm or response (link reset, link status, user data, etc)*	☐ None ☐ Fixed at_____ ms ☑ Configurable, range 0 to 65535 seconds ☐ Configurable, selectable from ___,___,___ms ☐ Configurable, other, describe_____ ☐ Variable, explain _____	*2000 ms*	*Proprietary File via Other Mechanism*

1.4 LINK LAYER	Capabilities	Current Value	If configurable, list methods
1.4.7 Maximum Data Link Retries: *The number of times the device will retransmit a frame that requests Link Layer confirmation.*	☐ Never Retries ☐ Fixed at _____ ☑ Configurable, range 0 to 255 ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____	*0*	*Proprietary File via Other Mechanism*
1.4.8 Maximum number of octets Transmitted in a Data Link Frame: *This number includes the CRCs. With a length field of 255, the maximum size would be 292.*	☑ Fixed at 292 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____	*292*	
1.4.9 Maximum number of octets that can be Received in a Data Link Frame: *This number includes the CRCs. With a length field of 255, the maximum size would be 292. The device must be able to receive 292 octets to be compliant.*	☑ Fixed at 292 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____	*292*	

1.5 APPLICATION LAYER	Capabilities	Current Value	If configurable, list methods
1.5.1 Maximum number of octets Transmitted in an Application Layer Fragment other than File Transfer: *This size does not include any transport or frame octets.* • *Masters must provide a setting less than or equal to 249 to be compliant.* • *Outstations must provide a setting less than or equal to 2048 to be compliant.* *Note: The current value of this outstation parameter is available remotely using protocol object Group 0 Variation 240.*	☑ Fixed at 2048 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____	*2048*	
1.5.2 Maximum number of octets Transmitted in an Application Layer Fragment containing File Transfer:	☐ Same current value as 1.5.1 ☐ Fixed at _____ ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		
1.5.3 Maximum number of octets that can be Received in an Application Layer Fragment: *This size does not include any transport or frame octets.* • *Masters must provide a setting greater than or equal to 2048 to be compliant.* • *Outstations must provide a setting greater than or equal to 249 to be compliant.* *Note: The current value of this outstation parameter is available remotely using protocol object Group 0 Variation 241.*	☑ Fixed at 2048 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____	*2048*	
1.5.4 Timeout waiting for Complete Application Layer Fragment: *Timeout if all frames of a message fragment are not received in the specified time. Measured from time first frame of a fragment is received until the last frame is received.*	☐ None ☐ Fixed at_____ ms ☑ Configurable, range 1000 to 65535000 ms ☐ Configurable, selectable from ___,___,___ms ☐ Configurable, other, describe_____ ☑ Variable, explain **fivefold of Data Link Layer Confirmation Timeout**	*10000ms*	*Proprietary File via Other Mechanism*

1.5 APPLICATION LAYER	Capabilities	Current Value	If configurable, list methods
1.5.5 Maximum number of objects allowed in a single control request for CROB (group 12): *Note: The current value of this outstation parameter is available remotely using protocol object Group 0 Variation 216.*	☑ Fixed at 10 (enter 0 if controls are not supported for CROB) ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____ ☐ Variable, explain _____ ☐ Same current value as 1.5.3	*10*	
1.5.6 Maximum number of objects allowed in a single control request for Analog Outputs (group 41):	☑ Fixed at 10 (enter 0 if controls are not supported for Analog Outputs) ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____ ☐ Variable, explain _____ ☐ Same current value as 1.5.3	*10*	
1.5.7 Maximum number of objects allowed in a single control request for Data Sets (groups 85, 86, 87):	☑ Fixed at 0 (enter 0 if controls are not supported for Data Sets) ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____ ☐ Variable, explain _____ ☐ Same current value as 1.5.3	*0*	
1.5.8 Supports mixing object groups (AOBs, CROBs and Data Sets) in the same control request:	☐ Not applicable – controls are not supported ☑ Yes ☐ No	*Yes*	

1.5 APPLICATION LAYER	Capabilities	Current Value	If configurable, list methods
1.5.9 Control Status Codes Supported: *Indicates which control status codes are supported by the device:* • *Masters must indicate which control status codes they accept in outstation responses.* • *Outstations must indicate which control status codes they generate in responses.* *Control status code 0 (success) must be supported by Masters and Outstations.*	☑ 1 – TIMEOUT ☑ 2 – NO_SELECT ☑ 3 – FORMAT_ERROR ☑ 4 – NOT_SUPPORTED ☑ 5 – ALREADY_ACTIVE ☑ 6 – HARDWARE_ERROR ☑ 7 – LOCAL ☑ 8 – TOO_MANY_OBJS ☑ 9 – NOT_AUTHORIZED ☑ 10 – AUTOMATION_INHIBIT ☑ 11 – PROCESSING_LIMITED ☑ 12 – OUT_OF_RANGE ☐ 13 – DOWNSTREAM_LOCAL ☐ 14 – ALREADY_COMPLETE ☐ 15 – BLOCKED ☐ 16 – CANCELLED ☐ 17 – BLOCKED_OTHER_MASTER ☐ 18 – DOWNSTREAM_FAIL ☐ 126 – RESERVED ☑ 127 – UNDEFINED		

1.6 FILL OUT THE FOLLOWING ITEMS FOR MASTERS ONLY	Capabilities	Current Value	If configurable, list methods
1.6.1 Timeout waiting for Complete Application Layer Response(ms): *Timeout on Master if all fragments of a response message are not received in the specified time.*	☐ None ☐ Fixed at_____ ms ☐ Configurable, range _____ to _____ms ☐ Configurable, selectable from ___,___,___ms ☐ Configurable, other, describe_____ ☐ Variable, explain _____	None	
1.6.2 Maximum Application Layer Retries for Request Messages: *The number of times a Master will retransmit an application layer request message if a response is not received. This parameter must never cause a Master to retransmit time sync messages.*	☐ None ☐ Fixed at_____ ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ___,___,___ ☐ Configurable, other, describe_____ ☐ Variable, explain _____	None	
1.6.3 Timeout waiting for First or Next Fragment of an Application Layer Response: *Timeout between a request and the first fragment of a response, or between subsequent fragments of the same response, or between an Application Layer Confirmation and a subsequent fragment.*	☐ None ☐ Fixed at_____ ms ☐ Configurable, range _____ to _____ms ☐ Configurable, selectable from ___,___,___ms ☐ Configurable, other, describe_____ ☐ Variable, explain _____	None	
1.6.4 Issuing controls to off-line devices: *Indicates if the Master issues control requests to devices that are thought to be off-line (i.e. the Master has not seen responses to previous Master requests).*	☐ Not applicable – controls are not supported ☐ Yes ☐ No	N/A	
1.6.5 Issuing controls to off-scan devices: *Indicates if the Master issues control requests to devices that are currently off-scan (i.e. the Master has been configured not to issue poll requests to the device).*	☐ Not applicable – controls are not supported ☐ Yes ☐ No	N/A	
1.6.6 Maximum Application Layer Retries for Control Select Messages (same sequence number): *Indicates the number of times a Master will retransmit an application layer control select request message if a response is not received – using the same message sequence number.*	☐ None (required) ☐ Fixed at_____ ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ___,___,___ ☐ Configurable, other, describe_____ ☐ Variable, explain _____	None	

1.6 FILL OUT THE FOLLOWING ITEMS FOR MASTERS ONLY	Capabilities	Current Value	If configurable, list methods
1.6.7 Maximum Application Layer Retries for Control Select Messages (new sequence number): *Indicates the number of times a Master will retransmit an application layer control select request message if a response is not received – using a new message sequence number.*	☐ None (required) ☐ Fixed at_____ ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ___,___,___ ☐ Configurable, other, describe_____ ☐ Variable, explain _____	None	
1.6.8 Item deleted			
1.6.9 Item deleted			
1.6.10 Item deleted			
1.6.11 Item deleted			

1.7 FILL OUT THE FOLLOWING ITEMS FOR OUTSTATIONS ONLY	Capabilities	Current Value	If configurable, list methods
1.7.1 Timeout waiting for Application Confirm of solicited response message:	☐ None ☐ Fixed at_____ ms ☑ Configurable, range 1000 to 65535000ms ☐ Configurable, selectable from ___,___,___ms ☐ Configurable, other, describe_____ ☑ Variable, explain **fivefold of Data Link Layer Confirmation Timeout**	*10000ms*	*Proprietary File via Other Mechanism*
1.7.2 How often is time synchronization required from the master: *Details of when the master needs to perform a time synchronization to ensure that the outstation clock does not drift outside of an acceptable tolerance. If the option to relate this to IIN1.4 is used then details of when IIN1.4 is asserted are in section 1.10.2.*	☐ Never needs time ☐ Within _____ seconds after IIN1.4 is set ☐ Periodically, fixed at _____ seconds ☑ Periodically, between 60 and 918000 seconds	*Periodically, every 3600 seconds.* *Note: Time period is configurable*	*Proprietary File via Other Mechanism*
1.7.3 Device Trouble Bit IIN1.6: *If IIN1.6 device trouble bit is set under certain conditions, explain the possible causes.*	☐ Never used ☑ Reason for setting, local S7-CPU in STOP state	*Used as described*	*Proprietary File via Other Mechanism*
1.7.4 File Handle Timeout: *If there is no activity referencing a file handle for a configurable length of time, the outstation must do an automatic close on the file. The timeout value must be configurable up to 1 hour. When this condition occurs the outstation will send a File Transport Status Object (group 70 var 6) using a status code value of file handle expired (0x02).*	☑ Not applicable, files not supported ☐ Fixed at_____ ms ☐ Configurable, range _____ to _____ms ☐ Configurable, selectable from ___,___,___ms ☐ Configurable, other, describe_____ ☐ Variable, explain _____	*Not applicable*	
1.7.5 Event Buffer Overflow Behavior:	☐ Discard the oldest event ☑ Discard the newest event ☐ Other, explain _____	*Discard newest*	

1.7 FILL OUT THE FOLLOWING ITEMS FOR OUTSTATIONS ONLY	Capabilities	Current Value	If configurable, list methods
1.7.6 Event Buffer Organization: *Explain how event buffers are arranged (per Object Group, per Class, single buffer, etc) and specify the number of events that can be buffered.*	☐ Per Object Group (see part 3) ☐Per Class Class 1: ☐Fixed at_____ ☐Configurable, range _____ to _____ ☐Configurable, selectable from ___,___,___ ☐Configurable, other, describe_____ Class 2: ☐Fixed at_____ ☐Configurable, range _____ to _____ ☐Configurable, selectable from ___,___,___ ☐Configurable, other, describe_____ Class 3: ☐Fixed at_____ ☐Configurable, range _____ to _____ ☐ Configurable, selectable from ___,___,___ ☐ Configurable, other, describe_____ ☑ Single Buffer ☐ Fixed at_____ ☑ Configurable, range 1 to 64,000 ☐ Configurable, selectable from ___,___,___ ☐ Configurable, other, describe_____ ☐ Other, describe: _____	*Three class specific buffers for every configured master*	*Proprietary File via Other Mechanism*
1.7.7 Sends Multi-Fragment Responses: *Indicates whether an Outstation sends multi-fragment responses (Masters do not send multi-fragment requests).*	☑ Yes ☐ No	Yes	
1.7.8 Last Fragment Confirmation: *Indicates whether the Outstation requests confirmation of the last fragment of a multi-fragment response.*	☑ Always ☑ Sometimes, explain: Only when it contains events ☑ Never	*Never*	*Proprietary File via Other Mechanism*

1.7 FILL OUT THE FOLLOWING ITEMS FOR OUTSTATIONS ONLY	Capabilities	Current Value	If configurable, list methods
1.7.9 DNP Command Settings preserved through a device restart: *If any of these settings are written through the DNP protocol and they are not preserved through a restart of the Outstation, the Master will have to write them again after it receives a response in which the Restart IIN bit is set.*	☐ Assign Class ☐ Analog Deadbands ☐ Data Set Prototypes ☐ Data Set Descriptors ☐ Function Code 31 Activate Configuration		
1.7.10 Supports configuration signature: *Indicates whether an Outstation supports the Group 0 device attribute "Configuration signature" (variation 200). If yes, list the vendor-defined name(s) of the algorithm(s) available to calculate the signature.* *Note: The algorithm used for calculating the signature is identified by name in a string that can be determined remotely using protocol object Group 0 Variation 201. If only a single algorithm is available, identifying that algorithm in this object is optional.*	☐ Configuration signature supported If configuration signature is supported, then the following algorithm(s) are available for calculating the signature: Algorithm Name: _____		
1.7.11 Requests Application Confirmation: *Indicate if application confirmation is requested:* • *when responding with events* • *when sending non-final fragments of multi-fragment responses* *Note: to be compliant both must be selected as "yes".*	For event responses: ● Yes O No O Configurable For non-final fragments: ● Yes O No O Configurable		
1.7.12 Supports Clock Management *Indicates whether the Outstation supports the clock management functionality:* *- supports timestamped object variations required for its subset level with a time accuracy that is consistent with section 1.10 of this Device Profile* *- if the outstation asserts IIN1.4 [NEED_TIME], it shall support DNP3 time synchronization functionality*	☑ Yes ☐ No		

1.8 OUTSTATION UNSOLICITED RESPONSE SUPPORT	Capabilities	Current Value	If configurable, list methods
1.8.1 Supports Unsolicited Reporting: *When the unsolicited response mode is configured "off", the device is to behave exactly like an equivalent device that has no support for unsolicited responses. If set to On, the Outstation will send a null Unsolicited Response after it restarts, then wait for an Enable Unsolicited Response command from the master before sending additional Unsolicited Responses containing event data.*	☐ Yes ☐ No ☑ Configurable, selectable from On and Off	*On*	*Proprietary File via Other Mechanism*
1.8.2 Master Data Link Address: *The destination address of the master device where the unsolicited responses will be sent.*	☐ Fixed at_____ ☑ Configurable, range 0 to 65519 ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____	*Depends on partner number*	*Proprietary File via Other Mechanism*
1.8.3 Unsolicited Response Confirmation Timeout: *This is the amount of time that the outstation will wait for an Application Layer confirmation back from the master indicating that the master received the unsolicited response message. As a minimum, the range of configurable values must include times from one second to one minute. This parameter may be the same one that is used for normal, solicited, application confirmation timeouts, or it may be a separate parameter.*	☐ Fixed at_____ ms ☑ Configurable, range 1000 to 65535000 ms ☐ Configurable, selectable from ___,___,___ms ☐ Configurable, other, describe_____ ☐ Variable, explain _____	*5000 ms*	*Proprietary File via Other Mechanism*
1.8.4 Number of Unsolicited Retries: *This is the number of retries that an outstation transmits in each unsolicited response series if it does not receive confirmation back from the master. The configured value includes identical and regenerated retry messages. To be compliant, one of the choices must provide for an indefinite (and potentially infinite) number of transmissions.*	☐ None ☐ Fixed at _____ ☑ Configurable, range 0 to 255 ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____ ☐ Unlimited	*0*	*Proprietary File via Other Mechanism*

1.9 OUTSTATION UNSOLICITED RESPONSE TRIGGER CONDITIONS	Capabilities	Current Value	If configurable, list methods
1.9.1 Number of class 1 events:	☐ Class 1 not used to trigger Unsolicited Responses ☐ Fixed at _____ ☑ Configurable, range 1 to 255 ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____	*1*	*Proprietary File via Other Mechanism*
1.9.2 Number of class 2 events:	☐ Class 2 not used to trigger Unsolicited Responses ☐ Fixed at _____ ☑ Configurable, range 1 to 255 ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____	*1*	*Proprietary File via Other Mechanism*
1.9.3 Number of class 3 events:	☐ Class 3 not used to trigger Unsolicited Responses ☐ Fixed at _____ ☑ Configurable, range 1 to 255 ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____	*1*	*Proprietary File via Other Mechanism*
1.9.4 Total number events from any class:	☑ Total Number of Events not used to trigger Unsolicited Responses ☐ Fixed at _____ ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		
1.9.5 Hold time after class 1 event: *A value of 0 indicates that responses are not delayed due to this parameter.*	☐ Class 1 not used to trigger Unsolicited Responses ☐ Fixed at _____ ms ☑ Configurable, range 0 to 65535000 ms ☐ Configurable, selectable from ____,____,____ ms ☐ Configurable, other, describe_____ ☐ Use value specified in section 1.9.8	*0ms*	*Proprietary File via Other Mechanism*
1.9.6 Hold time after class 2 event: *A value of 0 indicates that responses are not delayed due to this parameter.*	☐ Class 2 not used to trigger Unsolicited Responses ☐ Fixed at _____ ms ☑ Configurable, range 0 to 65535000 ms ☐ Configurable, selectable from ____,____,____ ms ☐ Configurable, other, describe_____ ☐ Same current value as 1.9.8	*0ms*	*Proprietary File via Other Mechanism*

1.9 OUTSTATION UNSOLICITED RESPONSE TRIGGER CONDITIONS	Capabilities	Current Value	If configurable, list methods
1.9.7 Hold time after class 3 event: *A value of 0 indicates that responses are not delayed due to this parameter.*	☐ Class 3 not used to trigger Unsolicited Responses ☐ Fixed at _____ ms ☑ Configurable, range 0 to 65535000 ms ☐ Configurable, selectable from ____,____,____ ms ☐ Configurable, other, describe_____ ☐ Same current value as 1.9.8	*0ms*	*Proprietary File via Other Mechanism*
1.9.8 Hold time after event assigned to any class: *A configured value of 0 indicates that responses are not delayed due to this parameter.*	☑ Class events not used to trigger Unsolicited Responses ☐ Fixed at _____ ms ☐ Configurable, range _____ to _____ ms ☐ Configurable, selectable from ____,____,____ ms ☐ Configurable, other, describe_____	*0ms*	
1.9.9 Retrigger Hold Timer: *The hold-time timer may be retriggered for each new event detected (increased possibly of capturing all the changes in a single response) or not retriggered (giving the master a guaranteed update time).*	☐ Hold-time timer will be retriggered for each new event detected (may get more changes in next response) ☑ Hold-time timer will not be retriggered for each new event detected (guaranteed update time)	*Not retriggered*	
1.9.10 Other Unsolicited Response Trigger Conditions:	_____		

1.10 OUTSTATION PERFORMANCE	Capabilities	Current Value	If configurable, list methods
1.10.1 Maximum Time Base Drift (milliseconds per minute): *If the device is synchronized by DNP, what is the clock drift rate over the full operating temperature range.*	☑ Fixed at 1 ms ☐ Range _____ to _____ ms ☐ Selectable from ____,____,____ ms ☐ Other, describe_____	*1ms*	
1.10.2 When does outstation set IIN1.4: *When does the outstation set the internal indication IIN1.4 NEED_TIME.*	☐ Never ☑ Asserted at startup until first Time Synchronization request received ☐ Periodically every____ seconds ☐ Periodically, range ____to____ seconds ☐ Periodically, selectable from ____,____,___ seconds ☐ ____ seconds after last time sync ☑ Range 60 to 918000 seconds after last time sync ☐ Selectable from___,___,___ seconds after last time sync ☐ When time error may have drifted by ____ ms ☐ When time error may have drifted by range ____to____ ms ☐ When time error may have drifted by selectable from ____,____,___ ms	*At startup* *3600 seconds after last sync* *Note: Time Sync Request is set at configurable time period*	*Proprietary File via Other Mechanism*
1.10.3 Maximum Internal Time Reference Error when set via DNP (ms): *The difference between the time set in a DNP Write Time message, and the time actually set in the Outstation.*	☑ Fixed at 100 ms ☐ Range _____ to _____ ms ☐ Selectable from ____,____,____ ms ☐ Other, describe_____	*100ms*	
1.10.4 Maximum Delay Measurement error (ms): *The difference between the time reported in the delay measurement response and the actual time between receipt of the delay measurement request and issuing the delay measurement reply.*	☑ Fixed at 100 ms ☐ Range _____ to _____ ms ☐ Selectable from ____,____,____ ms ☐ Other, describe_____	*100ms*	
1.10.5 Maximum Response time (ms): *The amount of time an Outstation will take to respond upon receipt of a valid request. This does not include the message transmission time.*	☑ Fixed at 1000 ms ☐ Range _____ to _____ ms ☐ Selectable from ____,____,____ ms ☐ Other, describe_____	*1000ms*	

1.10 OUTSTATION PERFORMANCE	Capabilities	Current Value	If configurable, list methods
1.10.6 Maximum time from start-up to IIN 1.4 assertion (ms):	☑ Fixed at 3000 ms ☐ Range _____ to _____ ms ☐ Selectable from ____,____,____ ms ☐ Other, describe_____	*3000ms*	
1.10.7 Maximum Event Time-tag error for local Binary and Double-bit I/O (ms): *The error between the time-tag reported and the absolute time of the physical event. This error includes the Internal Time Reference Error.* *Note: The current value of this parameter is available remotely using protocol object Group 0 Variation 217.*	☑ Fixed at 200 ms ☐ Range _____ to _____ ms ☐ Selectable from ____,____,____ ms ☐ Other, describe_____ Note: It depends on the number of configured datapoints.	*200ms*	
1.10.8 Maximum Event Time-tag error for local I/O other than Binary and Double-bit data types (ms):	☑ Fixed at 200 ms ☐ Range _____ to _____ ms ☐ Selectable from ____,____,____ ms ☐ Other, describe_____ Note: It depends on the number of configured datapoints.	*200ms*	

1.11 INDIVIDUAL FIELD OUTSTATION PARAMETERS:	Value of Current Setting	If configurable, list methods
1.11.1 User-assigned location name or code string (same as g0v245):	*not supported*	
1.11.2 User-assigned ID Code/number string (same as g0v246):	*supported (MAC-Address as string)*	
1.11.3 User-assigned name string for the outstation (same as g0v247):	*supported (CP-Name)*	
1.11.4 Device Serial Number string (same as g0v248):	*supported*	
1.11.5 User-assigned secondary operator name (same as g0v206):	*not supported*	
1.11.6 User-assigned primary operator name (same as g0v207):	*not supported*	
1.11.7 User-assigned system name (same as g0v208):	*not supported*	
1.11.8 User-assigned owner name (same as g0v244):	*not supported*	

1.12 SECURITY PARAMETERS	Capabilities	Current Value	If configurable, list methods
1.12.1 DNP3 device support for secure authentication: *If the device does not support secure authentication then ignore the rest of this section.* *If the device does support secure authentication then specify the version(s) that are supported in the device. The version number is an integer value defined in the DNP3 Specification. The Secure Authentication procedure defined in IEEE 1815-2010 is version 2. The Secure Authentication procedure defined in IEEE 1815-2012 is version 5.*	Supported version(s): ☑ Fixed at V5 ☐ Configurable, selectable from ____,____,____	*Supports security Version: V5*	
1.12.2 Maximum number of users: *The secure authentication algorithm provides support for multiple users. The device must support details for each user (update keys, session keys, etc). A user is identified by a 16-bit user number, allowing a maximum of 65535 users. Devices are not mandated to support this number of potential users. Indicate here the actual limit to the number of simultaneous users that can be supported.*	☑ Fixed at 1 ☐ Configurable, range _____ to _____	*Maximum number of users supported: 1*	
1.12.3 Security message response timeout: *Authentication of critical messages may involve additional message exchanges (challenges and responses) which can require an extension to the normal DNP3 message response timeout. This timeout specifies an additional time to be used when the extra security transactions are involved. The maximum allowable timeout extension should not exceed 120 seconds.*	☐ Fixed at _____ ms ☑ Configurable, range 0 to 65535000 ms ☐ Configurable, selectable from ____,____,____ ms ☐ Configurable, other, describe_____	*0*	*Proprietary File via Other Mechanism*
1.12.4 Aggressive mode of operation (receive): *DNP3 devices may (optionally) accept "aggressive" mode requests, where challenge data used for authentication is appended to a critical message rather than needing to be solicited via a separate message exchange.*		● *Yes - accepts aggressive mode requests* ○ *No – does not accept aggressive mode requests*	*Proprietary File via Other Mechanism*

1.12 SECURITY PARAMETERS	Capabilities	Current Value	If configurable, list methods
1.12.5 Aggressive mode of operation (issuing): *DNP3 devices must support the issuing of "aggressive" mode of operation, where challenge data used for authentication is appended to a critical message rather than needing to be solicited via a separate message exchange. Specific instances of devices may have the use of aggressive mode switched off.*		● *Yes - issues aggressive mode requests* O *No – does not issue aggressive mode requests*	*Proprietary File via Other Mechanism*
1.12.6 Session Key change interval: *To counter an attack that compromises the session key, the session key is changed at regular intervals. The maximum interval is 2 hours. Outstation devices invalidate the current set of session keys if they have not been changed by the master station after a period of twice this configured value.* *To accommodate systems with infrequent communications, this change interval can be disabled and just the session key change message count used (see 1.12.7)*	☑ Can be disabled When enabled: ☑ Configurable, range 1 to 3932100 seconds	*Enabled 900 seconds*	
1.12.7 Session Key change message count: *In addition to changing the session key at regular intervals, the key shall also be changed after a specified number of messages have been exchanged. The maximum allowable value for this message count is 10,000*	☑ Configurable, range 1 to 10000	*1000*	*Proprietary File via Other Mechanism*
1.12.8 Maximum error count (SAv2 only): *To assist in countering denial of service attacks when using SAv2, a DNP3 device shall stop replying with error codes after a number of successive authentication failures. This error count has a maximum value of 10. Setting the error count to zero inhibits all error messages.* *See 1.12.21 for error counts when using SAv5*	☐ Not applicable (not using SAv2) ☐ Configurable, range _____ to _____		

1.12 SECURITY PARAMETERS	Capabilities	Current Value	If configurable, list methods
1.12.9 MAC algorithm requested in a challenge exchange: *Part of the authentication message is hashed using an MAC algorithm. Secure Authentication version 2 specifies that DNP3 devices must support SHA-1 and may optionally support SHA-256 for this hashing process. Secure Authentication version 5 specifies that SHA-256 is the default. The output of the MAC algorithm is truncated (the resulting length dependent on the media being used).*	☐ SHA-1 (truncated to the leftmost 4 octets) ☐ SHA-1 (truncated to the leftmost 8 octets) ☑ SHA-1 (truncated to the leftmost 10 octets) ☐ SHA-256 (truncated to the leftmost 8 octets) ☑ SHA-256 (truncated to the leftmost 16 octets) ☐ AES-GMAC ☐ Other, explain _____	*SHA-256 (16)*	*Proprietary File via Other Mechanism*
1.12.10 Key-wrap algorithm to encrypt session keys: *During the update of a session key, the key is encrypted using AES-128 or optionally using other algorithms.*	☑ AES-128 ☑ AES-256 ☐ Other, explain _____	*AES-128*	*Proprietary File via Other Mechanism*
1.12.11 Cipher Suites used with DNP implementations using TLS: *When TLS is supported, DNP3 Secure Authentication mandates the support of TLS_RSA_WITH_AES_128_SHA. The specification has a number of recommended cipher suite combinations. Indicate the supported Cipher Suites for implementations using TLS.*	☑ Not relevant – TLS is not used ☐ TLS_RSA encrypted with AES128 ☐ TLS_RSA encrypted with RC4_128 ☐ TLS_RSA encrypted with 3DES_EDE_CBC ☐ TLS_DH, signed with DSS, encrypted with 3DES_EDE_CBC ☐ TLS_DH, signed with RSA, encrypted with 3DES_EDE_CBC ☐ TLS_DHE, signed with DSS, encrypted with 3DES_EDE_CBC ☐ TLS_DHE, signed with RSA, encrypted with 3DES_EDE_CBC ☐ TLS_DH, signed with DSS, encrypted with AES128 ☐ TLS_DH, signed with DSS, encrypted with AES256 ☐ TLS_DH encrypted with AES128 ☐ TLS_DH encrypted with AES256 ☐ Other, explain _____	*Not relevant*	

1.12 SECURITY PARAMETERS	Capabilities	Current Value	If configurable, list methods
1.12.12 Change cipher request timeout: *Implementations using TLS shall terminate the connection if a response to a change cipher request is not seen within this timeout period.*	☑ Not relevant – TLS is not used ☐ Fixed at _____ ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____	*Not relevant*	
1.12.13 Number of Certificate Authorities supported: *Implementations using TLS shall support at least 4 Certificate Authorities. Indicate the number supported.*		*0*	
1.12.14 Certificate Revocation check time: *Implementations using TLS shall evaluate Certificate Revocation Lists on a periodic basis, terminating a connection if a certificate is revoked.*	☑ Not relevant – TLS is not used ☐ Fixed at _____ hours ☐ Configurable, range _____ to _____hours ☐ Configurable, selectable from ____,____,____hours ☐ Configurable, other, describe_____	*Not relevant*	
1.12.15 Additional critical function codes: *The DNP3 specification defines those messages with specific function codes that are critical and must be used as part of a secure authentication message exchange. Messages with other function codes are optional and changes to this list should be noted here.* *Note: Secure Authentication version 5 defines additional functions as critical that were not considered critical in version 2. These are shown in the next column annotated with "V2 only".*	Additional function codes that are to be considered as "critical": ☐ 0 (Confirm) ☐ 1 (Read) ☐ 7 (Immediate freeze) ☐ 8 (Immediate freeze – no ack) ☐ 9 (Freeze-and-clear) ☐ 10 (Freeze-and-clear – no ack) ☐ 11 (Freeze-at-time) ☐ 12 (Freeze-at-time – no ack) ☐ 22 (Assign Class) ☐ 23 (Delay Measurement) ☐ 25 (Open File) – V2 only ☐ 26 (Close File) – V2 only ☐ 27 (Delete File) – V2 only ☐ 28 (Get File Info) – V2 only ☐ 30 (Abort File) – V2 only ☐ 129 (Response) ☐ 130 (Unsolicited Response)		

1.12 SECURITY PARAMETERS	Capabilities	Current Value	If configurable, list methods
1.12.16 Other critical fragments: *Other critical transactions can be defined and should be detailed here. Examples could be based on time (for example: the first transaction after a communications session is established). Other examples could be based on specific data objects (for example: the reading of specific data points).*	Describe any other critical fragment exchanges:		
1.12.17 Support for remote update key changes: *Devices implementing secure authentication version 5 or later have the option to support remote update key changes. If remote update key change is supported then the procedure using symmetric cryptography is mandatory. Additional support for the procedure using asymmetric (public key) cryptography is optional.*	☐ Remote update key change by symmetric cryptography. Supported key change methods: ☐ AES-128 key wrap with SHA-1-HMAC ☐ AES-256 key wrap with SHA-256-HMAC ☐ AES-256 key wrap with AES-GMAC ☐ Remote update key change by asymmetric cryptography Supported key change methods: ☐ RSAES-OAEP-1024/SHA-1 with DSA SHA-1 and SHA-1-HMAC ☐ RSAES-OAEP-2048/SHA-256 with DSA SHA-256 and SHA-256-HMAC ☐ RSAES-OAEP-3072/SHA-256 with DSA SHA-256 and SHA-256-HMAC ☐ RSAES-OAEP-2048/SHA-256 with DSA SHA-256 and AES-GMAC ☐ RSAES-OAEP-3072/SHA-256 with DSA SHA-256 and AES-GMAC		
1.12.18 "Default" user credentials are permitted to expire:	☐ Yes ☐ No		
1.12.19 Secure Authentication enabled:	☑ Configurable, selectable from On and Off ☐ Always On		

1.12 SECURITY PARAMETERS	Capabilities	Current Value	If configurable, list methods
1.12.20 Length of the challenge data: *The length of the challenge data used when setting up session keys shall be between a minimum length of 4 octets and a maximum length of 32 octets.*	☐ Fixed at _____ octets ☐ Configurable, range _____ to _____ octets ☐ Configurable, selectable from ____,____,____ octets ☐ Configurable, other, describe_____		
1.12.21 Maximum statistic counts (SAv5): *The SAv5 specification allows event objects to be generated when the statistics reach certain threshold values. Indicate here how these thresholds are set if using SAv5.* *Note that "Max Rekeys Due to Restarts" only applies to Masters and can be omitted from the Device Profile for Outstations.*	**Max Authentication Failures:** ☐ Not applicable (not using SAv5) ☐ Configurable, range _____ to _____ **Max Reply Timeouts:** ☐ Not applicable (not using SAv5) ☐ Configurable, range _____ to _____ **Max Authentication Rekeys:** ☐ Not applicable (not using SAv5) ☐ Configurable, range _____ to _____ **Max Error Messages Sent:** ☐ Not applicable (not using SAv5) ☐ Configurable, range _____ to _____ **Max Rekeys Due to Restarts:** ☐ Not applicable (not using SAv5) ☐ Configurable, range _____ to _____		

2 Capabilities and Current Settings for Device Database (Outstations Only)

The following tables identify the capabilities and current settings for each DNP3 data type. Details defining the data points available in the device are shown in part 5 of this Device Profile.

2.1 BINARY INPUTS Static (Steady-State) Group Number: **1** Event Group Number: **2**	**Capabilities** **(leave tick-boxes blank if this data type is not supported)**	**Current Value**	**If configurable, list methods**
2.1.1 Static Variation reported when variation 0 requested or in response to Class polls:	☐ Variation 1 – packed format ☑ Variation 2 – with flag ☐ Based on point Index (add column to table in part 5)	*Two*	
2.1.2 Event Variation reported when variation 0 requested or in response to Class polls: *Note: The support for binary input events can be determined remotely using protocol object Group 0 Variation 237.*	☐ Variation 1 – without time ☑ Variation 2 – with absolute time ☐ Variation 3 – with relative time ☐ Based on point Index (add column to table in part 5)	*Two*	
2.1.3 Event reporting mode: *When responding with event data and more than one event has occurred for a data point, an Outstation may include all events or only the most recent event. "All events" must be checked to be compliant.*	☐ Only most recent ☑ All events ☐ Based on point Index (add column to table in part 5)	*All events*	
2.1.4 Binary Inputs included in Class 0 response:	☑ Always ☐ Never ☐ Only if the point is assigned to a class ☐ Based on point Index (add column to table in part 5)	*Always* *Note: changeable via configuration*	*Proprietary File via Other Mechanism*
2.1.5 Binary Inputs Event Buffer Organization: *When event buffers are allocated per object group (see part 1.7.6), indicate the number of events that can be buffered for Binary Inputs. If event buffers are not allocated per object group then set "Fixed at 0".*	☑ Fixed at 0 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		

2.2 DOUBLE-BIT BINARY INPUTS Static (Steady-State) Group Number: **3** Event Group Number: **4**	**Capabilities** **(leave tick-boxes blank if this data type is not supported)**	**Current Value**	**If configurable, list methods**
2.2.1 Static Variation reported when variation 0 requested or in response to Class polls: *Note: The support for double-bit binary inputs can be determined remotely using protocol object Group 0 Variation 234.*	☐ Variation 1 – packed format ☐ Variation 2 – with flag ☐ Based on point Index (add column to table in part 5)		
2.2.2 Event Variation reported when variation 0 requested or in response to Class polls:	☐ Variation 1 – without time ☐ Variation 2 – with absolute time ☐ Variation 3 – with relative time ☐ Based on point Index (add column to table in part 5)		
2.2.3 Event reporting mode: *When responding with event data and more than one event has occurred for a data point, an Outstation may include all events or only the most recent event. "All events" must be checked to be compliant.*	☐ Only most recent ☐ All events ☐ Based on point Index (add column to table in part 5)		
2.2.4 Double-bit Binary Inputs included in Class 0 response:	☐ Always ☐ Never ☐ Only if the point is assigned to a class ☐ Based on point Index (add column to table in part 5)		
2.2.5 Double-bit Binary Inputs Event Buffer Organization: *When event buffers are allocated per object group (see part 1.7.6), indicate the number of events that can be buffered for Double-bit Binary Inputs. If event buffers are not allocated per object group then set "Fixed at 0".*	☐ Fixed at _____ ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		

2.3 BINARY OUTPUT STATUS AND CONTROL RELAY OUTPUT BLOCK Binary Output Status Group Number: **10** Binary Output Event Group Number: **11** CROB Group Number: **12** Binary Output Command Event Group Number: **13**	**Capabilities** **(leave tick-boxes blank if this data type is not supported)**	**Current Value**	**If configurable, list methods**
2.3.1 Minimum pulse time allowed with Trip, Close, and Pulse On commands:	☑ Fixed at 1000 ms (hardware may limit this further) ☐ Based on point Index (add column to table in part 5)	*Note: Pulse On in combination with Close or Trip is not supported.*	
2.3.2 Maximum pulse time allowed with Trip, Close, and Pulse On commands:	☑ Fixed at 65535 ms (hardware may limit this further) ☐ Based on point Index (add column to table in part 5)	*Note: Pulse On in combination with Close or Trip is not supported*	
2.3.3 Binary Output Status included in Class 0 response:	☐ Always ☑ Never ☐ Only if the point is assigned to a class ☐ Based on point Index (add column to table in part 5)	*Never* *Note: changeable via configuration*	*Proprietary File via Other Mechanism*
2.3.4 Reports Output Command Event Objects:	☑ Never ☐ Only upon a successful Control ☐ Upon all control attempts	*Never*	
2.3.5 Static Variation reported when variation 0 requested or in response to Class polls:	☐ Variation 1 – packed format ☑ Variation 2 – output status with flags ☐ Based on point Index (add column to table in part 5)	*Two*	
2.3.6 Event Variation reported when variation 0 requested or in response to Class polls: *Note: The support for binary output events can be determined remotely using protocol object Group 0 Variation 222.*	☐ Variation 1 – status without time ☑ Variation 2 – status with time ☐ Based on point Index (add column to table in part 5)	*Two*	
2.3.7 Command Event Variation reported when variation 0 requested or in response to Class polls:	☐ Variation 1 – command status without time ☐ Variation 2 – command status with time ☐ Based on point Index (add column to table in part 5)		
2.3.8 Event reporting mode: *When responding with event data and more than one event has occurred for a data point, an Outstation may include all events or only the most recent event*	☐ Only most recent ☑ All events	*All events*	

2.3 BINARY OUTPUT STATUS AND CONTROL RELAY OUTPUT BLOCK Binary Output Status Group Number: **10** Binary Output Event Group Number: **11** CROB Group Number: **12** Binary Output Command Event Group Number: **13**	**Capabilities** **(leave tick-boxes blank if this data type is not supported)**	**Current Value**	**If configurable, list methods**
2.3.9 Command Event reporting mode: *When responding with event data and more than one event has occurred for a data point, an Outstation may include all events or only the most recent event*	☐ Only most recent ☐ All events		
2.3.10 Maximum Time between Select and Operate:	☐ Not Applicable ☐ Fixed at _____ seconds ☑ Configurable, range 1 to 65535 seconds ☐ Configurable, selectable from___,___,___ seconds ☐ Configurable, other, describe_____ ☐ Variable, explain _____ ☐ Based on point Index (add column to table in part 5)	*1 second*	*Proprietary File via Other Mechanism*
2.3.11 Binary Outputs Event Buffer Organization: When event buffers are allocated per object group (see part 1.7.6), indicate the number of events that can be buffered for Binary Outputs. If event buffers are not allocated per object group then set “Fixed at 0”.	☑ Fixed at 0 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		
2.3.12 Binary Output Commands Event Buffer Organization: When event buffers are allocated per object group (see part 1.7.6), indicate the number of events that can be buffered for Binary Output Commands. If event buffers are not allocated per object group then set “Fixed at 0”.	☑ Fixed at 0 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		

2.4 COUNTERS / FROZEN COUNTERS Counter Group Number: **20** Frozen Counter Group Number: **21** Counter Event Group Number: **22** Frozen Counter Event Group Number: **23**	**Capabilities** **(leave tick-boxes blank if this data type is not supported)**	**Current Value**	**If configurable, list methods**
2.4.1 Static Counter Variation reported when variation 0 requested or in response to Class polls:	☑ Variation 1 – 32-bit with flag ☑ Variation 2 – 16-bit with flag ☐ Variation 5 – 32-bit without flag ☐ Variation 6 – 16-bit without flag ☐ Based on point Index (add column to table in part 5)	*One*	
2.4.2 Counter Event Variation reported when variation 0 requested or in response to Class polls: *Note: The support for counter events can be determined remotely using protocol object Group 0 Variation 227.*	☑ Variation 1 – 32-bit with flag ☑ Variation 2 – 16-bit with flag ☑ Variation 5 – 32-bit with flag and time ☑ Variation 6 – 16-bit with flag and time ☐ Based on point Index (add column to table in part 5)	*Note: Variation in the response depends on the DNP level of Master and the configured variable type*	*Proprietary File via Other Mechanism*
2.4.3 Counters included in Class 0 response:	☑ Always ☐ Never ☐ Only if the point is assigned to a class ☐ Based on point Index (add column to table in part 5)	*Always* *Note: changeable via configuration*	*Proprietary File via Other Mechanism*
2.4.4 Counter Event reporting mode: *When responding with event data and more than one event has occurred for a data point, an Outstation may include all events or only the most recent event. Only the most recent event is typically reported for Counters. When reporting "only most recent", the counter value reported in the response may be the value at the time of the original event or it may be the value at the time of the response.*	☐ Only most recent (value at time of event) ☐ Only most recent (value at time of response) ☑ All events ☐ Based on point Index (add column to table in part 5)	*All events*	
2.4.5 Static Frozen Counter Variation reported when variation 0 requested or in response to Class polls:	☑ Variation 1 – 32-bit with flag ☑ Variation 2 – 16-bit with flag ☑ Variation 5 – 32-bit with flag and time ☑ Variation 6 – 16-bit with flag and time ☐ Variation 9 – 32-bit without flag ☐ Variation 10 – 16-bit without flag ☐ Based on point Index (add column to table in part 5)	*Note: Variation in the response depends on the DNP level of Master and the configured variable type*	*Proprietary File via Other Mechanism*

2.4 COUNTERS / FROZEN COUNTERS Counter Group Number: **20** Frozen Counter Group Number: **21** Counter Event Group Number: **22** Frozen Counter Event Group Number: **23**	**Capabilities** **(leave tick-boxes blank if this data type is not supported)**	**Current Value**	**If configurable, list methods**
2.4.6 Frozen Counter Event Variation reported when variation 0 requested or in response to Class polls: *Note: The support for frozen counter events can be determined remotely using protocol object Group 0 Variation 225.*	☑ Variation 1 – 32-bit with flag ☑ Variation 2 – 16-bit with flag ☑ Variation 5 – 32-bit with flag and time ☑ Variation 6 – 16-bit with flag and time ☐ Based on point Index (add column to table in part 5)	*Note: Variation in the response depends on the DNP level of Master and the configured variable type*	*Proprietary File via Other Mechanism*
2.4.7 Frozen Counters included in Class 0 response:	☑ Always ☐ Never ☐ Only if the point is assigned to a class ☐ Based on point Index (add column to table in part 5)	*Always* *Note: changeable via configuration*	*Proprietary File via Other Mechanism*
2.4.8 Frozen Counter Event reporting mode: *When responding with event data and more than one event has occurred for a data point, an Outstation may include all events or only the most recent event. All events are typically reported for Frozen Counters.*	☐ Only most recent frozen value ☑ All frozen values ☐ Based on point Index (add column to table in part 5)	*All events*	
2.4.9 Counters Roll Over at:	☑ 16 Bits (65,535) ☑ 32 Bits (4,294,967,295) ☐ Other Fixed Value _____ ☐ Configurable; range _____ to_____ ☐ Configurable, selectable from ___,___,___ ☐ Configurable, other, describe_____ ☐ Based on point Index (add column to table in part 5)	*Based on point index*	
2.4.10 Counters frozen by means of:	☑ Master Request ☐ Freezes itself without concern for time of day ☐ Freezes itself and requires time of day ☐ Other, explain _____	*Master Request*	
2.4.11 Counters Event Buffer Organization: *When event buffers are allocated per object group (see part 1.7.6), indicate the number of events that can be buffered for Counters. If event buffers are not allocated per object group then set "Fixed at 0".*	☑ Fixed at 0 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		

2.4 COUNTERS / FROZEN COUNTERS Counter Group Number: **20** Frozen Counter Group Number: **21** Counter Event Group Number: **22** Frozen Counter Event Group Number: **23**	**Capabilities** **(leave tick-boxes blank if this data type is not supported)**	**Current Value**	**If configurable, list methods**
2.4.12 Frozen Counters Event Buffer Organization: *When event buffers are allocated per object group (see part 1.7.6), indicate the number of events that can be buffered for Frozen Counters. If event buffers are not allocated per object group then set "Fixed at 0".*	☑ Fixed at 0 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		
2.4.13 Reports counter events for change of value: *Indicate if counter events are created when the counter value changes.*	☐ Yes for all counters ☐ No for all counters ☑ Configurable, based on point Index (add column to table in part 5)		*Proprietary File via Other Mechanism*

2.5 ANALOG INPUTS / FROZEN ANALOG INPUTS Static (Steady-State) Group Number: **30** Static Frozen Group Number: **31** Event Group Number: **32** Frozen Analog Input Event Group Number: **33** Deadband Group Number: **34**	**Capabilities** **(leave tick-boxes blank if this data type is not supported)**	**Current Value**	**If configurable, list methods**
2.5.1 Static Variation reported when variation 0 requested or in response to Class polls:	☑ Variation 1 – 32-bit with flag ☑ Variation 2 – 16-bit with flag ☐ Variation 3 – 32-bit without flag ☐ Variation 4 – 16-bit without flag ☑ Variation 5 – single-precision floating point with flag ☑ Variation 6 – double-precision floating point with flag ☐ Based on point Index (add column to table in part 5)	*Note: Variation in the response depends on the DNP level of Master and the configured variable type*	*Proprietary File via Other Mechanism*
2.5.2 Event Variation reported when variation 0 requested or in response to Class polls: *Note: The support for analog input events can be determined remotely using protocol object Group 0 Variation 231.*	☐ Variation 1 – 32-bit without time ☐ Variation 2 – 16-bit without time ☑ Variation 3 – 32-bit with time ☑ Variation 4 – 16-bit with time ☐ Variation 5 – single-precision floating point w/o time ☐ Variation 6 – double-precision floating point w/o time ☑ Variation 7 – single-precision floating point with time ☑ Variation 8 – double-precision floating point with time ☐ Based on point Index (add column to table in part 5)	*Note: Variation in the response depends on the DNP level of Master and the configured variable type*	*Proprietary File via Other Mechanism*
2.5.3 Event reporting mode: *When responding with event data and more than one event has occurred for a data point, an Outstation may include all events or only the most recent event. Only the most recent event is typically reported for Analog Inputs. When reporting "only most recent", the analog value reported in the response may be the value at the time of the original event or it may be the value at the time of the response.*	☐ Only most recent (value at time of event) ☐ Only most recent (value at time of response) ☑ All events ☐ Based on point Index (add column to table in part 5)	*All events*	*Proprietary File via Other Mechanism*
2.5.4 Analog Inputs Included in Class 0 response:	☑ Always ☐ Never ☐ Only if the point is assigned to a class ☐ Based on point Index (add column to table in part 5)	*Allways*	

2.5 ANALOG INPUTS / FROZEN ANALOG INPUTS Static (Steady-State) Group Number: **30** Static Frozen Group Number: **31** Event Group Number: **32** Frozen Analog Input Event Group Number: **33** Deadband Group Number: **34**	**Capabilities** **(leave tick-boxes blank if this data type is not supported)**	**Current Value**	**If configurable, list methods**
2.5.5 How Deadbands are set:	☐ A. Global Fixed ☐ B. Configurable through DNP ☑ C. Configurable via other means ☐ D. Other, explain _____ ☐ Based on point Index - column in part 5 specifies which of the options applies, B, C, or D	C	*Proprietary File via Other Mechanism*
2.5.6 Analog Deadband Algorithm: *simple - just compares the difference from the previous reported value* *integrating - keeps track of the accumulated change* *other - indicating another algorithm*	☐ Simple ☑ Integrating ☐ Other, explain _____ ☐ Based on point Index (add column to table in part 5)	*Integrating*	*Proprietary File via Other Mechanism*
2.5.7 Static Frozen Analog Input Variation reported when variation 0 requested or in response to Class polls:	☐ Variation 1 – 32-bit with flag ☐ Variation 2 – 16-bit with flag ☐ Variation 3 – 32-bit with time-of-freeze ☐ Variation 4 – 16-bit with time-of-freeze ☐ Variation 5 – 32-bit without flag ☐ Variation 6 – 16-bit without flag ☐ Variation 7 – Single-precision, floating-point with flag ☐ Variation 8 – Double-precision, floating-point with flag ☐ Based on point Index (add column to table in part 5)		

2.5 ANALOG INPUTS / FROZEN ANALOG INPUTS Static (Steady-State) Group Number: **30** Static Frozen Group Number: **31** Event Group Number: **32** Frozen Analog Input Event Group Number: **33** Deadband Group Number: **34**	**Capabilities** **(leave tick-boxes blank if this data type is not supported)**	**Current Value**	**If configurable, list methods**
2.5.8 Frozen Analog Input Event Variation reported when variation 0 requested or in response to Class polls: *Note: The support for frozen analog input events can be determined remotely using protocol object Group 0 Variation 230.*	☐ Variation 1 – 32-bit without time ☐ Variation 2 – 16-bit without time ☐ Variation 3 – 32-bit with time ☐ Variation 4 – 16-bit with time ☐ Variation 5 – Single-precision, floating-point without time ☐ Variation 6 – Double-precision, floating-point without time ☐ Variation 7 – Single-precision, floating-point with time ☐ Variation 8 – Double-precision, floating-point with time ☐ Based on point Index (add column to table in part 5)		
2.5.9 Frozen Analog Inputs included in Class 0 response:	☐ Always ☐ Never ☐ Only if the point is assigned to a class ☐ Based on point Index (add column to table in part 5)		
2.5.10 Frozen Analog Input Event reporting mode: *When responding with event data and more than one event has occurred for a data point, an Outstation may include all events or only the most recent event. All events are typically reported for Frozen Analog Inputs.*	☐ Only most recent frozen value ☐ All frozen values ☐ Based on point Index (add column to table in part 5)		
2.5.11 Analog Inputs Event Buffer Organization: *When event buffers are allocated per object group (see part 1.7.6), indicate the number of events that can be buffered for Analog Inputs. If event buffers are not allocated per object group then set "Fixed at 0".*	☑ Fixed at 0 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		

2.5 ANALOG INPUTS / FROZEN ANALOG INPUTS Static (Steady-State) Group Number: **30** Static Frozen Group Number: **31** Event Group Number: **32** Frozen Analog Input Event Group Number: **33** Deadband Group Number: **34**	**Capabilities** **(leave tick-boxes blank if this data type is not supported)**	**Current Value**	**If configurable, list methods**
2.5.12 Frozen Analog Inputs Event Buffer Organization: *When event buffers are allocated per object group (see part 1.7.6), indicate the number of events that can be buffered for Frozen Analog Inputs. If event buffers are not allocated per object group then set "Fixed at 0".*	☐ Fixed at _____ ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		

2.6 ANALOG OUTPUTS / ANALOG OUTPUT COMMANDS Analog Output Status Group Number: **40** Analog Outputs Group Number: **41** Analog Output Events Group Number: **42** Analog Output Command Events Group Number: **43**	**Capabilities** **(leave tick-boxes blank if this data type is not supported)**	**Current Value**	**If configurable, list methods**
2.6.1 Static Analog Output Status Variation reported when variation 0 requested or in response to Class polls:	☑ Variation 1 – 32-bit with flag ☑ Variation 2 – 16-bit with flag ☑ Variation 3 – single-precision floating point with flag ☑ Variation 4 – double-precision floating point with flag ☐ Based on point Index (add column to table in part 5)	*Note: Variation in the response depends on the DNP level of Master and the configured variable type*	*Proprietary File via Other Mechanism*
2.6.2 Analog Output Status Included in Class 0 response:	☐ Always ☑ Never ☐ Only if the point is assigned to a class ☐ Based on point Index (add column to table in part 5)	*Never* *Note: changeable via configuration*	*Proprietary File via Other Mechanism*
2.6.3 Reports Output Command Event Objects:	☑ Never ☐ Only upon a successful Control ☐ Upon all control attempts	*Never*	
2.6.4 Event Variation reported when variation 0 requested or in response to Class polls: *Note: The support for analog output events can be determined remotely using protocol object Group 0 Variation 219.*	☐ Variation 1 – 32-bit without time ☐ Variation 2 – 16-bit without time ☑ Variation 3 – 32-bit with time ☑ Variation 4 – 16-bit with time ☐ Variation 5 – single-precision floating point w/o time ☐ Variation 6 – double-precision floating point w/o time ☑ Variation 7 – single-precision floating point with time ☑ Variation 8 – double-precision floating point with time ☐ Based on point Index (add column to table in part 5)	*Note: Variation in the response depends on the DNP level of Master and the configured variable type*	*Proprietary File via Other Mechanism*
2.6.5 Command Event Variation reported when variation 0 requested or in response to Class polls:	☐ Variation 1 – 32-bit without time ☐ Variation 2 – 16-bit without time ☐ Variation 3 – 32-bit with time ☐ Variation 4 – 16-bit with time ☐ Variation 5 – single-precision floating point w/o time ☐ Variation 6 – double-precision floating point w/o time ☐ Variation 7 – single-precision floating point with time ☐ Variation 8 – double-precision floating point with time ☐ Based on point Index (add column to table in part 5)		

2.6 ANALOG OUTPUTS / ANALOG OUTPUT COMMANDS Analog Output Status Group Number: **40** Analog Outputs Group Number: **41** Analog Output Events Group Number: **42** Analog Output Command Events Group Number: **43**	**Capabilities** **(leave tick-boxes blank if this data type is not supported)**	**Current Value**	**If configurable, list methods**
2.6.6 Event reporting mode: *When responding with event data and more than one event has occurred for a data point, an Outstation may include all events or only the most recent event.*	☐ Only most recent ☑ All events	*All events*	
2.6.7 Command Event reporting mode: *When responding with event data and more than one event has occurred for a data point, an Outstation may include all events or only the most recent event.*	☐ Only most recent ☐ All events		
2.6.8 Maximum Time between Select and Operate:	☐ Not Applicable ☐ Fixed at _____ seconds ☑ Configurable, range 1000 to 65636000 seconds ☐ Configurable, selectable from ___,___,___seconds ☐ Configurable, other, describe_____ ☐ Variable, explain _____ ☐ Based on point Index (add column to table in part 5)	*1000 seconds*	*Proprietary File via Other Mechanism*
2.6.9 Analog Outputs Event Buffer Organization: *When event buffers are allocated per object group (see part 1.7.6), indicate the number of events that can be buffered for Analog Outputs. If event buffers are not allocated per object group then set "Fixed at 0".*	☑ Fixed at 0 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		
2.6.10 Analog Output Commands Event Buffer Organization: *When event buffers are allocated per object group (see part 1.7.6), indicate the number of events that can be buffered for Analog Output Commands. If event buffers are not allocated per object group then set "Fixed at 0".*	☐ Fixed at _____ ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		

2.7 FILE CONTROL Group Number: 70	**Capabilities**	**Current Value**	**If configurable, list methods**
2.7.1 File Transfer Supported:	Supported (as defined in section 1.1.8) If not supported then do not complete other entries in section 2.7)		
2.7.2 File Authentication: *Indicates whether a valid authentication key must be obtained prior to open and delete requests.*	☐ Always ☐ Sometimes, explain _____ ☐ Never		
2.7.3 File Append Mode: *Indicates if a file can be opened and appended to versus just overwritten.*	☐ Always ☐ Sometimes, explain _____ ☐ Never		
2.7.4 Permissions Support: *Indicates the device is capable of using the indicated permissions.*	☐ Owner Read Allowed: 0x0100 ☐ Owner Write Allowed: 0x0080 ☐ Owner Execute Allowed: 0x0040 ☐ Group Read Allowed: 0x0020 ☐ Group Write Allowed: 0x0010 ☐ Group Execute Allowed: 0x0008 ☐ World Read Allowed: 0x0004 ☐ World Write Allowed: 0x0002 ☐ World Execute Allowed: 0x0001		
2.7.5 Multiple Blocks in a Fragment: *File data is transferred in a series of blocks of a maximum specified size. This indicates whether only a single block or multiple blocks will be sent in fragment.*	☐ Yes ☐ No		
2.7.6 Max number of Files Open at one time:	☑ Fixed at 0 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		

2.8 OCTET STRING & EXTENDED OCTET STRING POINTS Static (Steady-State) Group Number: **110, 114** Event Group Number: **111, 115**	**Capabilities** **(leave tick-boxes blank if this data type is not supported)**	**Current Value**	**If configurable, list methods**
2.8.1 Event reporting mode: *When responding with event data and more than one event has occurred for a data point, an Outstation may include all events or only the most recent event.*	☐ Only most recent ☑ All events ☐ Based on point Index (add column to table in part 5)	*All events*	
2.8.2 Octet Strings Included in Class 0 response:	☑ Always ☐ Never ☐ Only if the point is assigned to a class ☐ Based on point Index (add column to table in part 5)	*Always*	
2.8.3 Octet Strings Event Buffer Organization: *When event buffers are allocated per object group (see part 1.7.6), indicate the number of events that can be buffered for Octet Strings. If event buffers are not allocated per object group then set "Fixed at 0".*	☑ Fixed at 0 ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		
2.8.4 Object Group Selection *Indicate which object group is used to transport octet string objects.*	☑ Fixed, group 110 for all objects ☐ Fixed, group 114 for all objects ☐ Configurable, group 110 or 114 for all objects ☐ Based on point Index (add column to table in part 5)	*g110*	

2.9 VIRTUAL TERMINAL PORT NUMBERS (POINTS) Static (Steady-State) Group Number: **112** Event Group Number: **113**	**Capabilities**	**Current Value**	**If configurable, list methods**
2.9.1 Virtual Terminals Event Buffer Organization: *When event buffers are allocated per object group (see part 1.7.6), indicate the number of events that can be buffered for Virtual Terminals. If event buffers are not allocated per object group then set "Fixed at 0".*	☐ Fixed at _____ ☐ Configurable, range _____ to _____ ☐ Configurable, selectable from ____,____,____ ☐ Configurable, other, describe_____		

2.10 DATA SET PROTOTYPE Group Number: **85** Variation Number: **1**	**Capabilities**	**Current Value**	**If configurable, list methods**

This version of the Device Profile document has no requirement for describing Data Set Prototype capabilities and current settings. This page is intentionally left blank, existing as a placeholder for future use.

2.11 DATA SET DESCRIPTOR CONTENTS AND CHARACTERISTICS Group Number: **86** Variation Numbers: **1 and 2**	**Capabilities**	**Current Value**	**If configurable, list methods**

This version of the Device Profile document has the requirement for describing Data Set Descriptor capabilities being repeated for each Data Set (details can be found in section 4.11).

3 IMPLEMENTATION TABLE

The following implementation table identifies which object groups and variations, function codes and qualifiers the device supports in both requests and responses. The *Request* columns identify all requests that may be sent by a Master, or all requests that must be parsed by an Outstation. The *Response* columns identify all responses that must be parsed by a Master, or all responses that may be sent by an Outstation.

NOTE	The implementation table must list all functionality implemented in the Device.

DNP OBJECT GROUP & VARIATION			REQUEST Master may issue Outstation must parse		RESPONSE Master must parse Outstation may issue	
Object Group Number	**Variation Number**	**Description**	**Function Codes (dec)**	**Qualifier Codes (hex)**	**Function Codes (dec)**	**Qualifier Codes (hex)**
0	212	Device Attributes - Number of master-defined data set prototypes	1 *(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	213	Device Attributes - Number of outstation-defined data set prototypes	1 *(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	214	Device Attributes - Number of master-defined data sets	1 *(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	215	Device Attributes - Number of outstation-defined data sets	1 *(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	216	Device Attributes - Maximum number of binary output objects per request	1 *(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	217	Device Attributes - Local timing accuracy	1 *(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	218	Device Attributes - Duration of time accuracy	1 *(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	219	Device Attributes - Support for analog output events	1 *(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	220	Device Attributes - Maximum analog output	1 *(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*,

		index				17 *(index)*
0	221	Device Attributes - Number of analog outputs	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	222	Device Attributes - Support for binary output events	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	223	Device Attributes - Maximum binary output index	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	224	Device Attributes - Number of binary outputs	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	225	Device Attributes - Support for frozen counter events	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	226	Device Attributes - Support for frozen counters	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	227	Device Attributes - Support for counter events	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	228	Device Attributes - Maximum counter index	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	229	Device Attributes - Number of counter points	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	231	Device Attributes - Support for analog input events	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	232	Device Attributes - Maximum analog input index	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	233	Device Attributes - Number of analog input points	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	237	Device Attributes - Support for binary input events	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	238	Device Attributes - Maximum binary input index	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	239	Device Attributes - Number of binary input points	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	240	Device Attributes - Maximum transmit	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*,

		fragment size				17 *(index)*
0	241	Device Attributes - Maximum receive fragment size	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	242	Device Attributes - Device manufacturer's software version	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	243	Device Attributes - Device manufacturer's hardware version	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	246	Device Attributes - User-assigned ID code/number	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	247	Device Attributes - User-assigned device name	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	248	Device Attributes - Device serial number	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	249	Device Attributes - DNP subset and conformance	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	250	Device Attributes - Device manufacturer's product name and model	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	252	Device Attributes - Device manufacturer's name	1*(read)*	00 *(start-stop)*	129 *(Response)*	00 *(start-stop)*, 17 *(index)*
0	254	Device Attributes - Non-specific all attributes request	1*(read)*	00 *(start-stop)*, 06 *(no range, or all)*		
0	255	Device Attributes - List of attribute variations	1*(read)*	00 *(start-stop)*, 06 *(no range, or all)*	129 *(Response)*	00 *(start-stop)*, 5B *(free format)*
1	0	Binary Input - any variation				
1	1	Binary Input - Single-bit packed	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129 *(Response)*	00, 01 *(start-stop)*
1	2	Binary Input - Single-bit with flag	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or*	129 *(Response)*	00, 01 *(start-stop)*

				all)		
2	0	Binary Input Change Event - any variation				
2	1	Binary Input Change Event - without time	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*	129, 130	17, 28 *(index)*
2	2	Binary Input Change Event - with absolute time	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*	129, 130	17, 28 *(index)*
10	0	Binary Output Status - any variation				
10	1	Binary Output Status - packed	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129 *(Response)*	00, 01 *(start-stop)*
10	2	Binary Output Status - with flag	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129 *(Response)*	00, 01 *(start-stop)*
11	0	Binary Output Event - any variation				
11	1	Binary Output Event - without time	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129, 130	17, 28 *(index)*
11	2	Binary Output Event - with time	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129, 130	17, 28 *(index)*
12	0	Binary Command - any variation				
12	1	Binary Command - control relay output block (only latch on/off)	3, 4, 5, 6,	17, 28 *(index)*	129 *(Response)*	echo of request
20	0	Counter - any variation				
20	2	Counter - 16-bit with flag	1*(read)*	00, 01 *(start-stop)*,	129 *(Response)*	00, 01 *(start-stop)*

				06 *(no range, or all)*		
21	0	Frozen Counter - any variation				
21	2	Frozen Counter - 16-bit with flag	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129 *(Response)*	00, 01 *(start-stop)*
21	6	Frozen Counter - 16-bit with flag and time	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129 *(Response)*	00, 01 *(start-stop)*
22	0	Counter Change Event - any variation				
22	2	Counter Change Event - 16-bit with flag	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*	129, 130	17, 28 *(index)*
22	6	Counter Change Event - 16-bit with flag and time	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*	129, 130	17, 28 *(index)*
23	0	Frozen Counter Change Event - any variation				
23	2	Frozen Counter Change Event - 16-bit with flag	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*	129, 130	17, 28 *(index)*
23	6	Frozen Counter Change Event - 16-bit with flag and time	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*	129, 130	17, 28 *(index)*
30	0	Analog Input - any variation				
30	1	Analog Input - 32-bit with flag	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129 *(Response)*	00, 01 *(start-stop)*
30	5	Analog Input - single-precision, floating-point	1*(read)*	00, 01 *(start-*	129 *(Response)*	00, 01 *(start-*

		with flag		*stop)*, 06 *(no range, or all)*		*stop)*
32	0	Analog Input Change Event - any variation				
32	1	Analog Input Change Event - 32-bit without time	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*	129, 130	17, 28 *(index)*
32	2	Analog Input Change Event - 16-bit without time	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*	129, 130	17, 28 *(index)*
32	3	Analog Input Change Event - 32-bit with time	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*	129, 130	17, 28 *(index)*
32	4	Analog Input Change Event - 16-bit with time	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*	129, 130	17, 28 *(index)*
32	5	Analog Input Change Event - single-precision, floating-point without time	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*	129, 130	17, 28 *(index)*
32	7	Analog Input Change Event - single-precision, floating-point with time	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*	129, 130	17, 28 *(index)*
40	0	Analog Output Status - any variation				
40	1	Analog Output Status - 32-bit with flag	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129 *(Response)*	00, 01 *(start-stop)*
40	2	Analog Output Status - 16-bit with flag	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or*	129 *(Response)*	00, 01 *(start-stop)*

				all)		
40	3	Analog Output Status - single-precision, floating-point with flag	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129 *(Response)*	00, 01 *(start-stop)*
41	0	Analog Output Block - any variation				
41	1	Analog Output Block - 32-bit	3, 4 ,5 ,6	17, 28 *(index)*	129 *(Response)*	echo of request
41	2	Analog Output Block - 16-bit	3, 4, 5, 6	17, 28 *(index)*	129 *(Response)*	echo of request
41	3	Analog Output Block - single-precision, floating-point	3, 4, 5, 6	17, 28 *(index)*	129 *(Response)*	echo of request
42	0	Analog Output Event - any variation				
42	1	Analog Output Event - 32-bit without time	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129, 130	17, 28 *(index)*
42	2	Analog Output Event - 16-bit without time	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129, 130	17, 28 *(index)*
42	3	Analog Output Event - 32-bit with time	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129, 130	17, 28 *(index)*
42	4	Analog Output Event - 16-bit with time	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129, 130	17, 28 *(index)*
42	5	Analog Output Event - single-precision, floating-point without time	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129, 130	17, 28 *(index)*
42	7	Analog Output Event - single-precision, floating-point with time	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129, 130	17, 28 *(index)*

50	1	Time and Date - absolute time	1, 2	07 *(limited qty = 1)*	129 *(Response)*	07 *(limited qty = 1)*
60	1	Class Objects - class 0 data	1*(read)*	06 *(no range, or all)*		
60	2	Class Objects - class 1 data	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*		
60	2	Class Objects - class 1 data	20*(enable unsol.)*	06 *(no range, or all)*		
60	2	Class Objects - class 1 data	21*(disable unsol.)*	06 *(no range, or all)*		
60	3	Class Objects - class 2 data	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*		
60	3	Class Objects - class 2 data	20*(enable unsol.)*	06 *(no range, or all)*		
60	3	Class Objects - class 2 data	21*(disable unsol.)*	06 *(no range, or all)*		
60	4	Class Objects - class 3 data	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*		
60	4	Class Objects - class 3 data	20*(enable unsol.)*	06 *(no range, or all)*		
60	4	Class Objects - class 3 data	21*(disable unsol.)*	06 *(no range, or all)*		
110	string length	Octet String	1*(read)*	00, 01 *(start-stop)*, 06 *(no range, or all)*	129 *(Response)*	00, 01 *(start-stop)*
110	string length	Octet String	2*(write)*	00, 01 *(start-stop)*, 17, 28 *(index)*		

111	string length	Octet String Change Event	1*(read)*	06 *(no range, or all)*, 07, 08 *(limited qty)*	129 *(Response)*	17, 28 *(index)*
111	string length	Octet String Change Event			130 *(Unsol. Resp.)*	17, 28 *(index)*

---------- End of Device Profile for Reference Device ----------

4 DATA POINTS LIST (OUTSTATIONS ONLY)

This part of the Device Profile shows, for each data type, a table defining the data points available in the device or a description of how this information can be obtained if the database is configurable.

4.1 Definition of Binary Input Point List: *List all addressable points. Points that do not exist (for example, because an option is not installed) shall be omitted from the table.* *Note: the number of binary inputs present in the device, and the maximum binary input index, are available remotely using object Group 0 Variations 239 and 238.*	☐ Fixed, list shown in table below ☐ Configurable (current list may be shown in table below) ☐ Other, explain_____

Binary Input points list:

Point Index	Name	Event Class Assigned (1, 2, 3 or none)	Name for State when value is 0	Name for State when value is 1	Description
0					
1					
2					
: :	Add more rows as necessary				

4.2 Definition of Double-bit Input Point List: *List all addressable points. Points that do not exist (for example, because an option is not installed) shall be omitted from the table.* *Note: the number of double-bit inputs present in the device, and the maximum double-bit input index, are available remotely using object Group 0 Variations 236 and 235.*	☐ Fixed, list shown in table below ☐ Configurable (current list may be shown in table below) ☐ Other, explain_____

Double-bit Input points list:

Point Index	Name	Event Class Assigned (1, 2, 3 or none)	Name for State when value is 0 (Intermediate)	Name for State when value is 1 (Off)	Name for State when value is 2 (On)	Name for State when value is 3 (Indeterminate)	Description
0							
1							
2							
:	Add more rows as necessary						

4.3 Definition of Binary Output Status/Control relay output block (CROB) Point List: *List all addressable points. Points that do not exist (for example, because an option is not installed) shall be omitted from the table.* *Note: the number of binary outputs present in the device, and the maximum binary output index, are available remotely using object Group 0 Variations 224 and 223.*	☐ Fixed, list shown in table below ☐ Configurable (current list may be shown in table below) ☐ Other, explain_____

Binary Output Status and CROB points list:

Point Index	Name	Supported Control Operations											Name for State when value is 0	Name for State when value is 1	Event Class Assigned (1, 2, 3 or none)		Description
		Select/Operate	Direct Operate	Direct Operate – No Ack	Pulse On	Pulse Off	Latch On	Latch Off	Trip	Close	Count > 1	Cancel Currently Running Operation			Change	Command	
0																	
1																	
2																	
:	Add more rows as necessary																

4.4 Definition of Counter/Frozen Counter Point List: *List all addressable points. Points that do not exist (for example, because an option is not installed) shall be omitted from the table.* *Note: the number of counters present in the device, and the maximum counter index, are available remotely using object Group 0 Variations 229 and 228.*	☐ Fixed, list shown in table below ☐ Configurable (current list may be shown in table below) ☐ Other, explain_____

Counter / Frozen Counter points list:

Point Index	Name	Event Class Assigned to Counter Events (1, 2, 3 or none)	Frozen Counter Exists (Yes or No)	Event Class Assigned to Frozen Counter Events (1, 2, 3 or none)	Description
0					
1					
2					
: :	Add more rows as necessary				

4.5 Definition of Analog Input Point List: *List all addressable points. Points that do not exist (for example, because an option is not installed) shall be omitted from the table.* *Note: the number of analog inputs present in the device, and the maximum analog input index, are available remotely using object Group 0 Variations 233 and 232.*	☐ Fixed, list shown in table below ☐ Configurable (current list may be shown in table below) ☐ Other, explain_____

Analog Input points list:

Point Index	Name	Event Class Assigned (1, 2, 3 or none)	Transmitted Value		Scaling		Units	Resolution	Description
			Min	Max	Multiplier	Offset			
0									
1									
2									
: :	Add more rows as necessary								

4.6 Definition of Analog Output Status/Analog Output Block Point List: *List all addressable points. Points that do not exist (for example, because an option is not installed) shall be omitted from the table.* *Note: the number of analog outputs present in the device, and the maximum analog output index, are available remotely using object Group 0 Variations 221 and 220.*	☐ Fixed, list shown in table below ☐ Configurable (current list may be shown in table below) ☐ Other, explain_____

Analog Output points list:

Point Index	Name	Supported Control Operations			Transmitted Value		Scaling		Units	Resolution	Event Class Assigned (1, 2, 3 or none)		Description
		Select/Operate	Direct Operate	Direct Operate – No Ack	Min	Max	Multiplier	Offset			Change	Command	
0													
1													
2													
⋮	Add more rows as necessary												

4.7 Definition of File Names that may be read or written:	☐ Fixed, list shown in table below ☐ Configurable(current list may be shown in table below) ☐ Other, explain_____

Sequential Files list:

File Name	Event Class Assigned (1, 2, 3 or none)	Authentication Required for:			Description
		Read	Write	Delete	
Add more rows as necessary					

4.8 Definition of Octet String and Extended Octet String Point List: *List all addressable points. Points that do not exist (for example, because an option is not installed) shall be omitted from the table.*	☐ Fixed, list shown in table below ☐ Configurable (current list may be shown in table below) ☐ Other, explain_____

Octet String and Extended Octet String points list:

Point Index	Name	Event Class Assigned (1, 2, 3 or none)	Group Number used to transport the object	Description
0				
1				
2				
: :	Add more rows as necessary			

4.9 Definition of Virtual Terminal Port Numbers: *List all addressable points. Points that do not exist (for example, because an option is not installed) shall be omitted from the table.*	☐ Fixed, list shown in table below ☐ Configurable (current list may be shown in table below) ☐ Other, explain_____

Ports list:

Virtual Port Number (Point Index)	Name	Event Class Assigned (1, 2, 3 or none)	Description
0			
1			
2			
⋮	Add more rows as necessary		

4.10 Definition of Data Set Prototypes: *List of all data set prototypes. The following table is repeated for each Data Set Prototype defined.* *Note: the numbers of data set prototypes known to the device are available remotely using the protocol object Group 0 Variations 212 and 213.*	☐ Fixed, Data Set Prototypes are shown in table below ☐ Configurable, list methods:_____ (a list of currently defined Data Set Prototypes may be shown in tables below) ☐ Other, explain_____

Prototype Description:

Element Number	Descriptor Code (check one)							Element Description	Data Type Code (check one)									Maximum Data length	Ancillary Value: **ID = Identifier number** **UUID = UUID value** **NSPC = Prototype namespace** **NAME = Prototype name** **DAEL = Data element name** **CTLS = Control status name** **CTLV = Control value name**
	ID	UUID	NSPC	NAME	DAEL	CTLS	CTLV		NONE	VSTR	UINT	INT	FLT	OSTR	BSTR	TIME	UNCD		
0	X							Mandatory DNP identifier			X								
1		X						UUID assigned to prototype						X					
2																			
:								Add more rows as necessary											

4.11 Definition of Data Set Descriptors: *List of all data set descriptors. The following table is repeated for each Data Set Descriptor defined. Note: the numbers of data sets known to the device are available remotely using the protocol object Group 0 Variations 214 and 215.*	☐ Fixed, Data Set Descriptors are shown in table below ☐ Configurable (current list may be shown in table below) ☐ Other, explain_____

Data Set Description:

4.11.1 Data Set Properties:	☐ Readable ☐ Writable ☐ Outstation maintains a static data set ☐ Outstation generates a data set event ☐ Data set defined by master
4.11.2 Event Class Assigned:	☐ Class 1 ☐ Class 2 ☐ Class 3
4.11.3 Static Data Set included in Class 0 response:	☐ Always ☐ Never ☐ Only if assigned to a class

Element Number	Descriptor Code (check one)						Element Description	Data Type Code (check one)									Maximum Data length	Ancillary Value: **ID = Identifier number** **NAME = Data Set name** **DAEL = Data element name** **CTLS = Control status name** **CTLV = Control value name** **PTYP = UUID and (optional) instance name**
	ID	NAME	DAEL	CTLS	CTLV	PTYP		NONE	VSTR	UINT	INT	FLT	OSTR	BSTR	TIME	UNCD		
0	X						Mandatory DNP identifier			X								
1																		
:							Add more rows as necessary											

4.12 Data Set Descriptor – Point Index Attributes

The following table is optional and correlates data set elements to point indexes of standard DNP3 Data Objects. The element number below refers to the position in the present value (object 87) or event (object 88) data set and will not match the element number in the data set descriptor or data set prototype tables above.

Duplicate this table for each Data Set Descriptor defined

Data Set Description:

Element Number	DNP3 Group Number	Point Index
0		
1		
2		
⋮	Add more rows as necessary	