

Electromagnetic flowmeters

MAG 5000/6000 19" & safety barrier Ex e ia

Operating Instructions • 07/2010



SITRANS F

SIEMENS


Contents

1.	Introduction	3
2.	Installation	4
2.1	Installation of transmitter MAG 5000/6000 19"	4
2.2	Installation of sensor	4
2.3.1	Remote installation - At the sensor	6
2.3.2	Remote installation - Transmitter in 19" insert	6
2.4	Ex survey according to Directive 94/9/EC (ATEX)	7
2.5	Overview and intrinsically safe data	8
2.6	Device identification examples (MAG 1100 Ex labels shown)	8
3.	Electrical connection	9
3.1.1	19" IP 20 version Ex e (ia)	9
3.1.2	19" IP 66 version Ex e (ia)	9
3.2	Transmitter MAG 5000/6000 19"	10
4.	Technical data	11
4.1.1	Dimensions and weight MAG 1100 Ex	11
4.1.2	Dimensions and weight MAG 1100 FOOD Ex	11
4.1.3	Sensor MAG 1100 Ex	12
4.1.4	Sensor MAG 1100 Ex Food	14
4.2.1	Dimensions and weight MAG 3100 Ex	16
4.2.2	Sensor MAG 3100 Ex	17
4.3	Transmitter MAG 5000/6000 19"	20
4.4	Safety barrier (ia)	21
4.5	Output characteristics MAG 5000/6000 19"	22
5.	Commissioning	23
5.1	Keypad and display layout	23
5.2.1	Basic settings	24
5.2.2	Outputs	25
5.2.3	External input	25
5.2.4	Sensor characteristics	26
5.2.5	Language mode	26
5.2.6	Service mode	27
6.	Service	28
6.1	Transmitter check list	28
6.2	Trouble shooting MAG transmitter	29
7.	Ordering	29
8.	Certificates	30
8.1	EC-declaration of conformity	30
8.2	EC type examination certificate	32

1. Introduction




For safety reasons it is important that the following points, especially the points marked with a warning sign, are read and understood before the system is being installed:

- Installation, connection, commissioning and service must be carried out by personnel who are qualified and authorized to do so.
- It is very important that the same people have read and understood the instructions and directions provided in this manual and that they follow the instructions and directions before putting the equipment into use!
- People who are authorized and trained by the owner of the equipment may operate the equipment.
- The installation must ensure that the measuring system is correctly connected and is in accordance with the connection diagram. The transmitter has to be earthed by means of 4 mm² potential equalising conductor.
- In applications where the operating pressure or media can be hazardous in the event of a pipe failure, we recommend that special precautions are taken during the installation of the sensor, such as sensor location, guarding or the use of a pressure relief valve.
- Siemens Flow Instruments can provide assistance with the selection of sensor parts in contact with the media. However, the full responsibility for the selection rests with the customer and Siemens Flow Instruments can take no responsibility for any failure due to material incompatibility.
- Equipment used in hazardous areas must be Ex-approved and marked  .
It is required that the "Special Conditions for Safe Use" provided in the manual and in the Ex certificate must be followed!
- Installation of the equipment must comply with national regulations.
Example EN 60079-14 for the European Community.
- Repair and service can be done by approved Siemens Flow Instruments personnel only.

2. Installation

2.1 Installation of transmitter
MAG 5000/6000 19"


 **Safe area only!**




Transmitter MAG 5000/6000 19" must be installed in the **safe area only!**

2.2 Installation of sensor


 **Hazardous area**

**Category 2 equipment**

Sensors may be installed in zone 1 and zone 2.




The sensor must always be completely full with liquid.




Therefore avoid:

- Installation at the highest point in the pipe system
- Installation in vertical pipes with free outlet




For partially filled pipes or pipes with downward flow and free outlet the flowmeter should be located in a U-tube.


**Installation in vertical pipes**

Recommended flow direction: upwards. This minimizes the effect on the measurement of any gas/air bubbles in the liquid.


2.2 Installation of sensor
(continued)




Installation in horizontal pipes
The sensor must be mounted as shown in the upper figure. Do not mount the sensor as shown in the lower figure. This will position the electrodes at the top where there is possibility for air bubbles and at the bottom where there is possibility for mud, sludge, sand etc. If using empty pipe detection the sensor can be tilted 45°, as shown in the upper figure.



Measuring abrasive liquids and liquids containing particles
Recommended installation is in a vertical/inclined pipe to minimize the wear and deposits in the sensor.




Inlet and outlet conditions
To achieve accurate flow measurement it is essential to have straight lengths of inlet and outlet pipes and a certain distance between pumps and valves. It is also important to centre the flowmeter in relation to pipe flanges and gaskets.



Installation in large pipes
The flowmeter can be installed between two reducers (e.g. DIN 28545). Assuming that at 8° the following pressure drop curve applies. The curves are applicable to water.

Example:
A flow velocity of 3 m/s (V) in a sensor with a diameter reduction from DN 100 to DN 80 ($d_1/d_2 = 0.8$) gives a pressure drop of 2.9 mbar.

2.3.1 Remote installation - At the sensor




Remove the SENSORPROM® unit from the sensor and mount it on the connection plate in the transmitter.

Fit and connect the electrode and coil cables as shown in "Electrical connections" in the handbook. The unscreened cable ends must be kept as short as possible.

The electrode cable and the coil cable must be kept separate to prevent interference. Wire insulation must extend to within 0,5mm of the conductor clamps in the coil terminal block. Tighten the cable glands well to obtain optimum sealing.

2.3.2 Remote installation - Transmitter in 19" insert



1. Fit the SENSORPROM® memory unit on the connection board supplied with the transmitter. The SENSORPROM® unit is supplied with the sensor in the terminal box.
2. Mount the guide rails into the rack system as shown. Distance between guide rails is 20 TE. Guide rails are supplied with the rack system and not with the transmitter.
3. Mount the connection board as shown.
4. Connect the cables as shown under "Electrical connection", in the handbook.
5. Insert the transmitter into the rack system.

2.4 Ex survey according to Directive 94/9/EC (ATEX)

as an example:

II	2G	Ex	d	IIC	T3-T6
----	----	----	---	-----	-------

Directive 94/9/EC (ATEX)

Instrument groups _____

I	Applies to instruments used in underground mining operations, as well as their above ground operations, which can be endangered by mine gas and/or flammable dusts.
II	Applies to instruments used in the remaining areas which can be endangered by a potentially explosive atmosphere.

Instrument category _____

Labelling with gases	Labelling with dusts	Definition
1G (0)	1D (20)	Instruments of this category are for use in areas where ignitable atmospheres, caused by a mixture of air and gasses, vapours or mists or by dust/air mixtures, can exist all of the time or for long periods of time or else frequently.
2G (1)	2D (21)	Instruments of this category are for use in areas where ignitable atmospheres caused, by a mixture of air and gasses, vapours or mists or by dust/air mixtures, can exist some of the time.
3G (2)	3D (22)	Instruments of this category are for use in areas where ignitable atmospheres, caused by a mixture of air and gasses, vapours or mists or by dust/air mixtures, are not likely to exist. However, if they do occur then in all probability, only seldom or for short periods of time.

(The figures in brackets refer to IEC)

Explosion protected electrical equipment = Ex _____

Type of protection _____

Ex protection labelling in square brackets refers to "Associated electrical equipment"

o	Oil encapsulated	i	Intrinsic safety (ia, ib)
p	Pressurized apparatus	n	Non-incentive equipment
q	Powder filling	m	Encapsulation
d	Flameproof enclosure	s	Special protection
e	Increased safety		

Explosion groups _____

Gases and vapours (examples)	Minimum ignition energy [mJ]	EN/IEC
• Ammonia	-	IIA
• Acetone, aircraft fuel, benzene, crude oil, diesel oil, ethane, ethanoic acid, ether, gasolines, heating oil, hexane, methane, propane	0.18	IIA
• Ethylene, isoprene, town gas	0.06	IIB
• Acetylene, carbon disulphide, hydrogen	0.02	IIC


Ignition temperature _____

Maximum surface temperature		EN / IEC
450°C	842°F	T1
300°C	572°F	T2
200°C	392°F	T3
135°C	275°F	T4
100°C	212°F	T5
85°C	185°F	T6

EN/IEC 60079-10

2.5 Overview and intrinsically safe data

MAG 5000/6000
19" IP 20 & IP 65



Can **only** be installed in **safe area!**

Specifications:
Supply: 115-230 V or 24 V

Ambient temperature: -20 to 50°C
Enclosure: IP 20 or IP 65

Terminals **82-83**
IS data transmitter

MAG barriers	ia electrode
U _o	9.3 V
I _o	40 mA
P _o	0.4 W
L _o	23 mH
C _o	500 nF

MAG 1100 Ex & MAG 3100 Ex


All MAG 1100 Ex and MAG 3100 Ex sensors have the following ratings and input parameters:

Category 2 equipment
Sensors may be installed in zone 1 and zone 2.


Sensors intrinsically safe data

Terminals MAG sensor	85-86 coil	82-83 electrode
U _i	30/70 Vpk	30 V
I _i	130 mA	50 mA
P _i	-	0.5 W
L _i	-	2 µH
C _i	-	50 nF

2.6 Device identification examples (MAG 1100 Ex labels shown)




Example
Transmitter
MAG 5000/6000 19" IP 20
and IP 65 label




3. Electrical connection

3. Electrical connection

3.1.1 19" IP 20 version Ex e (ia)



3.1.2 19" IP 66 version Ex e (ia)



1. **Connection terminals to:**
 - Power supply
 - In- and output
2. **Connection terminals to:**
Sensors


▲ Intrinsically safe terminals!

It is an absolute requirement that the terminations of intrinsically safe circuits should be separated by at least 50 mm from any other bare conductor.

Incoming cables should be segregated and kept as short as possible.

The Ex "e" (coil) connections should be stripped such that conductor insulation is within 0.5 mm of cable clamps in the terminal block.

3.2 Transmitter MAG 5000/6000 19"



Installation

- ⚠ 1) Mains supply 115 to 230 V AC from building installation Class II. A switch or circuit-breaker (max. 15 A) shall be included in the building installation. It must be in close proximity to the equipment and within easy reach of the OPERATOR, and it shall be marked as the disconnecting device for the equipment.
- ⊕ 2) Protective conductor terminal. Required cable min. AGW16 or 1.5 mm² Cu. The insulation between the connected mains supply and 24 V AC/DC supply for the flowmeters, models 24 V AC/DC shall at least be rated with double or reinforced insulation at mains voltage.
- For field wiring installation **National Installation Code** shall be met of the country, where the flowmeters are installed.

Digital output


If the internal resistance of the loads exceeds 10KΩ, it is recommended to connect an external 10KΩ load resistor in parallel to the load.

4. Technical data

4.1.1 Dimensions and weight MAG 1100 Ex



MAG 1100 Ex




DN	A [mm]	B [mm]	D [mm]	D _i [mm]	D _p [mm]	D _G Ceramic [mm]	Weight [kg]
2	148	173	48.3	2	17.3	34	2.2
3	148	173	48.3	3	17.3	34	2.2
6	148	173	48.3	6	17.3	34	2.2
10	148	173	48.3	10	17.3	34	2.2
15	148	173	48.3	15	17.3	40	2.2
25	156	188	63.4	25	28.5	56	2.7
40	168	210	84.0	40	43.4	75	3.4
50	176	227	101.6	50	54.5	90	4.2
65	186	246	120.0	65	62.5	112	5.5
80	192	258	133.0	80	82.5	124	7.0
100	205	284	159.0	100	107.1	150	10.0

4.1.2 Dimensions and weight MAG 1100 FOOD Ex



MAG 1100 FOOD Ex



DN	L [mm]	A [mm]	B [mm]	D [mm]	D _i Ceramic [mm]	Weight [kg]
10	64	148	180.0	64.0	10	2.2
15	64	148	180.0	64.0	15	2.2
25	79	156	194.8	77.5	25	2.7
40	94	168	213.5	91.0	40	3.4
50	104	176	235.5	119.0	50	4.2
65	131	186	251.0	130.0	65	5.5
80	156	192	269.5	155.0	80	7.0
100	186	205	296.5	183.0	100	10.0

4.1.3 Sensor MAG 1100 Ex

Version	MAG 1100 Ex	MAG 1100 HT Ex (High temperature)
Measuring principle	Electromagnetic induction	Electromagnetic induction
Excitation frequency	DN 2...65 (1/12" ... 2½"): 12.5 Hz DN 80, 100 (3", 4"): 6.25 Hz	DN 15...50 (1" ... 2"): 12.5 Hz DN 80, 100 (3", 4"): 6.25 Hz
Process connection		
Nominal size		
MAG 1100 (Ceramic)	DN 2...DN 100 (1/12"...4")	DN 15...DN 100 (½"...4")
Mating flanges	EN 1092-1 (DIN 2501), ANSI B16.5 class 150 and 300 or equivalent Option: DN 2...10 (1/12"...3/8"): G½"/NPT ½" pipe connection adapters	EN 1092-1 (DIN 2501), ANSI B16.5 class 150 and 300 or equivalent
Rated operating conditions		
Ambient conditions		
Ambient temperature		
• Sensor	-20...+60°C (-4...+140°F)	-20...+60°C (-4...+140°F) ¹⁾
Temperature of medium		
• MAG 1100 (Ceramic)	-20...+150°C (-4...+300°F)	-20...+180°C (-4...+356°F)
Temperature shock		
• MAG 1100 (Ceramic)		
Duration ≤ 1 min, followed by 10 min rest	DN 2, 3 (1/12", 1/8") No limitations DN 6, 10, 15, 25: Max. ΔT ≤ 80°C/min (¼", 3/8", ½", 1": Max. ΔT ≤ 80 K/min) DN 40, 50, 65: Max. ΔT ≤ 70°C/min (1½", 2", 2½": Max. ΔT ≤ 70 K/min) DN 80, 100: Max. ΔT ≤ 60°C/min (3", 4": Max. ΔT ≤ 60 K/min)	DN 15, 25: Max. ΔT ≤ 80°C/min (½", 1": Max. ΔT ≤ 80 K/min) DN 40, 50: Max. ΔT ≤ 70°C/min (1½", 2": Max. ΔT ≤ 70 K/min) DN 80, 100: Max. ΔT ≤ 60°C/min (3", 4": Max. ΔT ≤ 60 K/min)
Operating pressure		
• MAG 1100 (Ceramic)	DN 2...65: 40 bar (1/12"...2½": 580 psi) DN 80: 37.5 bar (3": 540 psi) DN 100: 30 bar (4": 435 psi) Vacuum: 1x10 ⁻⁶ bar (1.5x10 ⁻⁵ psi)	DN 15...50: 40 bar (½"...2": 580 psi) DN 80: 37.5 bar (3": 540 psi) DN 100: 30 bar (4": 435 psi) Vacuum: 1x10 ⁻⁶ bar (1.5x10 ⁻⁵ psi)
Mechanical load	18 ... 1000 Hz random in x, y, z, directions for 2 hours according to EN 60068-2-36 Sensor: 3.17 grms	18 ... 1000 Hz random in x, y, z, directions for 2 hours according to EN 60068-2-36 Sensor: 3.17 grms
Enclosure rating		
Standard	IP67 to EN 60529 (NEMA 4X/6), 1 mH ₂ O for 30 min	IP67 to EN 60529 (NEMA 4X/6), 1 mH ₂ O for 30 min
EMC	89/336EEC	89/336EEC
Design		
Weight	See dimensional drawings	See dimensional drawings
Material		
Enclosure		
MAG 1100	Stainless steel AISI 316L (1.4404)	Stainless steel AISI 316L (1.4404)
Terminal box	Stainless steel AISI 316 (1.4436)	Stainless steel AISI 316 (1.4436)
Fixing studs	Stainless steel AISI 304 (1.4301), Number and size to EN 1092-1:2001	Stainless steel AISI 304 (1.4301), Number and size to EN 1092-1:2001
Gaskets		
- Standard	EPDM (max. 150°C, PN 40 (max. 300°F, 600 psi)	Graphite (max. 200°C, PN 40 (max. 390°F, 600 psi)
- Option	Graphite (max. 200°C, PN 40 (max. 390°F, 600 psi) PTFE (max. 130°C, PN 25 (max. 270°F, 300 psi)	
Pipe connection adapters: DN 2, 3, 6 and 10 (1/12", 1/8", ¼", 3/8")	- Stainless steel, AISI 316 - Hastelloy - PVDF	

¹⁾ Up to medium temperature of 150°C (300°F).

For medium temperature of 150 to 180°C (300 to 356°F) -20 to +50°C (-4 to +122°F)

4.1.3 Sensor MAG 1100 Ex
(continued)

Version	MAG 1100 Ex	MAG 1100 HT Ex (High temperature)
Liner		
• MAG 1100 (Ceramic)	DN 2, 3 (1/12", 1/8"): Zirconium oxide (ZrO ₂) (ceramic) DN 6 ... 100 (1/4" ... 4"): Aluminium oxide Al ₂ O ₃	DN 15...100 (1/2" ... 4"): Aluminium oxide Al ₂ O ₃
Electrodes		
• MAG 1100 (Ceramic)	DN 10 ...100 (3/8" ... 4") : Platinum with gold / Titanium brazing alloy DN 2 ... 6 (1/12" ... 1/4"): Platinum	Platinum with gold / Titanium brazing alloy
Cable entries	Remote installation 2 x M20	Remote installation 2 x M20
Certificates and approvals		
Conforms to	PED – 97/23EC	PED – 97/23EC
Ex approvals		
• MAG 1100 (Ceramic) ATEX sensor	ATEX 2G D sensor Ex d e ia IIB T3 - T6	ATEX 2G D sensor Ex d e ia IIB T3 - T6

4.1.4 Sensor MAG 1100 Ex FOOD

Measuring principle	Electromagnetic induction
Excitation frequency	DN 10...65 (¼"...2½"): 12.5 Hz
	DN 80...100 (3", 4"): 6.25 Hz
Process connection	
Nominal size	DN 10...DN 100 (3/8"...4")
Process connection	Hygienic adapters available for: <ul style="list-style-type: none"> • Direct welding onto pipe • Clamp fitting • Threaded fitting
Rated operating conditions	
<u>Ambient conditions</u>	
Ambient temperature ¹⁾	
• Sensor	-20...+60 °C (-4...+140°F)
<u>Temperature of medium</u>	
• MAG 1100 Food (Ceramic)	-20...+150°C (-4...+300°F) Suitable for steam sterilization
<u>Temperature shock</u>	
• MAG 1100 Food	
Duration ≤ 1 min, followed by 10 min rest	DN 10, 15, 25: Max. ΔT ≤ 80°C/min (3/8", ½", 1": Max. ΔT ≤ 80 K/min)
	DN 40, 50, 65: Max. ΔT ≤ 70°C/min (1½", 2", 2½": Max. ΔT ≤ 70 K/min)
	DN 80, 100: Max. ΔT ≤ 60°C/min (3", 4": Max. ΔT ≤ 60 K/min)
Operating pressure	
• MAG 1100 Food (Ceramic)	DN 10...65: 40 bar (3/8"...2½": 580 psi)
	DN 80: 37.5 bar (3": 540 psi)
	DN 100: 30 bar (4": 435 psi)
	Vacuum: 1x10 ⁻⁶ bar (1.5 x 10 ⁻⁵ psi) abs
Mechanical load	18 ... 1000 Hz random in x, y z, directions for 2 hours according to EN 60068-2-36
	Sensor: 3.17 grms
Enclosure rating	
Standard	IP67 to EN 60529 (NEMA 4X), 1 mH ₂ O for 30 min
EMC	89/336EEC
Design	
Weight	See dimensional drawings
<u>Material</u>	
Enclosure	
Ex ATEX (remote version only)	Stainless steel AISI 316 (1.4436)
Liner	
• MAG 1100 Food (Ceramic)	Aluminium oxide Al ₂ O ₃ (ceramics)
Electrodes	
• MAG 1100 Food (Ceramic)	Platinum with gold / Titanium brazing alloy
Cable entries	Remote installation 2 x M20
Certificates and approvals	
• MAG 1100 Food (Ceramic)	
Ex ATEX approvals for sensor or compact with MAG 6000 I Ex	ATEX 2G D sensor Ex d e ia IIB T3 - T6
Sensor	FM Class 1 div 2
Conforms to	PED – 97/23/EC and CRN (PFA) FDA


4.1.4 Sensor MAG 1100 Ex
FOOD (continued)

Accessories	
Weld-in adapter	
Adapter for welding onto dairy pipe	Tri-Clover ISP 2037, DIN 11850, SMS 3008, BS 4825-1
• DN 10, 15, 25, 40, 50, 65 and 80 (3/8", 1/2", 1", 1 1/2", 2", 2 1/2" and 3")	PN 40 (600 psi)
• DN 100 (4")	PN 25 (350 psi)
Clamp adapter	Tri-Clamp ISP2852, DIN32676, SMS3016, BS4825-3
• DN 10, 15, 25, 40 and 50 (3/8", 1/2", 1", 1 1/2", and 2")	PN 16 (200 psi)
DN 65, 80 and 100 (2 1/2", 3" and 4")	PN 10 (150 psi)
Thread adapter	
DIN 11851	
• DN 10, 15, 25, and 40 (3/8", 1/2", 1", and 1 1/2")	PN 40 (600 psi)
• DN 50, 65, 80 and 100 (2", 2 1/2", 3" and 4")	PN 25 (350 psi)
ISO 2853, SS3351, BS4825-4	
• DN 10, 15, 25, 40, 50, 65 and 80 (3/8", 1/2", 1", 1 1/2", 2", 2 1/2" and 3")	PN 16 (200 psi)
SMS 1145	
• DN 25, 40, 50, 65 and 80 (1", 1 1/2", 2", 2 1/2" and 3")	PN 6 (80 psi)
Design	
<u>Material</u>	
Adapter	Stainless steel AISI 316/Stainless steel AISI 304 (ISO 2852)
Gasket	
• Standard	EPDM (-20...+150°C (-4...+302°F))
• Option	NBR (-20...+100°C (-4...+212°F))

Note: When combined sensor and adapter, the operating pressure is the lower rated of the pair.

4.2.1 Dimensions and weight MAG 3100 Ex

MAG 3100 Ex



Nominal size		A	B	D ₁	L ¹⁾								AS 2129 E AS 4087 PN 16, 21, 35	AWWA C-207 Class D	T _C ²⁾	T _E ²⁾	Weight ³⁾
					EN 1092-1-2001						ANSI 16.5						
					PN 6, 10	PN 16/ PN 16 non PED	PN 25	PN 40	PN 63	PN 100	Class 150	Class 300					
[mm]	[inch]	[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[kg]
15	½	174	59	104	-	-	-	200	-	-	200	200	200	-	-	6	4
25	1	174	59	104	-	-	-	200	-	260	200	200	200	-	1.2	6	5
40	1½	184	82	124	-	-	-	200	-	280	200	200	200	-	1.2	6	8
50	2	192	72	139	-	-	-	200	276	300	200	200	200	-	1.2	6	9
65	2½	199	72	154	200	200/-	-	200	320	350	200	272	200	-	1.2	6	11
80	3	209	72	174	200	200/-	-	272	323	340	272	272	200 ⁴⁾	-	1.2	6	12
100	4	229	85	214	250	250/-	-	250	380	400	250	310	250	-	1.2	6	16
125	5	242	85	239	250	250/-	-	250	420	450	250	335	250	-	1.2	6	19
150	6	263	85	282	300	300/-	-	300	415	450	300	300	300	-	1.2	6	27
200	8	291	137	338	350	350/-	350	350	480	530	350	350	350	-	1.2	8	40
250	10	319	157	393	450	450/-	450	450	550	620	450	450	450	-	1.2	8	60
300	12	344	157	444	500	500/-	500	500	600	680	500	500	500	-	1.6	8	80
350	14	349	270	451	550	550/-	550	550	-	-	550	550	550	-	1.6	8	110
400	16	374	270	502	600	600/-	600	600	-	-	600	600	600	-	1.6	10	125
450	18	405	310	563	600	600/-	600	600	-	-	600	600	600	-	1.6	10	175
500	20	430	350	614	600	600/-	625	680	-	-	600	730	600 ⁵⁾	-	1.6	10	200
600	24	481	430	715	600	600/-	750	800	-	-	600	860	600 ⁶⁾	-	1.6	10	287
700	28	531	500	816	700	875/700	-	-	-	-	-	-	700	700	2.0	-	330
750	30	558	556	869	-	-/-	-	-	-	-	-	-	750	750	2.0	-	360
800	32	593	560	927	800	1000/800	-	-	-	-	-	-	800	800	2.0	-	450
900	36	640	630	1032	900	1125/900	-	-	-	-	-	-	900	900	2.0	-	530
1000	40	691	670	1136	1000	1250/1000	-	-	-	-	-	-	1000	1000	2.0	-	660
1100	44	742	770	1238	-	-/-	-	-	-	-	-	-	1100	1100	2.0	-	1140
1200	48	797	792	1348	1200	1500/1200	-	-	-	-	-	-	1200	1200	2.0	-	1180
1400	56	912	1000	1675	1400	-/1400	-	-	-	-	-	-	-	1400	3.0	-	1600
1500	50	959	1020	1672	1500	-/1500	-	-	-	-	-	-	-	1500	3.0	-	2460
1600	64	1012	1130	1915	1600	-/1600	-	-	-	-	-	-	-	1600	3.0	-	2140
1800	72	1110	1250	1974	1800	-/1800	-	-	-	-	-	-	-	1800	3.0	-	2930
2000	78	1210	1375	2174	2000	-/2000	-	-	-	-	-	-	-	2000	3.0	-	3665

1) When earthing flanges are used, the thickness of the earthing flange must be added to the build-in length

2) T_C = Type C grounding ring

3) Weights are approx. and for PN 16

4) PN 35 DN 80 = 272 mm

5) PN 35 DN 500 = 680 mm

6) PN 35 DN 600 = 750 mm

- Not available

D = Outside diameter of flange, see flange tables

4.2.2 Sensor MAG 3100 Ex

Version	MAG 3100 Ex	MAG 3100 HT Ex (High Temperature)	MAG 3100 P Ex
Rated operation conditions			
Ambient temperature (con- ditions also dependent on liner characteristics)			
Sensor (ATEX)	-20...+60 °C (-4...+140 °F)	-20...+60 °C (-4...+140 °F) ¹⁾	-20...+60 °C (-4...+140 °F)
Operating pressure [abs. bar] (maximum operating pressure decreases with increasing operating tempe- rature and with stainless steel flanges)	Neoprene 0.01...100 bar (0.15...1450 psi)	PTFE Teflon DN 15...300 (½"...12") (130/180°C) (266 °F/ 356°F): 0.3...50 bar (4...725 psi) (180°C (356°F) PTFE has fac- tory mounted grounding SS rings type E & SS terminal box) PFA DN 25...100 (1"...4"): 0.01...50 bar (0.15...725 psi)	PTFE Teflon DN 15...300 (½"...12"): 0.3...50 bar (4...725 psi)
	EPDM 0.01...40 bar (0.15...580 psi)		
	Linatex® 0.01...40 bar (0.15...580 psi)		PFA DN 15...100 (1"...4"): 0.01...50 bar (0.15...725 psi)
	Ebonite 0.01...100 bar (0.15...1450 psi)		
	PTFE (DN ≤ 300, PN ≤ 50 bar/ ≤ 12", PN ≤ 725 psi)		
	PTFE (350 ≤ DN ≤ 600, PN ≤ 40 bar/14" ≤ DN ≤ 24", PN ≤ 580 psi)		
PFA DN 25...100 (1"...4"): 0.01... 50 bar (0.15...725 psi))			
Enclosure rating	IP67/NEMA 4X/6 to EN 60529, 1mH ₂ O for 30 min	IP67/NEMA 4X/6 to EN 60529, 1mH ₂ O for 30 min	IP67/NEMA 4X/6 to EN 60529, 1mH ₂ O for 30 min
Pressure drop at 3 m/s	As straight pipe		
Test pressure	1.5 x PN (where applicable)		
Mechanical load	18...1000 Hz random in x, y z, directions for 2 hours according to EN 60068-2-36	18...1000 Hz random in x, y z, directions for 2 hours according to EN 60068-2-36	18...1000 Hz random in x, y z, directions for 2 hours according to EN 60068-2-36
	Sensor: 3.17 grms	Sensor: 3.17 grms	Sensor: 3.17 grms
Temperature of medium	Neoprene 0...+70 °C (32...158 °F)	PTFE -20...+130 °C (-4...+266 °F)	PTFE -20...+130 °C (-4...+266 °F)
	EPDM -10...+70 °C (14...158 °F)	PFA -20...+150 °C (-4...+300 °F)	PFA -20...+150 °C (-4...+300 °F)
	Linatex® (rubber)	PTFE -20...+180 °C (-4...+356 °F)	
	-40...+70 °C (-40...+158 °F) (for temperatures below -20°C (15°F) AISI 304 or 316 flan- ges must be used)		
	Ebonite 0 ...95 °C (32...203 °F)		
	PTFE -20...+100 °C (-4...+212 °F)		
PFA -20 ...+100 °C (-4...+212 °F)			
EMC	89/336 ECC	89/336 ECC	89/336 ECC

¹⁾ Up to medium temperature of 150°C (300°F).

For medium temperature of 150 to 180°C (300 to 356°F) -20 to +50°C (-4 to +122°F)

4.2.2 Sensor MAG 3100 Ex
(continued)

Version	MAG 3100 Ex	MAG 3100 HT Ex (High Temperature)	MAG 3100 P Ex
Rated operation conditions			
Ambient temperature (conditions also dependent on liner characteristics)			
Sensor (ATEX)	-20...+60 °C (-4...+140 °F)	-20...+60 °C (-4...+140 °F) ¹⁾	-20...+60 °C (-4...+140 °F)
Operating pressure [abs. bar] (maximum operating pressure decreases with increasing operating temperature and with stainless steel flanges)	Neoprene 0.01...100 bar (0.15...1450 psi)	PTFE Teflon DN 15...300 (½"...12") (130/180°C) (266 °F/ 356°F): 0.3...50 bar (4...725 psi) (180°C (356°F) PTFE has factory mounted grounding SS rings type E & SS terminal box) PFA DN 25...100 (1"...4"): 0.01...50 bar (0.15...725 psi)	PTFE Teflon DN 15...300 (½"...12"): 0.3...50 bar (4...725 psi)
	EPDM 0.01...40 bar (0.15...580 psi)		PFA DN 15...100 (1"...4"): 0.01...50 bar (0.15...725 psi)
	Linatex® 0.01...40 bar (0.15...580 psi)		
	Ebonite 0.01...100 bar (0.15...1450 psi)		
	PTFE (DN ≤ 300, PN ≤ 50 bar/ ≤ 12", PN ≤ 725 psi)		
	PTFE (350 ≤ DN ≤ 600, PN ≤ 40 bar/14" ≤ DN ≤ 24", PN ≤ 580 psi)		
Enclosure rating	IP67/NEMA 4X/6 to EN 60529, 1mH ₂ O for 30 min	IP67/NEMA 4X/6 to EN 60529, 1mH ₂ O for 30 min	IP67/NEMA 4X/6 to EN 60529, 1mH ₂ O for 30 min
Pressure drop at 3 m/s	As straight pipe		
Test pressure	1.5 x PN (where applicable)		
Mechanical load	18...1000 Hz random in x, y z, directions for 2 hours according to EN 60068-2-36	18...1000 Hz random in x, y z, directions for 2 hours according to EN 60068-2-36	18...1000 Hz random in x, y z, directions for 2 hours according to EN 60068-2-36
	Sensor: 3.17 grms	Sensor: 3.17 grms	Sensor: 3.17 grms
Temperature of medium	Neoprene 0...+70 °C (32...158 °F)	PTFE -20...+130 °C (-4...+266 °F)	PTFE -20...+130 °C (-4...+266 °F)
	EPDM -10...+70 °C (14...158 °F)	PFA -20...+150 °C (-4...+300 °F)	PFA -20...+150 °C (-4...+300 °F)
	Linatex® (rubber) -40...+70 °C (-40...+158 °F) (for temperatures below -20°C (15°F) AISI 304 or 316 flanges must be used)	PTFE -20...+180 °C (-4...+356 °F)	
	Ebonite 0...95 °C (32...203 °F)		
	PTFE -20...+100 °C (-4...+212 °F)		
	PFA -20...+100 °C (-4...+212 °F)		
EMC	89/336 ECC	89/336 ECC	89/336 ECC

¹⁾ Up to medium temperature of 150°C (300°F).

For medium temperature of 150 to 180°C (300 to 356°F) -20 to +50°C (-4 to +122°F)

4.2.2 Sensor MAG 3100 Ex
(continued)

Version	MAG 3100 Ex	MAG 3100 HT Ex (High Temperature)	MAG 3100 P Ex
Design			
Weight	See dimensional drawings		
Flange and housing material	Carbon steel ASTM A 105, with corrosion resistant two component epoxy coating (min. 150 µm) or AISI 304 (1.4301) flanges and carbon steel housing, with corrosion resistant two component epoxy coating (min. 150 µm) or AISI 316 L (1.4404) flanges and housing, polished	Carbon steel ASTM A 105, with corrosion resistant two component epoxy coating (min. 150 µm) or AISI 304 (1.4301) flanges and carbon steel housing, with corrosion resistant two component epoxy coating (min. 150 µm) or AISI 316 L (1.4404) flanges and housing, polished	Carbon steel ASTM A 105, with corrosion resistant two component epoxy coating (min. 150 µm)
Measuring pipe material	AISI 304 (1.4301)	AISI 304 (1.4301)	AISI 304 (1.4301)
Electrode material	AISI 316 Ti (1.4571)	AISI 316 Ti (1.4571)	Hastelloy C276 (PFA C22)
	Hastelloy C276 (PFA C22)	Hastelloy C276 (PFA C22)	
	Platinum/Iridium	Platinum/Iridium	
	Titanium	Titanium	
	Tantalum	Tantalum	
Grounding electrode material	Material as measuring electrodes: Exceptions - see ordering data	No grounding electrodes:	No grounding electrodes
Terminal box (remote version only)	Ex ATEX Stainless steel AISI 316 (1.4436)	Ex ATEX Stainless steel AISI 316 (1.4436)	Ex ATEX Stainless steel AISI 316 (1.4436)
Cable entries	2 x M20 (for supply/output)		2 x M20 (for supply/output)
Certificates and approvals			
Conforms to	PED – 97/23 EC, CRN	PED – 97/23 EC, CRN	PED – 97/23 EC, CRN
Material certificate EN 10204 3.1	On request	On request	Pipe and flange certificate available as option
Ex approvals	ATEX 2G D sensor	ATEX 2G D sensor	ATEX 2G D sensor
	DN 15...300: Ex d e ia IIC T3 - T6	DN 15...300: Ex d e ia IIC T3 - T6	DN 15...300: Ex d e ia IIC T3 - T6
	DN 350...2000 Ex e ia IIC T3 - T6		
Drinking water approvals	EPDM lining:		
	NSF61 (Cold water, US)		
	WRAS (WRc, BS6920 cold water, GB)		
	ACS listed (F)		
	DVGW W270 (D)		
	Belaqua (B)		

4.3 Transmitter MAG 5000/6000 19" Accuracy 0.5/0.25%



Current output	
Current	0-20 mA, 4-20 mA or 4-20 mA + alarm
Load	< 800 ohm
Time constant	0.1-30 s adjustable
Digital output	
Frequency	0-10 kHz, 50% duty cycle
Time constant	0.1-30 s adjustable
Active	24 V DC, 30 mA, $1\text{ K}\Omega \leq R_{\text{load}} \leq 10\text{ K}\Omega$, short-circuit-protected
Passive	3-30 V DC, max. 110 mA, $200\text{ }\Omega \leq R_{\text{load}} \leq 10\text{ K}\Omega$
Relay	
Time constant	Changeover relay, time constant same as current time constant
Load	42 V AC/2 A, 24 V DC/1A
Digital input	
Activation time	50 ms
Current	$I_{11\text{ V DC}} = 2.5\text{ mA}$, $I_{30\text{ V DC}} = 7\text{ mA}$
Functions	
Flow rate, 2 totalizers, low flow cut-off, empty pipe cut-off, flow direction, error system, operating time, uni/bidirectional flow, limit switches, pulse output, control for cleaning unit and batch	
Galvanic isolation	
All inputs and outputs are galvanically isolated	
Cut-off	
Low flow	0-9.9% of maximum flow
Totalizer	
Two eight-digit counters for forward, net or reverse flow	
Display	
Background illumination with alphanumerical text, 3 x 20 characters to indicate flow rate, totalized values, settings and faults	
Reverse flow indicated by negative sign	
Time constant	Time constant as current output time constant
Zero point adjustment	
Automatic	
Electrode input impedance	
$> 1 \times 10^{14}\text{ }\Omega$	
Excitation frequency	
Sensor size depending pulsating DC current (125 mA)	
Ambient temperature	
Display version during operation: -20 to +50°C	
Blind version during operation: -20 to +60°C	
During storage: -40 to +70°C (RH max. 95%)	
Communication	
<i>Standard</i>	Prepared for client mounted add-on modules
<i>Optional</i>	HART, Profibus PA as add-on module
19" insert	
Enclosure material	Standard 19" insert of aluminium/steel (DIN 41494)
	Width: 21 TE
	Height: 3 HE
Enclosure rating	IP 20 to EN 60529 and DIN 40050
Mechanical load	Version: 1 G, 1-800 Hz sinusoidal in all directions to EN 60068-2-36
EMC performance	
EN 61326	
Supply voltage	
115-230 V AC +10% to -15%, 50-60 Hz	
11-30 V DC or 11-24 V AC	
Power consumption	
230 V AC: 17 VA	
24 V DC: 9 W, $I_N = 380\text{ mA}$, $I_{ST} = 8\text{ A}$ (30 ms)	
12 V DC: 11 W, $I_N = 920\text{ mA}$, $I_{ST} = 4\text{ A}$ (250 ms)	

¹⁾ Special cable required in separate mounted installation

4.4 Safety barrier (ia)























Application	For use with MAG 5000/6000 19" and MAG 1100 Ex or MAG 3100 Ex sensor
Ex approval	See certificates
Ambient temperature	During operation: -20 to +50°C
	During storage: -20 to +70°C
19" insert	
Enclosure material	Standard 19" insert in aluminium/steel (DIN 41494)
	Width: 21 TE
	Height: 3 HE
Enclosure rating	IP 20 to EN 60529 and DIN 40050
Mechanical load	1 G, 1-800 Hz sinusoidal in all directions to EN 60068-2-36
EMC performance	EN 61326

IS data transmitter


Terminals MAG barriers	82-83 ia electrode
U _o	9.3 V
I _o	40 mA
P _o	0.4 W
L _o	23 mH
C _o	500 nF

4.5 Output characteristics MAG 5000/6000 19"

Output characteristics 0-20 mA	Bidirectional mode		Unidirectional mode	
				
4-20 mA				
Frequency				
Pulse output				
Relay	Power down		Active	
Error relay	No error		Error	
Limit switch or direction switch				
	Low flow (Reverse flow)		Intermediate flow	
	High flow (Forward flow)		High flow/ Low flow	
Batch on digital output				
Batch on relay	Hold		Batch	

5. Commissioning

5.1 Keypad and display layout



Keypad	The keypad is used to set the flowmeter. The function of the keys is as follows:		
TOP UP KEY		This key (hold 2 sec.) is used to switch between operator menu and setup menu. In the transmitter setup menu, a short press will cause a return to the previous menu.	
FORWARD KEY		This key is used to step forward through the menus. It is the only key normally used by the operator.	
BACKWARD KEY		This key is used to step backward through the menus.	
CHANGE KEY		This key changes the settings or numerical values.	
SELECT KEY		This key selects the figures to be changed.	
LOCK/UNLOCK KEY		This key allows the operator to change settings and gives access to submenus.	

Display	The display is alphanumerical and indicates flow values, flowmeter settings and error messages. The upper line is for primary flow readings and will always show either flow rate, totalizer 1 or totalizer 2. The line is divided into 3 fields. S: Sign field P: Primary field for numerical value U: Unit field The centre line is the title line (T) with individual information according to the selected operator or setup menu. The lowest line is the subtitle line (ST) which either will add information to the title line or keep individual information independent of the title line.		
---------	---	--	--

F: The alarm field. Two flashing triangles will appear by a fault condition.

M: The mode field. The symbols indicate the following.

Communication mode	Basic settings	Operator active
Service mode	Output	Operator inactive
Operator menu	External input	
Product identity	Sensor characteristics	
Language mode	Reset mode	

L: The lock field. Indicates the function of the lock key.

Ready for change	Access to submenu
Value locked	RESET MODE: Zero setting of totalizers and initialization of setting

5.2.1 Basic settings

Main frequency
To select the main power supply frequency corresponding to the country in which the flowmeter is installed.
(US = 60 Hz)

Flow direction
Select the correct flow direction in the pipe.

$Q_{max.}$
Sets the measuring range, the analog outputs and the frequency output. Value, decimal point, unit and time can be set individually (setting is dimension dependent).



$Q_{max.2}$
Sets the measuring range, the analog outputs and the frequency output. Value, decimal point, unit and time can be set individually (setting is dimension dependent). Only visible when it has been chosen as external digital input.



Totalizers
To set unit and decimal point.

Low flow cut off
To set a % of selected $Q_{max.}$. To filter noise in the installation. Influences display and all outputs.

Error level
To select which error level, the flowmeter will detect an error.

Comma for flow rate, totalizer 1 and totalizer 2 can be individually positioned.

- open the respective window.
- ensure that the cursor is positioned below the comma. Use the SELECT KEY .
- move the comma to the requested position. Use the CHANGE KEY .


Units are changed by means of the CHANGE KEY  with the cursor placed below the unit selected. Select units (cursor moved) by means of the SELECT KEY .

Totalizer 2 is not visible when batch is selected as digital output. 

$Q_{max. 2}$ - is only visible when it has been chosen as external input.


5.2.2 Outputs

Current output
Proportional to flowrate
(Terminal 31 and 32)




The current output must be set off when not used.


Digital output
Pulse/volume
(Terminal 56, 57, 58)



Digital output
Frequency
Proportional to flowrate
(Terminal 56, 57, 58)




5.2.3 External input




5.2.4 Sensor characteristics


If "SENSORPROM not installed" is shown, refer to the handbook (depending on type of mounting configuration).



5.2.5 Language mode



5.2.6 Service mode



All previous settings are reinitialised when service mode is exited using the top up key.

The error system

The error system is divided into an error pending list and a status log list. Time is gained as days, minutes and hours since the error has occurred.

The first 9 standing errors are stored in error pending. When an error is removed it is removed from error pending.

The latest 9 errors are stored in the status log. When an error is removed it is still kept in status log. Errors in status log is stored for 180 days.

Error pending and status log are accessible when enabled in the operator menu.

6. Service


Often problems with unstable/wrong measurements occur due to insufficient/wrong earthing or potential equalization. Please check this connection. If OK, the SITRANS F M MAGFLO transmitter can be checked as described in the handbook.

6.1 Transmitter check list

When checking SITRANS F M MAGFLO installations for malfunction the easiest method to check the transmitter is to replace it with another MAG 5000/6000 transmitter with a similar power supply.

A replacement can easily be done as all settings are stored in and downloaded from the SENSORPROM unit - no extra settings need to be made.

If no spare transmitter is available - then check transmitter according to check table.



6.2 Trouble shooting MAG transmitter

Symptom	Output signals	Error code	Cause	Remedy
Empty display	Minimum		1. No power supply	Power supply Check MAG 5000/6000 for bended pins on the connector
			2. MAG 5000/6000 defective	Replace MAG 5000/6000
No flow signal	Minimum		1. Current output disabled	Turn on current output
			2. Digital output disabled	Turn on digital output
			3. Reverse flow direction	Change direction
		F70	Incorrect or no coil current	Check cables/connections
		W31	Measuring pipe empty	Ensure that the measuring pipe is full
		F60	Internal error	Replace MAG 5000/6000
	Undefined	P42	1. No load on current output 2. MAG 5000/6000 defective	Check cables/connections Replace MAG 5000/6000
		P41	Initializing error	Switch off MAG 5000/6000, wait 5 s and switch on again
Indicates flow with no flow in pipe	Undefined		Measuring pipe empty	Select empty pipe cut-off
			Empty pipe cut-off is OFF	Ensure that the measuring pipe is full
			Electrode connection missing/ electrode cable is insufficiently screened	Ensure that electrode cable is connected and sufficiently screened
Unstable flow signal	Unstable		1. Pulsating flow	Increase time constant
			2. Conductivity of medium too low	Use special electrode cable
			3. Electrical noise potential between medium and sensor	Ensure sufficient potential equalization
			4. Air bubbles in medium	Ensure medium does not contain air bubbles
			5. High concentration of particles or fibres	Increase time constant
Measuring error	Undefined		Incorrect installation	Check installation
		P40	No SENSORPROM unit	Install SENSORPROM unit
		F61	Deficient SENSORPROM unit	Replace SENSORPROM unit
		F62	Wrong type of SENSORPROM unit	Replace SENSORPROM unit
		F63	Deficient SENSORPROM unit	Replace SENSORPROM unit
		F71	Loss of internal data	Replace MAG 5000/6000
	Maximum	W30	Flow exceeds 100% of $Q_{max.}$	Check $Q_{max.}$ (Basic Settings)
		W21	Pulse overflow • Volume/pulse too small • Pulse width too large	Change volume/pulse Change pulse width
Measuring approx. 50%			Missing one electrode connection	Check cables
Loss of totalizer data	OK	W20	Initializing error	Reset totalizer manually
##### Signs in display	OK		Totalizer roll over	Reset totalizer or increase totalizer unit

7. Ordering

7. Ordering



Please use online PIA Selector to get latest updates.
PIA selector link:

www.pia-selector.automation.siemens.com

8.1 EC-declaration of conformity

Please note the following certificates are incomplete for the full version please refer to <http://siemens.com/flow>

SIEMENS

EC Declaration of Conformity EG-Konformitätserklärung



No. 083R3044-03

Manufacturer:

Hersteller:

Siemens Flow Instruments A/S

Address:

Nordborgvej 81, DK-6430 Nordborg

Anschrift:

Denmark

Product description:

Flow transmitter / Durchfluß meßumformer

Produktbezeichnung

SITRANS F M

Type/Typ MAG5000, MAG6000, MAG6000CT, with option modules, used with sensors MAG1100, MAG1100Ex, MAG3100, MAG3100Ex and MAG5100

The product described above in the form as delivered is in conformity with the provisions of the following European Directives:

Das bezeichnete Produkt stimmt in der von uns in Verkehr gebrachten Ausführung mit den Vorschriften folgender Europäischer Richtlinien überein:

89/336/EEC	Council Directive on the approximation of the laws of the Member States relating to electromagnetic compatibility.(amended by 91/263/EEC, 92/31/EEC and 93/68/EEC)
EMC	<i>Richtlinie des Rates zur Angleichung der Rechtsvorschriften der Mitgliedstaaten über die elektromagnetische Verträglichkeit.(geändert durch 91/263/EWG, 92/31/EWG und 93/68/EWG).</i>
2006/95/EC	Directive of the European Parliament and of the Council on the harmonisation of the laws of Member States relating to electrical equipment designed for use within certain voltage limits.
LVD	<i>Richtlinie des Europäischen Parlaments und des Rates zur Angleichung der Rechtsvorschriften der Mitgliedstaaten betreffend elektrische Betriebsmittel zur Verwendung innerhalb bestimmter Spannungsgrenzen.</i>
94/9/EC	Directive of the European Parliament and the Council on the approximation of the laws of the Member States concerning equipment and protective systems intended for use in potentially explosive atmospheres.
ATEX	<i>Richtlinie des Europäischen Parlaments und des Rates zur Angleichung der Rechtsvorschriften der Mitgliedstaaten für Geräte und Schutzsysteme zur bestimmungsgemäßen Verwendung in explosionsgefährdeten Bereichen.</i>
97/23/EC	Directive of the European Parliament and of the Council on the approximation of the laws of the Member States concerning pressure equipment.
PED	<i>Richtlinie des Europäischen Parlaments und des Rates zur Angleichung der Rechtsvorschriften der Mitgliedstaaten über Druckgeräte</i>
2004/22/EC	Directive of the European Parliament and the Council on the approximation of the laws of the Member States concerning equipment intended for Legal Metrological Measuring systems.
MID	<i>Richtlinie des Europäischen Parlaments und des Rates zur Angleichung der Rechtsvorschriften der Mitgliedstaaten für Geräte zur bestimmungsgemäßen Verwendung in Legale Metrologische Messsysteme.</i>

Annex A is integral part of this declaration.

Anhang A ist integraler Bestandteil dieser Erklärung.

This declaration certifies the conformity to the specified directives but contains no assurance of properties. The safety documentation accompanying the product shall be considered in detail.

Diese Erklärung bescheinigt die Übereinstimmung mit den genannten Richtlinien, ist jedoch keine Beschaffenheits- oder Haltbarkeitsgarantie nach §443 BGB. Die Sicherheitshinweise der mitgelieferten Produktdokumentation sind zu beachten.

Siemens Aktiengesellschaft: Chairman of the Supervisory Board: Gerhard Cromme

Managing Board: Peter Loescher, Chairman, President and Chief Executive Officer; Heinrich Hiesinger, Joe Kaeser, Rudi Lamprecht, Eduardo Montes, Juergen Radomski, Erich R. Reinhardt, Hermann Requardt, Uriel J. Sharaf, Peter Y. Solmsen, Klaus Wucherer

Registered offices: Berlin and Munich; Commercial registries: Berlin Charlottenburg, HRB 12300, Munich, HRB 6684

WEEE-Reg.-Nr. DE 23691322

SIEMENS

**EG-Konformitätserklärung
EC Declaration of Conformity**

No. 083R3044-03

Nordborg, 10.01.2008

Siemens Flow Instruments A/S

Jen Parkum, R&D



Name, function
Name, Funktion

signatur
Unterschrift

Ove Kirk Andersen, Quality



Name, function
Name, Funktion

signatur
Unterschrift

Anhang A ist integraler Bestandteil dieser Erklärung

Annex A is integral part of this declaration Diese Erklärung bescheinigt die Übereinstimmung mit den genannten Richtlinien, ist jedoch keine Zusicherung von Eigenschaften.

Die Sicherheitshinweise der mitgelieferten Produktdokumentation sind zu beachten.

This declaration certifies the conformity to the specified directives but contains no assurance of properties. The safety documentation accompanying the product shall be considered in detail.

Page 2 / 3

SIEMENS

Annex A to the EC Declaration of Conformity Anhang A zur EG-Konformitätserklärung

No. 083R3044-03

Product description: Flow transmitter / Durchfluß meßumformer
 Produktbezeichnung: SITRANS F M
 Type/Typ: MAG5000, MAG6000, MAG6000CT, with option modules, used with sensors MAG1100, MAG1100Ex, MAG3100, MAG3100Ex and MAG5100

Conformity to the Directives indicated on page 1 is assured through the application of the following standards (depending on versions):

Die Konformität mit den auf Blatt 1 angeführten Richtlinien wird nachgewiesen durch die Einhaltung folgender Normen (variantenabhängig):

Direktive Richtlinie	Standard / Reference number Norm / Referenznummer	Edition Ausgabe datum	MAG 5000/6000	MAG 6000CT	MAG 1100	MAG 1100Ex	MAG 3100	MAG 3100Ex	MAG 3100PFA	MAG 3100PTFE	MAG 5100
2006/95/EC	EN61010-1	2001	x		x	x	x	x	x	x	
89/336/EEC	EN 61326-1 *	2006	x		x	x	x	x	x	x	
89/336/EEC	EN 61326-2-5	2006	x		x	x	x	x	x	x	
94/9/EC	EN 50014 + A1 and A2	1997	x								
94/9/EC	EN 50020	2002	x								
94/9/EC	EN 1127-1	1998				x					
94/9/EC	EN 60079-0	2005				x	x				
94/9/EC	EN 60079-1	2004					x				
94/9/EC	EN 60079-7	2007				x	x				
94/9/EC	EN 60079-11	2007				x	x				
94/9/EC	EN 61241-0	2006				x	x				
94/9/EC	EN 61241-1	2004				x	x				
97/23/EC	Modul H	2001			x	x					
97/23/EC	Modul B	2001								x	
97/23/EC	Modul E1	2001					x	x	x		
2004/22/EC	OIML R49	2006		x							x

* all environments included

Certificates Zertifikate	MAG 5000/6000	MAG 6000CT	MAG 1100	MAG 1100Ex	MAG 3100	MAG 3100Ex	MAG 3100PFA	MAG 3100PTFE	MAG 5100
SIRA 07 ATEX 1182X				x		x			
SIRA 07 ATEX 3181X				x					
DEMKO 03 ATEX 135255X	x								
SIRA 03 ATEX 3339X						x			
FORCE DK 0200-4.853/03			x	x					
BSI CE 67317								x	
BSI CE 56993					x	x	x	x	
DK-0200-MI005		x							x

Inspection / Surveillance:

Kontrolle / Überwachung:

Directive Richtlinie	Notified Body Product Quality Assurance Benannte Stelle Qualitätssicherung Produktion	No.:
94/9/EC	SIRA Certification Service (Stonehouse, UK)	0518
94/9/EC	UL International Demko (Nordborg, DK)	0539
27/23/EC	British Standards Institution (Stonehouse, UK)	0086
27/23/EC	FORCE - Dantest CERT (Nordborg, DK)	0200
2004/22/EC	FORCE - Dantest CERT	0200

8.2 EC type examination certificate

Please note the following certificates are incomplete for the full version please refer to <http://siemens.com/flow>

1 **EC TYPE-EXAMINATION CERTIFICATE**

2 Equipment intended for use in Potentially Explosive Atmospheres Directive 94/9/EC

3 Certificate Number: **Sira 07ATEX1182X** Issue: **2**4 Equipment: **Remote version: SITRANS F M MAGFLO MAG3100Ex DN15 to DN300**
Compact configuration: SITRANS F M MAGFLO MAG6000 INDUSTRY5 Applicant: **Siemens Flow Instruments A/S** **Siemens Flow Instruments Ltd**6 Address: Nordborgvej 81 Magflo House
Nordborg 6430 Ebley Road
Denmark Stonehouse
Gloucestershire GL10 2LU
UK

7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 Sira Certification Service, notified body number 0518 in accordance with Article 9 of Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN 60079-0:2006

EN 60079-1:2004

EN 60079-7:2007

EN 60079-11:2007

EN 61241-0:2006

EN 61241-1:2004

10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

11 This EC type-examination certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.

12 The marking of the equipment shall include the following:

Remote version:

II 2(1) GD

Ex d e ia IIC T3-T6

Ex tD A21 IP67 T°C

Ta = -20°C to +60°C (with process temperatures equal to or less than +150°C)

Ta = -20°C to +50°C (with process temperatures equal to or less than +180°C)

(* pipe temperature +13 K)

Compact Configuration (This marking is shown on the transmitter label, the flowmeter is not separately marked):

II 2(1)(2) GD

Ex d [ia] [ib] ia IIC T3-T6

Ex tD A21 IP67 T°C

Ta = -10°C to +60°C (with process temperatures equal to or less than +150°C)

Ta = -10°C to +50°C (with process temperatures equal to or less than +180°C)

(* pipe temperature +13 K, but not less than 85°C)

Note: Siemens label will mark "Ta: (Refer to user instructions)"

Project Number 52A17771

C. Index 12

This certificate and its schedules may only be reproduced in its entirety and without change.

C. Ellaby
Certification Officer

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900

Fax: +44 (0) 1244 681330

Email: info@siracertification.comWeb: www.siracertification.com



SCHEDULE

EC TYPE-EXAMINATION CERTIFICATE

Sira 07ATEX1182X
Issue 2

13 DESCRIPTION OF EQUIPMENT

The SITRANS F M MAGFLO MAG 3100Ex Flowmeters comprises a cylindrical carbon steel enclosure with a stainless steel tube passing through it creating an internal cavity. The tube has a flange at each end such as to allow mounting into process pipe work. Two electrodes are internally fitted to the Flowmeter, which project into the process tube from the internal cavity. Additionally the Flowmeter is fitted with sensing coils in the internal cavity, which are mounted to the pipe body.


Cables enter the enclosure via an extension on the body and through a silicone compression seal. The seal is compressed by means of a central threaded element and is retained by a circlip arrangement. A terminal box is mounted on the extension to enable termination of the intrinsically safe and increased safety 'e' cabling. The whole Flowmeter is considered Ex 'd' up to the terminal box (up to internal flameproof 'silicone compression seal') at which point the field and factory wiring is considered protected by Ex 'ia' and Ex 'e' protection principles.

Design Variations/Options


The SITRANS F M MAGFLO MAG3100Ex Flowmeters are available in three size ranges (pipe bore):

- DN15 to DN25
- DN40 to DN300
- DN50 to DN300 (High Pressure Type)

Additionally the MAG3100Ex is either configured as a Remote or Compact type sensor. The Remote version has the MAG3100Ex Flowsensor installed independently with cable connections made via the terminal box to the MAG6000 transmitter located in a separate location. The Compact type configuration has the MAG6000 (Sira 05ATEX2072X) mounted directly to the MAG3100Ex Sensor in place of the terminal box. The diagram below shows the two configuration types.



Remote Configuration



Compact Configuration

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
Fax: +44 (0) 1244 681330
Email: info@siracertification.com
Web: www.siracertification.com

**SCHEDULE****EC TYPE-EXAMINATION CERTIFICATE**

Sira 07ATEX1182X
Issue 2

The parameters for the SITRANS F M MAGFLO MAG3100Ex Flowmeter are as follows:

Remote version:

Terminals 0, 81, 82, 83, 84 (Ex ia)

U_i = 30 V
I_i = 50 mA
P_i = 0.5 W
C_i = 50 nF
L_i = 2 µH

Terminals 85, 86 (Ex e)

U_i = 30/70 V_{pk}
I_i = 130 mA

Compact version:

Refer to certificate number Sira 05ATEX2072X.

Variation 1 - This variation introduced the following changes:

- i. The modification of the mounting arrangement for the divider separating the Ex 'e' and the Ex 'ia' terminals.

Variation 2 - This variation introduced the following changes:

- i. The ambient temperature specification relative to process temperatures to be reviewed; this is the result of the upper process temperature limit being raised from 150°C up to a maximum of 180°C. The special condition for safe use appertaining to the temperature limits, temperature classes and maximum surface temperatures for dust is also modified and the marking has been amended so that the user/installer is advised to refer to the instructions for this information.

14 DESCRIPTIVE DOCUMENTS

14.1 Drawings

Refer to Certificate Annexe.

14.2 Associated Sira Reports and Certificate History

Issue	Date	Report no.	Comment
0	1 October 2007	R52A16921A	The release of the prime certificate.
1	29 January 2008	R52A17771A	The introduction of Variation 1.
2	5 February 2008	R52A17771A	The introduction of Variation 2.

This certificate and its schedules may only be reproduced in its entirety and without change.

Form 9400 Issue1

Page 3 of 5

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
Fax: +44 (0) 1244 681330
Email: info@siracertification.com
Web: www.siracertification.com

**SCHEDULE****EC TYPE-EXAMINATION CERTIFICATE****Sira 07ATEX1182X
Issue 2****15 SPECIAL CONDITIONS FOR SAFE USE** (denoted by X after the certificate number)

15.1 The surface temperature of the equipment depends on the temperature of the process fluid.

Maximum process fluid temperature (°C)	Temperature class (for gases)
72°C	T6 (85°C)
87°C	T5 (100°C)
122°C	T4 (135°C)
180°C ¹	T3 (200°C)

¹ The maximum ambient temperature allowed at this process temperature is +50°C. Process temperatures up to and including 150°C may have a maximum ambient temperature of +60°C.

For dust protection, the surface temperature is equal to the process fluid temperature +13 K when configured in the Remote version and process fluid temperature +13 K but not less than +85°C in the compact configuration.

15.2 In operation, the output is earthed through the conductive medium being measured and therefore potential equalisation is necessary throughout the hazardous area. The apparatus housing shall be connected to the potential equalising conductor in the hazardous area.

15.3 The external connections to the Ex 'e' Terminals of the Remote version shall comply with the following:

15.3.1 The wire conductors shall have a cross-sectional area between 0.5 mm² and 4 mm².

15.3.2 No more than one single or multiple strand wire conductor shall normally be connected to each of the terminals. If multiple conductors are required, these shall be joined in a suitable manner, e.g. two conductors into a single insulated crimped boot lace ferrule.

15.3.3 The insulation on the wire conductors shall extend to within 1mm of the metal of the terminal throat.

15.3.4 The terminal screws shall be tightened down with a torque between 0.5 Nm and 0.7 Nm.

15.3.5 The terminals shall never be exposed to temperatures outside of the range -50°C to +130°C; in addition, they shall only be installed and wired with cable in an ambient temperature of -10°C to +80°C. Furthermore, in the event of there being a process temperatures of +180°C in conjunction with an upper ambient temperature of +50°C the terminal strips should not be installed or wired with cable.

15.4 The terminal box shall not be opened when an explosive gas or dust atmosphere may be present.

16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900

Fax: +44 (0) 1244 681330

Email: info@siracertification.comWeb: www.siracertification.com

**SCHEDULE****EC TYPE-EXAMINATION CERTIFICATE**

Sira 07ATEX1182X
Issue 2

17 CONDITIONS OF CERTIFICATION

- 17.1 The use of this certificate is subject to the Regulations Applicable to Holders of Sira Certificates.
- 17.2 Holders of EC type-examination certificates are required to comply with the production control requirements defined in Article 8 of directive 94/9/EC.
- 17.3 Each enclosure, including cast pedestal when used, shall be subject to a routine pressure test for at least 10 s as required by clause 16.1 of EN 60079-1:2004 (see table below). There shall be no damage or permanent deformation as a result of the tests.

Description	Minimum test pressure
≥DN 15 ≤DN 25	10 Bar
>DN 25 ≤DN 300	14 Bar

- 17.4 When used in 'Compact' configuration, the conditions imposed by certificate Sira 05ATEX2072X apply to the assembly.
- 17.5 Dielectric strength test required as per Clause 7.1 of EN 60079-7:2007
- 17.6 The Remote Version of the equipment, as supplied, shall only be connected to another item of certified Ex ia associated apparatus or Ex e equipment (e.g. an electro-magnetic transmitter).
- 17.7 This certificate relies on the following previously certified products. When used as part of the SITRANS F M MAGFLO MAG3100 Ex Flowsensor, the key attributes are listed in the table below and shall still be maintained by their original certificate.

Product	Certificate number	Key attributes
Weidmuller BK2/E Terminal	Sira 01ATEX3247U	EEx e II
Hawke type PET5 Pillar Earth Terminal	BAS 01ATEX2247U	EEx e II

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
 Fax: +44 (0) 1244 681330
 Email: info@siracertification.com
 Web: www.siracertification.com

Certificate Annexe**Certificate Number:** Sira 07ATEX1182X**Equipment:** SITRANS F M MAGFLO MAG3100Ex
DN15 to DN300
SITRANS F M MAGFLO MAG6000 INDUSTRY**Applicants:** Siemens Flow Instruments A/S
Siemens Flow Instruments Ltd**Issue 0**

Number	Sheet	Rev.	Date (Sira stamp)	Description
A5E01211108A	1 of 1	01	28 Sep 07	Certification DRG. for MAG3100Ex DN15 – DN300 with MAG6000 Industry (SIRA)
A5E01211109A	1 of 1	01	28 Sep 07	Terminal Box DN15 – DN2000 Certification Drawing MAG3100Ex Sensor
A5E01211110A	1 of 1	01	28 Sep 07	Certification Drawing DN15 – DN25 MAG3100Ex Flowsensor
A5E01211111A	1 of 1	01	28 Sep 07	Certification Drawing DN40 – DN300 MAG3100Ex Flowsensor
A5E01214561A	1 of 1	04	28 Sep 07	Certification Drawing for DN50 – DN300 High Pressure MAG3100Ex Flowsensor
A5E01215897A	1 of 1	01	28 Sep 07	Certification DRG. for MAG3100Ex MAG6000I ASSY (SIRA)
A5E01263817A	1 of 1	01	28 Sep 07	Certification Label MAG3100Ex DN15-300 / MAG6000 Industry (Compact)
083A0275	1 of 1	05	28 Sep 07	Data Label DN15 – DN2000 MAG3100Ex Flowsensor
083A0285	1 of 1	01	28 Sep 07	Certification Label DN15 – DN300 MAG3100Ex Flowsensor
083Z3043	1 of 1	03	28 Sep 07	ST.ST Ferrule MAG3100 Flowsensor
083Z3042	1 of 1	04	28 Sep 07	Ferrule/Glass Seal ASSY MAG3100 Flowsensor

Issue 1

Number	Sheet	Rev.	Date (Sira stamp)	Description
A5E01211109A	1 of 1	03	28 Jan 08	Terminal Box DN15 - DN2000 Certification Drawing MAG3100Ex Sensors

Issue 2

Number	Sheet	Rev.	Date (Sira stamp)	Description
083A0285	1 of 1	02	04 Feb 08	Certification Label DN15 – DN300 MAG3100Ex Flowsensor
A5E01263817A	1 of 1	02	04 Feb 08	Appro. Label DN≤300 MAG6000I + MAG3100

This certificate and its schedules may only be reproduced in its entirety and without change.

Form 9400 Issue 1

Page 1 of 1

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
 Fax: +44 (0) 1244 681330
 Email: info@siracertification.com
 Web: www.siracertification.com



1 EC TYPE-EXAMINATION CERTIFICATE

2 Equipment intended for use in Potentially Explosive Atmospheres Directive 94/9/EC

3 Certificate Number: **Sira 07ATEX3181X** Issue: **1**

4 Equipment: **SITRANS F M MAGFLO MAG1100Ex DN2 to DN100**

5 Applicant: **Siemens Flow Instruments A/S**

6 Address: Nordborgvej 81
Nordborg 6430
Denmark

7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 Sira Certification Service, notified body number 0518 in accordance with Article 9 of Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN 60079-0:2006

EN 60079-7:2007

EN 60079-11:2007

EN 61241-0:2006

EN 61241-1:2004

EN 1127:1998

10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

11 This EC type-examination certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.

12 The marking of the equipment shall include the following:

Remote version:



II 2(1) GD

Ex e ia IIB T3-T6

Ex tD A21 IP67 T=°C

Ta = -20°C to +60°C (with process temperatures equal to or less than +150°C)

Ta = -20°C to +50°C (with process temperatures equal to or less than +180°C)

(* pipe temperature +18 K)

Compact Configuration (This marking is shown on the transmitter label, the flowmeter is not separately marked):



II 2(1)(2) GD

Ex d [ia] [ib] ia IIB T3-T6

Ex tD A21 IP67 T=°C

Ta = -10°C to +60°C (with process temperatures equal to or less than +150°C)

Ta = -10°C to +50°C (with process temperatures equal to or less than +180°C)

(* pipe temperature +18 K, but not less than 85°C)

Note: Siemens label will mark "Ta: (Refer to user instructions)".

Project Number 52A16937
C. Index 12

This certificate and its schedules may only be reproduced in its entirety and without change.

C. Ellaby
Certification Officer

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
Fax: +44 (0) 1244 681330
Email: info@siracertification.com
Web: www.siracertification.com

Form 9400 Issue 1

Page 1 of 4



SCHEDULE

EC TYPE-EXAMINATION CERTIFICATE

Sira 07ATEX3181X
Issue 1

13 DESCRIPTION OF EQUIPMENT

Each of the MAG1100Ex Flowmeters comprises two concentric cylindrical tubes with welded end caps. The outer tube is stainless steel and the inner is ceramic. The end caps are machined such as to allow mounting into process pipe work, the process fluid passing through the inner ceramic tube. 'O' ring seals are fitted between the tubes to prevent the ingress of process fluid. The enclosure contains energising coils with sensing electrodes.


Cables enter the enclosure via an extension on the body and through a silicone compression seal. The seal is compressed by means of a central threaded element and is retained by a circlip arrangement. A terminal box is mounted on the extension to enable termination of the intrinsically safe and increased safety 'e' cabling. The whole Flowmeter is considered Ex 'd' up to the terminal box (up to internal flameproof 'silicone compression seal') at which point the field and factory wiring is considered protected by Ex 'ia' and Ex 'e' protection principles.

Design Variations/Options

The SITRANS F M MAGFLO MAG1100Ex Flowmeters are available in size ranges (pipe bore):

- DN2 to DN6 (Zirconium Ceramic)
- DN6 to DN100 (Alumina Ceramic)

Additionally the MAG1100Ex is either configured as a Remote or Compact type sensor. The Remote version has the MAG1100Ex Flowsensor installed independently with cable connections made via the terminal box to the MAG6000 transmitter located in a separate location. The Compact type configuration has the MAG6000 (Sira 05ATEX2072X) mounted directly to the MAG1100Ex Sensor in place of the terminal box. The diagram below shows the two configuration types.



Note: The diagram above is representative of a MAG1100 Flowsensor and is only presented to depict the configuration of either the terminal box or MAG6000Ex to the Flowsensor.

This certificate and its schedules may only be reproduced in its entirety and without change.

Form 9400 Issue1

Page 2 of 4

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
 Fax: +44 (0) 1244 681330
 Email: info@siracertification.com
 Web: www.siracertification.com

**SCHEDULE****EC TYPE-EXAMINATION CERTIFICATE**Sira 07ATEX3181X
Issue 1

The parameters for the SITRANS F M MAGFLO MAG1100Ex Flowmeter are as follows:

Remote version:

Terminals 0, 81, 82, 83, 84 (Ex ia)

 $U_i = 30 \text{ V}$
 $I_i = 50 \text{ mA}$
 $P_i = 0.5 \text{ W}$
 $C_i = 50 \text{ nF}$
 $L_i = 2 \text{ } \mu\text{H}$

Terminals 85, 86 (Ex e)

 $U_i = 30/70 \text{ V}_{pk}$
 $I_i = 130 \text{ mA}$
Compact version:

Refer to certificate number Sira 05ATEX2072X.

Variation 1 - This variation introduced the following changes:

- i. The ambient temperature specification relative to process temperatures was reviewed; this is the result of the upper process temperature limit being raised from 150°C up to a maximum of 180°C. The special condition for safe use appertaining to the temperature limits, temperature classes and maximum surface temperatures for dust are also modified and the marking has been amended so that the user/installer is advised to refer to the instructions for this information.

14 DESCRIPTIVE DOCUMENTS**14.1 Drawings**

Refer to Certificate Annexe.

14.2 Associated Sira Reports and Certificate History

Issue	Date	Report no.	Comment
0	1 October 2007	R52A16937A	The release of the prime certificate.
1	5 February 2008	R52A17771A	The introduction of Variation 1.

15 SPECIAL CONDITIONS FOR SAFE USE (denoted by X after the certificate number)

- 15.1 The surface temperature of the equipment depends on the temperature of the process fluid.

Maximum process fluid temperature	Temperature class (for gases)
67°C	T6 (85°C)
82°C	T5 (100°C)
117°C	T4 (135°C)
180°C ¹	T3 (200°C)

¹ The maximum ambient temperature allowed at this process temperature is +50°C. Process temperatures up to and including 150°C may have a maximum ambient temperature of +60°C.

For dust protection, the surface temperature is equal to the process fluid temperature +18 K when configured in the Remote version and process fluid temperature +18 K but not less than +85°C in the compact configuration.

- 15.2 In operation, the output is earthed through the conductive medium being measured and therefore potential equalisation is necessary throughout the hazardous area. The apparatus housing shall be connected to the potential equalising conductor in the hazardous area.

This certificate and its schedules may only be reproduced in its entirety and without change.

Form 9400 Issue1

Page 3 of 4

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
 Fax: +44 (0) 1244 681330
 Email: info@siracertification.com
 Web: www.siracertification.com

**SCHEDULE****EC TYPE-EXAMINATION CERTIFICATE****Sira 07ATEX3181X****Issue 1**

- 15.3 The external connections to the Ex 'e' Terminals of the Remote version shall comply with the following:
- 15.3.1 The wire conductors shall have a cross-sectional area between 0.5 mm² and 4 mm².
 - 15.3.2 No more than one single or multiple strand wire conductor shall normally be connected to each of the terminals. If multiple conductors are required, these shall be joined in a suitable manner, e.g. two conductors into a single insulated crimped boot lace ferrule.
 - 15.3.3 The insulation on the wire conductors shall extend to within 1mm of the metal of the terminal throat.
 - 15.3.4 The terminal screws shall be tightened down with a torque between 0.5 Nm and 0.7 Nm.
 - 15.3.5 The terminals shall never be exposed to temperatures outside of the range -50°C to +130°C; in addition, they shall only be installed and wired with cable in an ambient temperature of -10°C to +80°C. Furthermore, in the event of there being a process temperatures of +180°C in conjunction with an upper ambient temperature of +50°C the terminal strips should not be installed or wired with cable.
- 15.4 The terminal box shall not be opened when an explosive gas or dust atmosphere may be present.
- 16 **ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)**
- The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.
- 17 **CONDITIONS OF CERTIFICATION**
- 17.1 The use of this certificate is subject to the Regulations Applicable to Holders of Sira Certificates.
 - 17.2 Holders of EC type-examination certificates are required to comply with the production control requirements defined in Article 8 of directive 94/9/EC.
 - 17.3 Each enclosure, including cast pedestal when fitted, shall be subjected to a routine pressure test of 8.85 bar for at least 10 s as required by clause 16.1 of EN 60079-1:2004. There shall be no damage or permanent deformation as a result of the tests.
 - 17.4 When used in 'Compact' configuration, the conditions imposed by certificate Sira 05ATEX2072X apply to the assembly.
 - 17.5 Dielectric strength test required as per Clause 7.1 of EN 60079-7:2007
 - 17.6 The Remote Version of the equipment, as supplied, shall only be connected to another item of certified Ex ia associated apparatus or Ex e equipment (e.g. an electro-magnetic transmitter).
 - 17.7 This certificate relies on the following previously certified products. When used as part of the SITRANS F M MAGFLO MAG3100 Ex Flowsensor, the key attributes are listed in the table below and shall still be maintained by their original certificate.

Product	Certificate number	Key attributes
Weidmuller BK2/E terminal	Sira 01ATEX3247U	EEx e II

This certificate and its schedules may only be reproduced in its entirety and without change.

Form 9400 Issue1

Page 4 of 4

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
 Fax: +44 (0) 1244 681330
 Email: info@siracertification.com
 Web: www.siracertification.com

Certificate Annexe

Certificate Number: Sira 07ATEX3181X
Equipment: SITRANS F M MAGFLO MAG1100Ex
 DN2 to DN100
Applicant: Siemens Flow Instruments A/S

**Issue 0**

Number	Sheet	Rev.	Date (Sira stamp)	Description
083A0280	1 of 1	5	28 Sep 07	Skilt Plate
A5E01263820A	1 of 1	1	28 Sep 07	Appro. label MAG1100 DN2-100
A5E01263812A	1 of 1	1	28 Sep 07	Appro. label MAG6000I + MAG1100
A5E01409195A	1 of 1	1	28 Sep 07	Terminal box DN6-DN100 certification drawing MAG1100Ex sensors
A5E01409379A	1 of 1	1	28 Sep 07	Terminal box DN2-DN6 (Zirconium) certification drawing MAG1100Ex sensors
A5E01409438A	1 of 1	1	28 Sep 07	Certification drawing MAG1100 Ex DN2 to DN6 ZrO2
A5E01409518A	1 of 1	1	28 Sep 07	Certification drawing MAG1100 Ex DN6 to DN100 AI oxide
A5E01409569A	1 of 1	1	28 Sep 07	Certification drawing MAG1100 Ex food
A5E01409614A	1 of 1	1	28 Sep 07	Certification DRG for MAG1100Ex DN2-DN100 with MAG6000 Industry (SIRA)

Issue 1

Number	Sheet	Rev.	Date (Sira stamp)	Description
A5E01263820A	1 of 1	03	04 Feb 08	Appro. Label MAG1100 DN2-100
A5E01263812A	1 of 1	02	04 Feb 08	Appro. Label MAG6000I + MAG1100

This certificate and its schedules may only be reproduced in its entirety and without change.

Form 9400 Issue 1

Page 1 of 1

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
 Fax: +44 (0) 1244 681330
 Email: info@siracertification.com
 Web: www.siracertification.com



1 EC TYPE-EXAMINATION CERTIFICATE

2 Equipment intended for use in Potentially Explosive Atmospheres Directive 94/9/EC

3 Certificate Number: **Sira 03ATEX3339X** Issue: **7**

4 Equipment: **SITRANS F M MAGFLO MAG3100 Ex**

5 Applicant: **Siemens Flow Instruments**

6 Address: Magflo house
Ebley Road
Stonehouse
Gloucestershire GL10 2LU
UK

7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 Sira Certification Service, notified body number 0518 in accordance with Article 9 of Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN 50014:1997 (A1 and A2) EN 50019:2000 EN 50020:2002 EN 50281-1-1:1998

10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

11 This EC type-examination certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.

12 The marking of the equipment shall include the following:



II 2 G D
EEx e ia IIC T3 to T6

'Compact' arrangement marked 'MAG6000 INDUSTRY'



II 2(1)(2) GD T85°C
EEx de [ia] ia [ib] IIC T3-T6 (Ta -10°C to +60°C)

Project Number 52A17771
C. Index 13

This certificate and its schedules may only be reproduced in its entirety and without change.

C. Ellaby
Certification Officer

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
Fax: +44 (0) 1244 681330
Email: info@siracertification.com
Web: www.siracertification.com

**SCHEDULE****EC TYPE-EXAMINATION CERTIFICATE**

Sira 03ATEX3339X
Issue 7

13 DESCRIPTION OF EQUIPMENT

The SITRANS F M MAGFLO MAG3100 Ex flowsensor comprises a pair of increased safety windings and intrinsically safe magnetic sensing circuit electrodes that are mounted on a pipe body. The size range covered is DN350 to DN2000. The windings are rated at 30 V d.c. and the sensing circuit is rated at 9.3 V, 40 mA.

The pipe body is fitted with clips, which secure the increased safety windings, and pipe flanges for installation to the process pipework. Two diametrically opposed tubes are welded to the sides of the pipe and these contain intrinsically safe electrodes that pass through the wall of the pipe into the bore. An outer casing manufactured from steel encloses the windings and wiring, but the diametrically opposed tubes pass through this outer casing and the open ends are sealed by tamperproof plugs. The interior of the tubes is filled with gel encapsulant.

The increased safety windings are manufactured from self-bonding insulated copper winding wire and are connected in series. The connection leads from the windings and the electrodes are taken back to a junction box which is mounted on a tube welded to the outer casing. The leads pass through the tube and enter the rear of the enclosure where they are terminated on terminal blocks. The junction box meets IP67 ingress protection.

The sensing circuit leads are screened, with a single core, with the screens terminated on an earth terminal near the intrinsically safe terminal block.

Additional earthing electrodes fitted through the wall of the pipe may be provided. The earthing electrodes are fitted into holes in the sensor tube and are secured by a continuous weld. Alternatively the electrodes may be screwed in and Loctite applied to the threads to seal them.

Variation 1 - This variation introduced the following changes:

- i. The Special Condition For Safe Use, clause 15.3 in the original certificate, was deleted as the equipment cannot be used with a flow of metallic powder.
- ii. The replacement of drawing 083A0274 with drawing 083A0284, this reflects changes to the rating of the intrinsically safe sensing circuit as follows:

$$U_i = 30 \text{ V} \qquad L_i = 2 \text{ } \mu\text{H}$$

Variation 2 - This variation introduced the following changes:

- i. The correction of a ferrule specification drawing.

Variation 3 - This variation introduced the following changes:

- i. The introduction of a strengthening sleeve welded over the existing pedestal.

Variation 4 - This variation introduced the following changes:

- i. The removal of the terminal box and the fitting of interface components, this allows the Sitrans F M Magflo MAG6000 industry transmitter, Certificate Number Sira 05ATEX2072X, to be mounted directly onto the flowmeter, this combined transmitter/sensor arrangement being designated the 'Compact' arrangement and being marked 'MAG6000 INDUSTRY'; see clause 12 for applicable marking.
- ii. The introduction of an alternative method of joining the coil wire to the leads.
- iii. The use of an alternative terminal box base plate and intrinsically safe separation shield was permitted.
- iv. The use of alternative cable glands into the terminal box was permitted.
- v. The use of an alternative electrode pin through the existing glass ferrule was permitted.

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
 Fax: +44 (0) 1244 681330
 Email: info@siracertification.com
 Web: www.siracertification.com

**SCHEDULE****EC TYPE-EXAMINATION CERTIFICATE**

Sira 03ATEX3339X
Issue 7

Variation 5 - This variation introduced the following changes:

- i. The fabricated pedestal was substituted by a cast steel version.

Variation 6 - This variation introduced the following changes:

- i. The terminal box arrangement used on the MAG3100 (DN15 – DN300) under Sira certificate 07ATEX1182X may be used on this version of the MAG3100, sizes DN350 to DN2000; new drawing ASE01211109A refers.
- ii. The label material was changed from "adhesive backed polyester, temp range -20 to +140 Deg C" to "MP50 Metallised Polyester, Permanent Adhesive Backed" (to bring into line with other label materials), in addition, tolerance +/-2 mm was added to dimensions.
- iii. A reference to Sira 07ATEX1182X was included on Drawing 083Z3042.

Variation 7 - This variation introduced the following changes:

- i. The modification of the mounting arrangement for the divider separating the Ex 'e' and the Ex 'ia' terminals.

14 **DESCRIPTIVE DOCUMENTS**

14.1 **Drawings**

Refer to Certificate Annexe.

14.2 **Associated Sira Reports and Certificate History**

Issue	Date	Report no.	Comment
0	29 August 2003	R52V10518A	The release of the prime certificate.
1	25 May 2004	R53V11823V	The introduction of Variation 1.
2	4 April 2005	R51V13265A	The introduction of Variation 2.
3	13 March 2007	R51A16396A	The introduction of Variation 3.
4	16 August 2007	R51M15493A	The introduction of Variation 4.
5	16 July 2007	R51M16470A	The introduction of Variation 5.
6	7 December 2007	R52A17346A	This Issue covers the following changes: <ul style="list-style-type: none"> • All previously issued certification was rationalised into a single certificate, Issue 6, Issues 0 to 5 referenced above are only intended to reflect the history of the previous certification and have not been issued as documents in this format. • The introduction of Variation 6.
7	29 January 2008	R52A17771A	This Issue covers the following changes: <ul style="list-style-type: none"> • The introduction of Variation 7. • Special Condition for Safe Use, clause 15.3, was removed, refer to Variation 1. • The Certificate History was corrected and clarified. • The marking in clause 12 was extended to include that associated with the compact in Variation 4.

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
 Fax: +44 (0) 1244 681330
 Email: info@siracertification.com
 Web: www.siracertification.com

**SCHEDULE****EC TYPE-EXAMINATION CERTIFICATE****Sira 03ATEX3339X
Issue 7**15 **SPECIAL CONDITIONS FOR SAFE USE** (denoted by X after the certificate number)

15.1 The surface temperature of the equipment depends on the temperature of the process fluid:

Process fluid temperature	Temperature class (for gases)
<75°C	T6
<90°C	T5
<125°C	T4
<190°C	T3

For dust protection, the surface temperature is equal to the process fluid temperature plus 5°C.

15.2 In operation, the output is earthed through the conductive medium being measured and therefore potential equalisation is necessary throughout the hazardous area. The apparatus housing shall be connected to the potential equalising conductor in the hazardous area.

16 **ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II** (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

17 **CONDITIONS OF CERTIFICATION**

17.1 The use of this certificate is subject to the Regulations Applicable to Holders of Sira Certificates.

17.2 Holders of EC type-examination certificates are required to comply with the production control requirements defined in Article 8 of directive 94/9/EC.

17.3 This certificate relies on the following previously certified products. When used as part of the SITRANS F M MAGFLO MAG3100 Ex flowsensor, the key attributes listed in the table below shall still be maintained by their original certificate.

Product	Certificate number	Key attributes
Weidmuller BK2/E terminal	Sira 01ATEX3247U	EEx e II
Hawke type PET5 Pillar earth terminal	BAS 01ATEX2247U	EEx e II

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
Fax: +44 (0) 1244 681330
Email: info@siracertification.com
Web: www.siracertification.com

Certificate Annexe

Certificate Number: Sira 03ATEX3339X
Equipment: SITRANS F M MAGFLO MAG3100 Ex
Applicant: Siemens Flow Instruments

**Issue 0**

Drawing	Sheet	Rev.	Date	Title
083A0275	1 of 1	2	11 Aug 03	Data label MAG 3100Ex Flowsensor
083A0266	1 of 1	4	11 Aug 03	Intrinsically Safe Electrode Terminals Label MAG3100Ex Flowsensor
083A0274	1 of 1	3	12 Aug 03	Certification Label DN350 to DN2000 MAG3100Ex Sensors
083A0245	1 of 1	4	12 Aug 03	Safety Label MAG3100Ex Flowsensor
083C0233	1 of 1	7	12 Aug 03	Internal Wiring Diagram EEx e ia DN350-DN2000 incl MAG3100Ex Sensors
083Z0151	1 of 1	4	12 Aug 03	Ferrule Glass Seal Assy. MAG3100Ex flowsensor
083Z9542	1 of 1	6	28 Apr 03	Coil winding DN350 – DN2000 MAG3100Ex sensors
083Z9544	1 of 1	4	12 Aug 03	Terminal Box DN350-DN2000 Certification Drawing Mag3100Ex Sensors
083Z9545	1 of 1	4	12 Aug 03	Certification Drawing EEx e ia IIC Specification MAG3100Ex DN350-DN2000
083Z9546	1 of 1	4	12 Aug 03	Certification Drawing Coil and Electrode Assembly MAG3100Ex DN350-DN2000
083Z9555	1 of 1	2	12 Aug 03	Certification Drawing Fixing Earthing Electrode MAG3100Ex DN350-DN2000
083R0208	1 of 1	3	12 Aug 03	Joining Coil Wire to Flying Lead MAG3100Ex Flowsensor

Issue 1

Drawing	Sheet	Rev.	Date	Description
083A0284	1 of 1	1	04 May 04	Certification Label

Issue 2

Drawing	Sheet	Rev.	Date	Description
083Z0151	1 of 1	5	27 Nov 03	Ferrule Glass Seal Assy. MAG3100Ex Flowsensor

Issue 3

Drawing	Sheet	Rev.	Date	Description
083R1633	1 of 1	3	(Sira stamp) 13 Mar 07	Pedestal Support Sleeve MAG3100 / MAG3100EX

Issue 4

Drawing	Sheet	Rev.	Date	Description
083Z9610	1 of 1	01	29 Sep 06	MAG3100Ex 'Compact' – < DN350
083Z9609	1 of 1	02	10 Aug 06	MAG3100Ex 'Compact' – > DN 350
083Z9544	1 of 1	05	09 Aug 06	Modified Terminal Box Arrangement
083Z3042	1 of 1	03	09 Aug 06	Modified Electrode Arrangement
083R0207	1 of 1	02	01 May 03	Coil Wire Jointing Method
A5E00713575A	1 of 1	05	07 Aug 07	Amalgamated Label Drawing

Issue 5

Drawing	Sheet	Rev.	Date	Description
083Z9545	1 of 1	05	25 Sep 06	Certification Drawing EEx e ia IIC Specification MAG3100Ex DN350-DN2000
083Z9609	1 of 1	03	13 Feb 07	MAG3100Ex 'Compact' – > DN 350
083Z9610	1 of 1	03	09 Feb 07	MAG3100Ex 'Compact' – DN15-2000

This certificate and its schedules may only be reproduced in its entirety and without change.

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
 Fax: +44 (0) 1244 681330
 Email: info@siracertification.com
 Web: www.siracertification.com

Certificate Annexe

Certificate Number: Sira 03ATEX3339X
Equipment: SITRANS F M MAGFLO MAG3100 Ex
Applicant: Siemens Flow Instruments

**Issue 6**

Drawing	Sheet	Rev.	Date	Description
A5E01211109A	1 of 1	01	05 Sep 07	Terminal Box DN15-DN2000 Certification Drawing MAG3100Ex Sensors
083A0245	1 of 1	05	06 Oct 05	MP50 metalised polyester permanent adhesive backed.
083Z3042	1 of 1	04	12 Sep 07	Ferrule/Glass Seal Assy MAG3100 Flowsensor.
083Z9546	1 of 1	05	30 Nov 07	Certification Drawing Coil & Electrode Assembly MAG3100Ex DN350 – DN2000

Issue 7

Drawing	Sheet	Rev.	Date	Description
A5E01211109A	1 of 1	03	28 Jan 08	Terminal Box DN15-DN2000 Certification Drawing MAG3100Ex Sensors

This certificate and its schedules may only be reproduced in its entirety and without change.

Form 9400 Issue 1

Page 2 of 2

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900
 Fax: +44 (0) 1244 681330
 Email: info@siracertification.com
 Web: www.siracertification.com

[1] **EC-TYPE EXAMINATION CERTIFICATE**

[2] Equipment or Protective System intended for use
in Potentially Explosive Atmospheres
Directive 94/9/EC

[3] EC-Type Examination Certificate Number: DEMKO 03 ATEX 135254X

[4] Equipment or Protective System: SITRANS F M MAGFLO Safety Barrier Type FDK:083F50_ _

[5] Manufacturer: Siemens Flow Instruments A/S.

[6] Address: Nordborgvej 81, DK-6430 Nordborg, Denmark.

[7] This equipment or protective system and any acceptable variation there to is specified in the schedule to this certificate and the documents therein referred to.

[8] UL International Demko A/S, notified body number 0539 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report no. 135254.

[9] Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
EN 50014: 1997 E Amds. A1+A2 EN 50020 2002 E

[10] If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

[11] This EC-Type examination certificate relates only to the design, examination and tests of the specified equipment or protective system in accordance to the Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by the certificate.

[12] The marking of the equipment or protective system shall include the following:

 II (2)G [EEEx ia] IIC

On behalf of UL International Demko A/S

Herlev, 2003-09-01


Karina Christiansen
Certification Manager

UL International Demko A/S

Lyskaer 8, P.O. Box 514
DK-2730 Herlev, Denmark
Telephone: +45 44856565
Fax: +45 44856500

Certificate: 03 ATEX 135254X

This certificate may only be reproduced in its
entirety and without any change, schedule included



An Affiliate of
**Underwriters
Laboratories Inc.®**

P1

Schedule

EC-TYPE EXAMINATION CERTIFICATE No.
DEMKO 03 ATEX 135254X[15] Description of Equipment or protective system.

The SITRANS F M MAGFLO Safety Barrier Type FDK:083F50__ is associated apparatus and comprises a Stahl zener barrier type 9002/22-093-040-00 mounted on a printed circuit board and enclosed in an enclosure with an ingress protection rating of not less than IP 20.

Nomenclature for type FDK:083F5034

Electrical data

Non Intrinsic safety circuits: U_m : 250 V

Intrinsically safe specifications:

ia output (terminal no.: 82 – 83):

Linear characteristic:

U_o : 9,3 V

I_o : 40 mA

P_o : 0,4 W

L_o : 23 mH

C_o : 500 nF

Installation instructions and mounting instructions

According to manufacture Instruction Manual.

Routine tests

Routine tests according to EN 50020 §11.1 shall be done by the manufacture.

[16] Report No.

Project Report No.: 135254-01; 135254-03 (Hazardous Location Testing)

Drawings:

Number

083R3089_DS01

Date

2006-05-02

Description

R-instruction.

The Schedule drawings are listed in the document entitled 083R3089.

UL International Demko A/S

Lyskaer 8, P.O. Box 514
DK-2730 Herlev, Denmark
Telephone: +45 44856565
Fax: +45 44856500

Certificate: 03 ATEX 135254X
Report: 135254-03

This certificate may only be reproduced in its
entirety and without any change, schedule included



An Affiliate of
**Underwriters
Laboratories Inc.®**

P2/3

Schedule

EC-TYPE EXAMINATION CERTIFICATE No. DEMKO 03 ATEX 135254X

17] Special conditions for safe use:

- The ambient temperature range is -20 °C to +50 °C.
- The barrier shall be connected to the PE earth (light blue) according to local installation equipments. IEC60079-14 can be used as guideline.
- The PE earth shall be connected to the PE at the sensor according to local installation equipments. IEC60079-14 can be used as guideline.
- The intrinsic safety wiring shall be separated from non intrinsic safety wiring according to local installation equipments.
- The apparatus must be installed in plastic enclosure code FDK:083F5038 with an Ingress Protection suitable for the environment. The Plastic box FDK083F5038 has been evaluated for IP65 according to EN60529: 1989.

18] Essential Health and Safety Requirements

Concerning ESR this Schedule verifies compliance with the Ex standards only. The manufacturer's Declaration of Conformity declares compliance with other relevant Directives.

The manufacturer shall inform the notified body concerning all modifications to the technical documentation as described in ANNEX III to Directive 94/9/EC of the European Parliament and the Council of 23 March 1994.

On behalf of UL International Demko A/S

Herlev, 2006-12-04


Karina Christiansen
Certification Manager

UL International Demko A/S

Lyskaer 8, P.O. Box 514
DK-2730 Herlev, Denmark
Telephone: +45 44856565
Fax: +45 44856500

Certificate: 03 ATEX 135254X
Report: 135254-03

This certificate may only be reproduced in its entirety and without any change, schedule included



An Affiliate of
**Underwriters
Laboratories Inc.®**

P3/3

For more information

www.siemens.com/flow

Siemens A/S
Flow Instruments
Nordborgvej 81
DK-6430 Nordborg

Subject to change without prior notice
Order No.: A5E02082880
Lit. No.: SFIDK.PS.026.C4.02
© Siemens AG 07.2010



www.siemens.com/automation