

Certificate of Compliance

Certificate Number **20110713-E44653**
Report Reference **E44653-19960620**
Issue Date **2011-JULY-13**

Page 1 of 3



Issued to: **SIEMENS AG
I IA CE CP PRM SR
WERNER-VON-SIEMENS-STRASSE 48
92220 AMBERG GERMANY**

*This is to certify that
representative samples of* **AUXILIARY DEVICES**

3RH1911 followed by -1, followed by A, or B followed by A, followed by 0, or 1, followed by 0, or 1, may be followed by suffix letters and/or numbers.


Type No. 3RA1924-1A

*Have been investigated by Underwriters Laboratories in accordance with
the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: **Industrial Control Equipment-UL 508 and CSA-C22.2 No. 14**

Additional Information: See UL On-line Certification Directory at WWW.UL.COM for additional information.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney
Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus>

Certificate of Compliance

Certificate Number **20110713-E44653**
Report Reference **E44653-19960620**
Issue Date **2011-JULY-13**

Page 2 of 3



This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

GENERAL:

3RH1911:

These devices are 1-pole auxiliary contact blocks for this manufacturer's devices series 3R.

3RA1924-1A:

These devices are mechanical interlock without electrical function for reversing contactors series 3R.

RATINGS:

A600/Q600

240 V/10 A general purpose

NOMENCLATURE BREAKDOWN:

3RH1911 = $\frac{1}{I}$ $\frac{A}{II}$ $\frac{A}{III}$ $\frac{1}{IV}$ $\frac{0}{V}$ $\frac{0}{VI}$ $\frac{..}{VII}$

I - Basic type

II - Type of terminals

-1 - Screw terminal

III - Mounting area

A - Top mounted, entry of conductors top

B - Top mounted, entry of conductors bottom

IV - Switching function

A - Without determination

V - Contact arrangements for NO

0 - non NO

1 - 1 NO

William R. Carney

Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus>

Certificate of Compliance

Certificate Number **20110713-E44653**
Report Reference **E44653-19960620**
Issue Date **2011-JULY-13**

Page 3 of 3



VI - Contact arrangements for NC

0 - nonNC

1 - 1 NC

VII - Manufacturers Identification

.. - Manufacturers Identification

3RA1924-1A - Mechanical interlock

William R. Carney

Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus>