


Test Documents for Vacuum Circuit-Breaker 3AH4306-8 (36 kV, 40 kA, 4000 A)

The vacuum circuit-breakers of type 3AH4 were type tested in accordance with

IEC Publication 62271-1, Edition 1.0, 2007-10,
IEC Publication 62271-100, Edition 2.0, 2008-04 and the relevant harmonisation documents.

For vacuum circuit-breaker 3AH4306-8 the following test documents are valid:

Type Tests	Rated Values	Test Documents
Dielectric tests	$U_p = 170 \text{ kV}$ $U_d = 70 \text{ kV}$	09-011-MH/E
Temperature-rise tests	$I_r = 4000 \text{ A}$	09-077-ME/E
Mechanical operation test at ambient temperature, Low and high temperature tests	120.000 op. Cycles -5 / +55 °C	11-015-MM/E
Short-time withstand current and peak withstand current tests	$I_{sc} = 40 \text{ kA/3s}$ $I_{ma} = 104 \text{ kA}$	KEMA 105-04
Short-circuit making and breaking tests	$I_{sc} = 40 \text{ kA}$ $I_{ma} = 104 \text{ kA}$	KEMA 105-04



Berlin, September 09, 2011

Siemens AG
Energy Sector; Leitung: Wolfgang Dehen
Power Distribution Division; Leitung: Ralf Christian
Medium Voltage; Leitung: Wolfgang Heuring

Nonnendammallee 104
13629 Berlin
Deutschland

Tel.: +49 (30) 386 0

Siemens Aktiengesellschaft: Vorsitzender des Aufsichtsrats: Gerhard Cromme; Vorstand: Peter Löscher, Vorsitzender; Wolfgang Dehen, Heinrich Hiesinger, Joe Kaeser, Barbara Kux, Hermann Requardt, Siegfried Russwurm, Peter Y. Solmsen
Sitz der Gesellschaft: Berlin und München, Deutschland; Registergericht: Berlin Charlottenburg, HRB 12300, München, HRB 6684
WEEE-Reg.-Nr. DE 23691322

Test Documents for Vacuum Circuit-Breaker 3AH4306-8 (36 kV, 40 kA, 4000 A)

If a test is carried out with a vacuum circuit-breaker with different order number, the validity of the test document is given by the following statements:

The listed test documents for the mentioned vacuum circuit-breaker are valid in respect to familiar design of the vacuum circuit-breakers, as the construction of the main current path and mechanical driving mechanism is nearly identical.


Anger
E D MV C PMB



Berlin, September 09, 2011

Siemens AG
Energy Sector; Leitung: Wolfgang Dehen
Power Distribution Division; Leitung: Ralf Christian
Medium Voltage; Leitung: Wolfgang Heuring

Nonnendammallee 104
13629 Berlin
Deutschland


Tel.: +49 (30) 386 0

Siemens Aktiengesellschaft: Vorsitzender des Aufsichtsrats: Gerhard Cromme; Vorstand: Peter Löscher, Vorsitzender; Wolfgang Dehen, Heinrich Hiesinger, Joe Kaeser, Barbara Kux, Hermann Requardt, Siegfried Russwurm, Peter Y. Solmssen
Sitz der Gesellschaft: Berlin und München, Deutschland; Registergericht: Berlin Charlottenburg, HRB 12300, München, HRB 6684
WEEE-Reg.-Nr. DE 23691322

Test Documents for Vacuum Circuit-Breaker 3AH4306-8 (36 kV, 40 kA, 4000 A)

In addition to the type tests in accordance with IEC 62271-1 and IEC 62271-100 the following tests were carried out:

Type Tests	Test Documents
Single-phase and double earth fault tests	KEMA 105-04
Capacitive current switching tests: -cable-charging current breaking tests -single capacitor bank switching tests	KEMA 105-04
Out-of-phase making and breaking tests	KEMA 105-04



Anger
E D M V C P M B

Berlin, September 09, 2011

Siemens AG
Energy Sector; Leitung: Wolfgang Dehen
Power Distribution Division; Leitung: Ralf Christian
Medium Voltage; Leitung: Wolfgang Heuring

Nonnendammallee 104
13629 Berlin
Deutschland

Tel.: +49 (30) 386 0

Siemens Aktiengesellschaft: Vorsitzender des Aufsichtsrats: Gerhard Cromme; Vorstand: Peter Löscher, Vorsitzender;
Wolfgang Dehen, Heinrich Hiesinger, Joe Kaeser, Barbara Kux, Hermann Requardt, Siegfried Russwurm, Peter Y. Solmssen
Sitz der Gesellschaft: Berlin und München, Deutschland; Registergericht: Berlin Charlottenburg, HRB 12300, München, HRB 6684
WEEE-Reg.-Nr. DE 23691322