

CERTIFICATE

NO. 2538/6178

Regensburg, 2004-07-26

Customer: User	Order-No. --- Dispatch Note No. --- Copy: 1 x
-------------------	---

Item	Quantity	Equipment
		Auxiliary contact for N-type miniature circuit-breakers 5SY..., 5SP4... 5ST3010, 5ST3011, 5ST3012
		Fault signal contact for N-Type miniature circuit-breakers 5SY..., 5SP4... 5ST3020, 5ST3021, 5ST3022

The equipment is manufactured according to the specifications nach DIN VDE 0660, part 200 (DIN EN 60947-5-1) and DIN EN 62019 (VDE 0640).

It possesses the approval in accordance with these specifications.
The corresponding quality is superintended by off-hand samples taken by our testing-department.

Siemens Aktiengesellschaft

J. V. Wagner
Wagner

J. V. Hoffmann
Dr. Hoffmann

Electrical Installation Technology Division

Division President: Godehardt Schneider

Postal Address: Siemens AG
Q P

Name:
Peifz
Office Address:

Telephone +49 941 790 - 01 (Switchboard)
Direct Tel. 2419
Fax +49 941 790 - 2714

P. O. Box 10 09 53
D - 93009 Regensburg

Siemensstr. 10
D - 93055 Regensburg

Siemens Aktiengesellschaft · Chairman of the Supervisory Board: Karl-Hermann Baumann · Managing Board: Heinrich v. Pierer, Chairman, President and Chief Executive Officer · Members: Johannes Feldmayer, Thomas Ganswindt, Klaus Kleinfeld, Edward G. Krubasik, Rudi Lamprecht, Heinz-Joachim Neubürger, Jürgen Radomski, Erich R. Reinhardt, Uriel J. Sharef, Claus Weyrich, Klaus Wucherer
Registered Offices: Berlin and München · Commercial Registries: Berlin-Charlottenburg, HRB 12300; München, HRB 6684