

SIEMENS

SIMATIC

S7-PLCSIM Advanced

Function Manual

Introduction

1

Product overview

2

Installing

3

Communication paths

4

Simulating

5

Virtual time response

6

Restrictions, messages, and
solution

7

List of abbreviations

A

Legal information

Warning notice system

This manual contains notices you have to observe in order to ensure your personal safety, as well as to prevent damage to property. The notices referring to your personal safety are highlighted in the manual by a safety alert symbol, notices referring only to property damage have no safety alert symbol. These notices shown below are graded according to the degree of danger.

DANGER

indicates that death or severe personal injury **will** result if proper precautions are not taken.

WARNING

indicates that death or severe personal injury **may** result if proper precautions are not taken.

CAUTION

indicates that minor personal injury can result if proper precautions are not taken.

NOTICE

indicates that property damage can result if proper precautions are not taken.

If more than one degree of danger is present, the warning notice representing the highest degree of danger will be used. A notice warning of injury to persons with a safety alert symbol may also include a warning relating to property damage.

Qualified Personnel

The product/system described in this documentation may be operated only by **personnel qualified** for the specific task in accordance with the relevant documentation, in particular its warning notices and safety instructions. Qualified personnel are those who, based on their training and experience, are capable of identifying risks and avoiding potential hazards when working with these products/systems.

Proper use of Siemens products

Note the following:

WARNING

Siemens products may only be used for the applications described in the catalog and in the relevant technical documentation. If products and components from other manufacturers are used, these must be recommended or approved by Siemens. Proper transport, storage, installation, assembly, commissioning, operation and maintenance are required to ensure that the products operate safely and without any problems. The permissible ambient conditions must be complied with. The information in the relevant documentation must be observed.

Trademarks

All names identified by ® are registered trademarks of Siemens Aktiengesellschaft. The remaining trademarks in this publication may be trademarks whose use by third parties for their own purposes could violate the rights of the owner.

Disclaimer of Liability

We have reviewed the contents of this publication to ensure consistency with the hardware and software described. Since variance cannot be precluded entirely, we cannot guarantee full consistency. However, the information in this publication is reviewed regularly and any necessary corrections are included in subsequent editions.

Table of contents

1	Introduction.....	6
1.1	General information.....	6
1.2	S7-PLCSIM Advanced documentation guide.....	7
1.3	Tool support.....	12
1.4	Cybersecurity information.....	13
1.5	Administrator rights.....	13
2	Product overview	14
2.1	What is S7-PLCSIM Advanced?	14
2.2	S7-PLCSIM products.....	15
2.3	Supported CPUs.....	17
2.4	Compatibility in case of updates.....	18
2.5	Security for S7-PLCSIM Advanced.....	19
2.6	Supporting simulation.....	20
2.7	Differences between a simulated and a real CPU.....	20
2.7.1	Restrictions for all supported CPUs.....	21
2.7.2	Notes.....	22
2.8	Password to protect confidential configuration data.....	24
3	Installing.....	26
3.1	Introduction.....	26
3.1.1	System requirements.....	26
3.1.2	Restrictions due to antivirus programs	27
3.1.3	Licenses.....	28
3.1.4	Trial License.....	28
3.1.5	Installation log.....	29
3.1.6	Contents of the S7-PLCSIM Advanced package.....	30
3.2	Installing S7-PLCSIM Advanced.....	30
3.3	Changing an installation.....	32
3.4	Repairing an installation.....	32
3.5	Uninstalling the product.....	33

4	Communication paths.....	35
4.1	Local communication	36
4.2	Communication via TCP / IP.....	37
4.2.1	Communication via TCP/IP in Single Adapter Network Mode (promiscuous mode).....	37
4.2.2	Communication via TCP/IP in Multiple Adapter Network Mode (non-promiscuous mode)	40
4.2.3	Using a Software/Open Controller with a TCP/IP communication interface.....	43
4.3	Enable distributed communication	44
5	Simulating.....	47
5.1	Simulating a CPU.....	47
5.1.1	Basic procedure for the simulation.....	47
5.1.2	Control Panel - User interface.....	48
5.1.2.1	S7-PLCSIM Advanced Symbol.....	48
5.1.2.2	Control Panel quick view and window.....	48
5.1.2.3	S7-PLCSIM Advanced Control Panel.....	50
5.1.2.4	Importing instances.....	54
5.1.3	Downloading a STEP 7 project.....	55
5.1.4	Network addresses in the simulation.....	59
5.1.4.1	Siemens PLCSIM Virtual Ethernet Adapter.....	59
5.1.4.2	S7-PLCSIM Advanced instances.....	60
5.1.5	Simulate communication.....	62
5.1.5.1	Communication services that can be simulated.....	62
5.1.5.2	Communication between instances.....	63
5.1.6	Provide project data offline for simulation	64
5.2	Simulating a CPU with ODK functionality.....	66
5.2.1	Special features of ODK.....	66
5.2.2	Loading functions	69
5.2.3	Calling functions.....	69
5.2.4	Unloading functions.....	70
5.3	Simulating the SIMATIC Drive Controller.....	72
5.4	Simulating a redundant S7-1500R/H system.....	74
6	Virtual time response.....	77
6.1	Speed up and slow down simulation.....	78
7	Restrictions, messages, and solution.....	79
7.1	OPC UA server.....	79
7.2	Web server.....	79
7.3	Backing up and restoring the configuration of an S7-PLCSIM Advanced instance.....	80
7.4	Loading project data of an F-CPU to a standard CPU	80
7.5	Update of a TIA Portal project to a new CPU firmware.....	81
7.6	Restrictions for storage paths.....	81
7.7	Restrictions for instance names.....	82

7.8	Restrictions for communications services.....	82
7.9	Restrictions for instructions.....	82
7.10	Restrictions to local communication via Softbus.....	83
7.11	Unknown data records.....	83
7.12	Messages for communication via TCP/IP.....	83
7.13	Time synchronization via NTP mode	85
7.14	Restrictions of security with VMware vSphere Hypervisor (ESXi).....	85
7.15	Restrictions for Hyper-V.....	86
7.16	Restrictions for AWS Cloud.....	86
7.17	Monitoring overflow	86
7.18	Deviating I/O values in the STEP 7 user program	87
7.19	Multiple simulations and possible collision of IP addresses.....	87
7.20	Lacking access to an IP address.....	87
7.21	Simulation in standby mode.....	87
7.22	Simulation start of SIMIT with S7-PLCSIM Advanced.....	88
7.23	Known restrictions when operating with a co-simulation, for example, SIMIT.....	88
7.24	ET 200SP CPUs: Use of BusAdapters with fiber-optic interface.....	88
7.25	Installing SIMATIC NET.....	89
7.26	No simulation for configuration control.....	90
7.27	Communication interface is not updated on the control panel when using an older API.....	90
7.28	Trace jobs with duplicate timestamps for motion OBs.....	90
7.29	The control panel shows VPNs.....	90
7.30	Downloading a central CP with S7-1500R/H CPU family using TCP/IP.....	90
7.31	Axis control panel functionality.....	90
7.32	Cannot locate S7-PLCSIM Advanced Instances.....	91
7.33	Synchronization of IRT systems.....	91
7.34	Simulated PLC will not RUN with local I/O send clock.....	91
7.35	Download error after change to "IP address from DHCP server" in STEP 7.....	91
7.36	Software PLC interfaces not showing after download.....	92
A	List of abbreviations.....	93

Introduction

1.1 General information

Purpose of the documentation

This function manual describes the simulation software, SIMATIC S7-PLCSIM Advanced. You can use this software to simulate and test your SIMATIC STEP 7 programs on a simulated PLC instance. You can also use an API to connect the simulated PLC instance to a system or machine simulation (co-simulation).

Basic knowledge required

The software must only be used by qualified staff.
The following knowledge is required:

- Industrial Automation and Automation Technology
- Programming with STEP 7 (TIA Portal)
- SIMATIC CPUs and CPU programming
- PC-based automation using S7-1500 and WinCC Runtime Advanced
- Knowledge of programming with C++ or C#
- PC technology
- Windows operating system

Conventions

STEP 7: In this documentation, "STEP 7" is used as a synonym for all versions of the configuration and programming software "SIMATIC STEP 7 (TIA Portal)".

Also observe notes marked as follows:

NOTE

A note contains important information on the product described in the documentation, on the handling of the product or on the section of the documentation to which particular attention should be paid.

Scope

This function manual is valid for the following product variants:

Article number	Product variants
6ES7823-1FA06-0YA5	SIMATIC S7-PLCSIM Advanced V7.0
6ES7823-1FE06-0YA5	SIMATIC S7-PLCSIM Advanced V7.0 Download
6ES7823-1FA06-0YE5	SIMATIC S7-PLCSIM Advanced V7.0 Upgrade V1.0 -> V7.0
6ES7823-1FE06-0YE5	SIMATIC S7-PLCSIM Advanced V7.0 Upgrade V1.0 -> V7.0 Download
6ES7823-1FE06-0YA7	SIMATIC S7-PLCSIM Advanced V7.0 POC
6ES7823-1FE00-0YN5	SIMATIC S7-PLCSIM Advanced Subscription Download

The articles each contain one license, which is valid for two instances.

NOTE

You can obtain online readme updates to the S7-PLCSIM manuals on the Internet (<https://support.industry.siemens.com/cs/us/en/view/109824282>).

You can find the following application examples for S7-PLCSIM Advanced on the Internet:

- SIMATIC S7-PLCSIM Advanced: Co-Simulation via API
(<https://support.industry.siemens.com/cs/ww/de/view/109739660/en>)
- Digitalization with TIA Portal: Virtual commissioning with SIMATIC and Simulink
(<https://support.industry.siemens.com/cs/ww/en/document/109749187>)

Recycling and disposal

For environmentally sustainable recycling and disposal of your old equipment, contact a certified electronic waste disposal service and dispose of the equipment according to the applicable regulations in your country.

Industry Mall

The Industry Mall (<https://mall.industry.siemens.com>) is the catalog and order system of Siemens AG for automation and drive solutions on the basis of Totally Integrated Automation (TIA) and Totally Integrated Power (TIP).

1.2 S7-PLCSIM Advanced documentation guide

The control panel buttons display the English S7-PLCSIM Advanced Function Manual and API Manual in PDF format. Download the free Adobe Reader if necessary to view PDFs. The installation folder of S7-PLCSIM Advanced includes German PDFs and English PDFs.

Other display formats are available at Siemens Industry Online Support (<https://support.industry.siemens.com>) (SIOS).

Accessing documentation on SIOS

Documentation for this product is available at Siemens Industry Online Support (<https://support.industry.siemens.com/>). Formats include the following for display or download:

- PDF document
- Multimedia document (HTML5 Web site)
- Website with chapter structure (useful for providing a specific topic link to other people)

From the Web site, search for your product name. Filter the search results by manuals if you are only looking for documentation. For your product, select the edition that corresponds to the version of your product. You can switch the display language for the page and the documents from the menu.

The various document formats provide navigation and search features based on their documentation format.

Navigating an HTML5 site

When you open an HTML5 Web site, click Begin from the Start page.

The table of contents displays on the left. Each chapter collapses as you navigate from one chapter to the next to optimize screen space on devices such as phones and tablets. You can also click the  button to hide the table of contents. Click  to restore it.

Left and right arrow buttons allow to navigate back and forward through topics that you have previously viewed:  

Previous and next page buttons allow you to navigate sequentially through topics and chapters in the order of the table of contents:  

Searching in an HTML5 site

To search an HTML5 Web site, click the  button on the right. When you enter your search text, you see a list of topics that contain the search text. Click any topic to view it. The page highlights occurrences of the matched search text.

To see where the topic exists in the table of contents, click the  button to switch from the search view to the table of contents view. To switch back to your search, click  again. The search functions much the same as any search from a Web browser. Ctrl+F searches within the displayed topic.

Changing the language of the HTML5 site

The S7-PLCSIM Advanced HTML5 documentation includes German and English. Click the  button to switch to another language.



The documentation for the SIMATIC S7-1500 automation system, for the 1513/1516pro-2 PN, SIMATIC Drive Controller CPUs based on SIMATIC S7-1500 and the SIMATIC ET 200MP, ET 200SP, ET 200AL and ET 200eco PN distributed I/O systems is arranged into three areas.

This arrangement enables you to access the specific content you require.

You can download the documentation free of charge from the Internet

(<https://support.industry.siemens.com/cs/ww/en/view/109742705>).

Basic information



The system manuals and Getting Started describe in detail the configuration, installation, wiring and commissioning of the SIMATIC S7-1500, SIMATIC Drive Controller, ET 200MP, ET 200SP, ET 200AL and ET 200eco PN systems. Use the corresponding operating instructions for 1513/1516pro-2 PN CPUs.

The STEP 7 online help supports you in the configuration and programming.

Examples:

- Getting Started S7-1500
- System manuals
- Operating instructions ET 200pro and 1516pro-2 PN CPU
- Online help TIA Portal

Device information



Equipment manuals contain a compact description of the module-specific information, such as properties, wiring diagrams, characteristics and technical specifications.

Examples:

- Equipment manuals for CPUs
- Equipment manuals for interface modules
- Equipment manuals for digital modules
- Equipment manuals for analog modules
- Equipment manuals for communication modules
- Equipment manuals for technology modules
- Equipment manuals for power supply modules
- Equipment manuals for BaseUnits

General information



The function manuals contain detailed descriptions on general topics relating to the SIMATIC Drive Controller and the S7-1500 automation system.

Examples:

- Function Manual Diagnostics
- Function Manual Communication
- Function Manuals Motion Control
- Function Manual Web Server
- Function Manual Cycle and Response Times
- PROFINET Function Manual
- PROFIBUS Function Manual

Product Information

Changes and supplements to the manuals are documented in a Product Information. The Product Information takes precedence over the device and system manuals.

You will find the latest Product Information on the Internet:

- S7-1500/ET 200MP (<https://support.industry.siemens.com/cs/de/en/view/68052815>)
- SIMATIC Drive Controller (<https://support.industry.siemens.com/cs/de/en/view/109772684/en>)
- Motion Control (<https://support.industry.siemens.com/cs/de/en/view/109794046/en>)
- ET 200SP (<https://support.industry.siemens.com/cs/de/en/view/73021864>)
- ET 200eco PN (<https://support.industry.siemens.com/cs/ww/en/view/109765611>)

Manual Collections

The Manual Collections contain the complete documentation of the systems put together in one file.

You will find the Manual Collections on the Internet:

- S7-1500/ET 200MP/SIMATIC Drive Controller (<https://support.industry.siemens.com/cs/ww/en/view/86140384>)
- ET 200SP (<https://support.industry.siemens.com/cs/ww/en/view/84133942>)
- ET 200AL (<https://support.industry.siemens.com/cs/ww/en/view/95242965>)
- ET 200eco PN (<https://support.industry.siemens.com/cs/ww/en/view/109781058>)

Additional SIMATIC documents will complete your information. You can find these documents and their use at the following links and QR codes.

The Industry Online Support gives you the option to get information on all topics. Application examples support you in solving your automation tasks.

Overview of the SIMATIC Technical Documentation

Here you will find an overview of the SIMATIC documentation available in Siemens Industry Online Support:



Industry Online Support International
<https://support.industry.siemens.com/cs/ww/en/view/109742705>

Watch this short video to find out where you can find the overview directly in Siemens Industry Online Support and how to use Siemens Industry Online Support on your mobile device:



Quick introduction to the technical documentation of automation products per video <https://support.industry.siemens.com/cs/us/en/view/109780491>



YouTube video: Siemens Automation Products - Technical Documentation at a Glance <https://youtu.be/TwLSxxRQqSA>

mySupport

With "mySupport" you can get the most out of your Industry Online Support.

Registration	You must register once to use the full functionality of "mySupport". After registration, you can create filters, favorites and tabs in your personal workspace.
Support requests	Your data is already filled out in support requests, and you can get an overview of your current requests at any time.
Documentation	In the Documentation area you can build your personal library.
Favorites	You can use the "Add to mySupport favorites" to flag especially interesting or frequently needed content. Under "Favorites", you will find a list of your flagged entries.
Recently viewed articles	The most recently viewed pages in mySupport are available under "Recently viewed articles".
CAX data	The CAX data area gives you access to the latest product data for your CAX or CAE system. You configure your own download package with a few clicks: • Product images, 2D dimension drawings, 3D models, internal circuit diagrams, EPLAN macro files • Manuals, characteristics, operating manuals, certificates • Product master data

You can find "mySupport" on the Internet. <https://support.industry.siemens.com/My/ww/en>

Application examples

The application examples support you with various tools and examples for solving your automation tasks. Solutions are shown in interplay with multiple components in the system - separated from the focus on individual products.

You can find the application examples on the Internet.

(<https://support.industry.siemens.com/cs/ww/en/ps/ae>)

1.3 Tool support

Tools

The tools described below support you in all steps: from planning, over commissioning, all the way to analysis of your system.

TIA Selection Tool

The TIA Selection Tool tool supports you in the selection, configuration, and ordering of devices for Totally Integrated Automation (TIA).

As successor of the SIMATIC Selection Tools, the TIA Selection Tool assembles the already known configurators for automation technology into a single tool.

With the TIA Selection Tool, you can generate a complete order list from your product selection or product configuration.

You can find the TIA Selection Tool on the Internet.

(<https://support.industry.siemens.com/cs/us/en/view/109767888>)

SINETPLAN

SINETPLAN, the Siemens Network Planner, supports you in planning automation systems and networks based on PROFINET. The tool facilitates professional and predictive dimensioning of your PROFINET installation as early as in the planning stage. In addition, SINETPLAN supports you during network optimization and helps you to exploit network resources optimally and to plan reserves. This helps to prevent problems in commissioning or failures during productive operation even in advance of a planned operation. This increases the availability of the production plant and helps improve operational safety.

The advantages at a glance

- Network optimization thanks to port-specific calculation of the network load
- Increased production availability thanks to online scan and verification of existing systems
- Transparency before commissioning through importing and simulation of existing STEP 7 projects
- Efficiency through securing existing investments in the long term and the optimal use of resources

You can find SINETPLAN on the Internet

(<https://new.siemens.com/global/en/products/automation/industrial-communication/profinet/sinetplan.html>).

1.4 Cybersecurity information

Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks.

In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept.

Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place.

For additional information on industrial cybersecurity measures that may be implemented, please visit

<https://www.siemens.com/cybersecurity-industry>.

Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats.

To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under

<https://new.siemens.com/cert>.

1.5 Administrator rights

NOTE

Administrator rights

For normal operation, the standard user rights are sufficient. You need administrator rights only when you install or repair S7-PLCSIM Advanced or change the network configuration.

Product overview

2.1 What is S7-PLCSIM Advanced?

You use S7-PLCSIM Advanced to simulate your CPU programs on a simulated PLC instance. You do not need any real controllers for simulation. You configure your CPU with STEP 7 in TIA Portal, program your application logic and then load the hardware configuration and the program into the simulated CPU. From STEP 7, you run your program logic, monitor the effects of simulated inputs and outputs, and adapt your programs.

In addition to communication via Softbus, which limits communication to a local PC or virtual machine, S7-PLCSIM Advanced offers a full Ethernet connection and thus also supports distributed I/O systems.

S7-PLCSIM Advanced also includes an application programming interface (API), which enables interaction with native C++/C# programs or simulation software. The API extends simulation capabilities and provides features such as the following:

- Simulation of hardware interrupts
- Stopping a simulation
- Synchronization with simulation partners

For these and other API functions, refer to the S7-PLCSIM Advanced API manual included with your release.

Application areas

Typical application areas of S7-PLCSIM Advanced are:

- Verification of the user program (TIA Portal)
- Testing of the STEP 7 program
- Software in the loop simulation for the virtual commissioning of machine tools/production machines, production cells, and production lines in a plant.
- Operator training through the connection of a real HMI

Advantages

S7-PLCSIM Advanced offers numerous advantages:

- Improve the quality of automation projects by early error detection
- Avoid costs for hardware in simulation environments
- Shorten commissioning time
- Reduce risk for commissioning
- Train operators earlier
- Increase production efficiency by optimizing program components

- Increase efficiency during replacement of machine components
- Increase efficiency during expansion of existing plants

2.2 S7-PLCSIM products

Comparison of S7-PLCSIM simulation software products

Function	S7-PLCSIM Advanced	S7-PLCSIM Vxx	S7-PLCSIM V5.x
User interface	S7-PLCSIM Advanced Control Panel	S7-PLCSIM UI	Look&Feel of STEP 7 V5.x
Communication	Softbus ⁴ , TCP/IP	Softbus ⁴ , TCP/IP	Softbus ⁴
Supported CPU families	Supported CPUs (Page 17)	S7-1200 S7-1200 (F), S7-1500 (C, T, F), 1500R/H, SIMATIC Drive Controller, ET 200SP, ET 200SP F, SIPLUS CPUs (S7-1500; Stand- ard and F-CPU, S7-1500R/H and ET 200SP; Standard and F-CPU) Software/Open Controller	S7-300, S7-300F, S7-400, S7-400F
API for co-simulation ¹	✓	-	✓
Web server	✓ via TCP/IP	-	-
ODK	✓	-	-
OPC UA	✓ via TCP/IP	-	-
Process diagnostics	✓	✓	-
S7 communication	✓	Using Softbus	Using Softbus
Open user communication	✓ UDP via TCP/IP	Using Softbus	-
Secure Communication	✓ via TCP/IP	-	-
Traces ²	✓	-	-
Motion	✓	✓ ³	-
Protected blocks (KHP)	✓	✓ for S7-1500 CPUs only	-
Multiple instances	Up to 16	Up to 2	Up to 8
Support of distributed instances	✓ via TCP/IP	-	-
Virtual time	✓	-	-
Connection of real CPUs/HMIs	✓ via TCP/IP	-	✓
DHCP/DNS use	✓ via TCP/IP	-	-

¹ Via C++ and C# programs and simulation software

² Can be monitored with S7-PLCSIM V16 and higher in the TIA Portal; can also be monitored with S7-PLCSIM Advanced V3.0 and higher on the Web server.

³ With S7-PLCSIM V16 and higher, the axes are always in simulation mode irrespective of the axis configuration. With S7-PLCSIM Advanced V3.0 and higher, the axes can also be operated in "Real" mode over the API.

⁴ You can find more information on Softbus (online access PLCSIM) in the "Communication" section.

2.2 S7-PLCSIM products

Function	S7-PLCSIM Advanced	S7-PLCSIM Vxx	S7-PLCSIM V5.x
Virtual memory card	✓	-	-
Communication between the instances	-	S7-PLCSIM as of V12 and S7-PLCSIM V5.x can be installed and operated on the same PC or the same virtual machine.	
	-	Instances of S7-PLCSIM as of V12 can communicate via Softbus with S7-PLCSIM V5.x.	
	S7-PLCSIM Advanced V3.0 and higher and S7-PLCSIM V15 and higher can be installed and operated on the same PC or the same virtual machine. The communication between the two applications cannot be simulated.		-
	S7-PLCSIM V5.4 SP8 is automatically installed with S7-PLCSIM Advanced. The communication between the two applications can be simulated. Instances of S7-PLCSIM Advanced can communicate via Softbus with S7-PLCSIM ≥ V5.4 SP8.		

- ¹ Via C++ and C# programs and simulation software
- ² Can be monitored with S7-PLCSIM V16 and higher in the TIA Portal; can also be monitored with S7-PLCSIM Advanced V3.0 and higher on the Web server.
- ³ With S7-PLCSIM V16 and higher, the axes are always in simulation mode irrespective of the axis configuration. With S7-PLCSIM Advanced V3.0 and higher, the axes can also be operated in "Real" mode over the API.
- ⁴ You can find more information on Softbus (online access PLCSIM) in the "Communication" section.

2.3 Supported CPUs

Supported CPUs from the S7-1500 family

S7-PLCSIM Advanced supports the simulation of the following CPUs:

Type	Firmware version V1.8 to V4.0	
	Standard	Fail-safe
CPUs¹	CPU 1511-1 PN CPU 1513-1 PN CPU 1515-2 PN CPU 1516-3 PN/DP CPU 1516-3 PN CPU 1517-3 PN/DP CPU 1517-3 PN CPU 1518-4 PN/DP CPU 1518-4 PN/DP ODK CPU 1518-4 PN/DP MFP	CPU 1511F-1 PN CPU 1513F-1 PN CPU 1515F-2 PN CPU 1516F-3 PN/DP CPU 1517F-3 PN/DP CPU 1517F-3 PN CPU 1518F-4 PN/DP CPU 1518F-4 PN/DP ODK CPU 1518F-4 PN/DP MFP
Compact CPUs²	CPU 1511C-1 PN CPU 1512C-1 PN	-
ET 200SP CPUs¹	CPU 1510SP-1 PN CPU 1512SP-1 PN CPU 1514SP-2 PN CPU 1514SP T-2 PN CPU 1514PA-2 PN CPU 1515SP PC2 (T) ⁴ CPU 1515SP PC3 (T) ⁴	CPU 1510SP F-1 PN CPU 1512SP F-1 PN CPU 1514SP F-2 PN CPU 1514SP TF-2 PN CPU 1515SP PC2 (F/TF) ⁴ CPU 1515SP PC3 (F/TF) ⁴
Technology CPUs	CPU 1511T-1 PN CPU 1515T-2 PN CPU 1516T-3 PN/DP CPU 1516T-3 PN CPU 1517T-3 PN/DP CPU 1517T-3 PN CPU 1518T-3 PN CPU 1518T-4 PN/DP	CPU 1511TF-1 PN CPU 1515TF-2 PN CPU 1516TF-3 PN/DP CPU 1516TF-3 PN CPU 1517TF-3 PN/DP CPU 1517TF-3 PN CPU 1518TF-4 PN/DP
R/H-CPUs^{1, 2}	CPU 1513R-1 PN CPU 1515R-2 PN CPU 1517H-3 PN CPU 1517H-4 PN CPU 1518-3 P	CPU 1518HF-4 PN CPU 1518F-3 PN

¹ SIPLUS and SIPLUS RAIL CPUs are supported. They are of the same design as the standard and fail-safe CPUs listed here but have their own article numbers.

² The on-board I/O of the CPUs is not simulated. The simulation interface corresponds to the process image. For the R/H CPUs, S7-PLCSIM Advanced supports firmware version 2.9 and higher.

³ Versions 30.0 and 30.1. STEP 7 only simulates the S7-1500 Software Controller. PC station configuration is not supported. You must set the IP address of the network interface on the simulated PLC to match the STEP 7 project. If you change the firmware version in the STEP 7 project, you must delete the simulated PLC instance at the former version and simulate a new PLC instance for the changed version. You can then download from the TIA Portal to the new instance.

⁴ Open Controller

2.4 Compatibility in case of updates

Type	Firmware version V1.8 to V4.0	
	Standard	Fail-safe
ET 200pro CPUs	CPU 1513pro-2 PN CPU 1516pro-2 PN	CPU 1513pro F-2 PN CPU 1516pro F-2 PN
SIMATIC Drive Controller		CPU 1504D TF CPU 1507D TF
S7-1500 Software/Open Controller ³	CPU 1505SP CPU 1505SP T CPU 1507S CPU 1508S CPU 1508S T	CPU 1505SP F CPU 1505SP TF CPU 1507SP F CPU 1508S F CPU 1508S TF

¹ SIPLUS and SIPLUS RAIL CPUs are supported. They are of the same design as the standard and fail-safe CPUs listed here but have their own article numbers.

² The on-board I/O of the CPUs is not simulated. The simulation interface corresponds to the process image. For the R/H CPUs, S7-PLCSIM Advanced supports firmware version 2.9 and higher.

³ Versions 30.0 and 30.1. STEP 7 only simulates the S7-1500 Software Controller. PC station configuration is not supported. You must set the IP address of the network interface on the simulated PLC to match the STEP 7 project. If you change the firmware version in the STEP 7 project, you must delete the simulated PLC instance at the former version and simulate a new PLC instance for the changed version. You can then download from the TIA Portal to the new instance.

⁴ Open Controller

Unsupported CPUs

S7-PLCSIM Advanced does not simulate S7-1200 or S7-1200 G2CPUs.

To simulate CPUs of the S7-1200 or S7-1200 G2 product family, use the latest edition of S7-PLCSIM (<https://support.industry.siemens.com/cs/ww/en/view/109826203>).

If you download a TIA Portal project whose configuration includes an unsupported CPU, the following error message appears:

"Loading of hardware configuration failed (0020 -3 2 0). Please check the diagnostic buffer of the target hardware."

2.4 Compatibility in case of updates

When you install S7-PLCSIM Advanced, you update any earlier version to the current version.

Compatibility with TIA Portal and with CPU firmware versions

A simulated PLC instance in S7-PLCSIM Advanced corresponds to that of a CPU S7-15xx V4.0.

NOTE**Password encryption in case of updates**

When a TIA Portal project is updated from CPU firmware version < V2.0 to CPU firmware version ≥ V2.0, the following error message is displayed during a download of the project to SIMATIC S7-PLCSIM Advanced:

"Loading of hardware configuration failed (0020 -3 2 0). Please check the diagnostic buffer of the target hardware."

To successfully download such a project to SIMATIC S7-PLCSIM Advanced, click the "Update password encryption" button while updating the project.

2.5 Security for S7-PLCSIM Advanced

Restrictions for security

S7-PLCSIM Advanced does not provide options for authentication and authorization. Communication is not protected by authentication.

Communication

- The multi-computer simulation communication is not encrypted.
- A TCP/IP port is opened on the PC for cross-network communication.
- The installed Npcap program library provides access to TCP/IP network communication.

NOTE

For cross-computer communication, use a closed simulation network that is not connected to a production network.

Know-how protection

NOTE**Know-how protected blocks**

If know-how-protected blocks for the simulation support are enabled, the know-how protection is limited.

NOTE**CPU function libraries for ODK**


The SO files (shared object files) for ODK are not know-how-protected. The customer is responsible for the SO files and its know-how protection.

2.6 Supporting simulation

Requirement for simulation

NOTE**Enable simulation capability**

To use a STEP 7 project with simulation, you must select the "Support simulation during block compilation" option in the "Protection" tab in the properties of the project and confirm with OK.



Know-how protection

If a know-how-protected block is to be used for the simulation, it must be unlocked by entering a password.

After you have unlocked the know-how-protected block, you can activate the option "Can be simulated with SIMATIC S7-PLCSIM". You will find the option in the properties of the block in the "General > Compilation" tab.

Additional information can be found on the Internet (<https://support.industry.siemens.com/cs/ww/en/view/109754928>).

Global libraries

You cannot use know-how protection with global libraries, because the libraries are write-protected.

The "Can be simulated with SIMATIC S7-PLCSIM" option must be set when generating the blocks (source of the blocks).

2.7 Differences between a simulated and a real CPU

A simulated PLC instance cannot fully simulate a real CPU down to the individual details. Even if a program is downloaded (Page 55) without errors to the simulated CPU and running successfully, this does not necessarily mean that the simulated CPU behaves exactly like a real CPU.

Deterministic

S7-PLCSIM Advanced runs on a PC with the Windows operating system. The scan cycle time and the exact time of actions in S7-PLCSIM Advanced are not the same as when these actions run on physical hardware. This is because several programs share the processing resources on your PC.

To provide the best possible deterministic behavior under these conditions, S7-PLCSIM Advanced requires one free Core (CPU core) per instance. Information on the minimum requirements for the computer hardware or a virtual machine can be found in the section System Requirements.

If your program depends heavily on the time required to execute actions, then make sure that you do not evaluate your program based only on the results of the simulation time.

Know-how protection

Projects with know-how protection for blocks can only be simulated if they are enabled for simulation. You need the block password for this purpose.

Instructions

Instructions are simulated with a few exceptions, see Restrictions for instructions [\(Page 82\)](#).

Programs that are based on the instructions behave differently than real CPUs in the simulation.

S7-1500R/H

For communication with other devices, you can configure system IP addresses in STEP 7 for a redundant S7-1500R/H system.

2.7.1 Restrictions for all supported CPUs

Fieldbus systems

S7-PLCSIM Advanced does not simulate fieldbus systems (PROFINET IO, PROFIBUS DP).

Intelligent I/O devices (I-devices)

S7-PLCSIM Advanced does not simulate I-Device functionality.

I/O

S7-PLCSIM Advanced simulates the real CPU, but not configured I/O modules and the on-board I/O of the compact CPUs.

Removal and insertion

In contrast to real systems, S7-PLCSIM Advanced allows the removal and insertion of head modules in distributed I/O systems.

Communications modules and communications processors

S7-PLCSIM Advanced does not support CMs and CPs and the related features such as "Access to PLC via communications module".

Diagnostics / diagnostic alarms

The S7-PLCSIM Advanced control panel does not enable simulation of diagnostic buffer entries.

Online and diagnostic functions

Certain online and diagnostic functions (e.g. the "Firmware update" function) are not supported.

Copy protection

S7-PLCSIM Advanced does not simulate copy protection.

Limited support

S7-PLCSIM Advanced simulates some functions to a limited extent. You can find an overview in the section Restrictions, messages, and solution [\(Page 79\)](#).

2.7.2 Notes

Password applied during CPU swap

Depending on the firmware version of the CPUs affected (the CPU to be replaced and the replacement CPU), you are either offered an update to the latest algorithm or prompted to assign a new password because the replacement CPU cannot use the existing password configuration.

If the CPU to be replaced and the replacement CPU are identical in terms of the algorithm used, no action is required: the password configuration and the other parameter settings are transferred.

S7-PLCSIM Advanced does not support any password encryption for CPU versions with firmware less than V2.0.

In order to use protection levels, the Web server and the access protection of the F-CPU in the simulation, click on the "Update password encryption" button. The button is located in the CPU properties in the "Protection & Security" tab under "Access level".

HMI devices and CPU protection levels

- S7-PLCSIM Advanced supports SIMATIC HMI devices as of version 14. Connections to SIMATIC HMI devices prior to V14 are not supported.
- S7-PLCSIM Advanced supports protection levels if the virtual S7-1500 controller is configured with a firmware version V2.0 or higher.
- It is possible to connect SIMATIC HMI devices as of V14 to virtual S7-1500 controllers that are configured with a firmware version V2.0 or higher, with or without protection levels.
- It is possible to connect SIMATIC HMI devices as of V14 to virtual S7-1500 controllers which are configured with a firmware version lower than V2.0 without protection levels.

Solution

To establish a connection to the SIMATIC HMI device V13 or earlier, you must update this SIMATIC HMI device to version V14.

To establish a connection from the simulated PLC instance that is configured with a CPU firmware version lower than V2.0 to the SIMATIC HMI device, you must remove existing protection levels from the project.

Safety system versions

To successfully simulate and test a project with fail-safe input and output modules, you need to use safety system version V1.6, V2.0, V2.1, V2.2, V2.3, V2.4, V2.5, or V2.6. Simulation of the fail-safe input and output modules does not work correctly with an older version.

Technology module TM Count - Error message of instruction High_Speed_Counter

When you are using S7-PLCSIM Advanced for the simulation of a high-speed counter in a TM Count technology module, the instruction High_Speed_Counter signals an error 16#80C7.

The instruction High_Speed_Counter expects that the module has set a bit for "Status ready" (STS_READY). Because S7-PLCSIM Advanced does not simulate the module behavior, the instruction signals an error.

The STS_READY bit is located in the input area of the module at offset 13.4. When the input area of your TM Count module starts at %I32, for example, the STS_READY bit is located at %I45.4.

To prevent this error message of the High_Speed_Counter instruction, set the STS_READY bit accordingly.

2.8 Password to protect confidential configuration data

As of STEP 7 V17, you have the option of assigning a password to protect confidential configuration data of the respective CPU as of FW version V2.9. This refers to data such as private keys that are required for the proper functioning of certificate-based protocols.

Assign a password to protect confidential configuration data

You assign the password in STEP 7, in the CPU properties, in the area "Protection & Security > Protection of the PLC configuration data".

You can use the same password for an S7-PLCSIM Advanced instance as for the real CPU. This makes it easier for you to assign it uniquely.

S7-PLCSIM Advanced stores the password encrypted in a file on the virtual memory card. The handling of the password is the same as with the real CPU.

Only the current, active Windows user and no other user is allowed to read the password for the protection of confidential configuration data on the computer.

NOTE

Note that your Windows password protects the password used to protect confidential configuration data. Therefore, do not share the Windows password with other, untrustworthy users.

Detailed information on the protection of confidential configuration data and on secure communication can be found in the Communication function manual (<https://support.industry.siemens.com/cs/ww/en/view/59192925>).

Resetting to factory settings

A reset to factory settings causes the instance to start in fault mode under these circumstances:

- The CPU instance is protected with a password to protect PLC confidential data.
- You perform a reset to factory settings and select only the option "Delete password for protection of confidential PLC configuration data".

The instance is in fault mode because the password is missing. You cannot make an online connection or download to the instance.

You must reset the CPU instance with the "Format memory card" selection. With this selection, the instance is not in fault after the reset to factory settings. The storage is, however, cleared out.

Moving the virtual SIMATIC memory card to another virtual machine, for example, SIMIT

If you have not set a password to protect confidential configuration data, there are no restrictions on move operations.

If you have specified the password to protect confidential configuration data, the following restriction applies:

When you move the virtual memory card from one computer to another, you cannot start the S7-PLCSIM Advanced instance on the new system.

NOTE

To ensure maximum security on your systems, the password for protecting confidential configuration data is not available on a new system. You must reset the password again in the new system.

Solution:

The computer is part of an Active Directory.

The password encryption is linked to the Windows user. When you use the same Active Directory user in your domain on another computer, you can start S7-PLCSIM Advanced instances there.

When SIMIT archives the virtual SIMATIC memory card as a ZIP file and another user/computer is trying to restart this simulation

To recover from this situation, follow these steps:

1. Remove the password for protecting confidential configuration data from the STEP 7 project.
2. Load the project to the simulated PLC instance.

You can move the virtual memory card to other computers without any restrictions.

Switching on the S7-PLCSIM Advanced instance without a valid password

When you switch on an instance and the password for the protection of confidential configuration data is incorrect, the instance restarts automatically and switches to STOP mode. The ERROR LED flashes red.

Installing

3.1 Introduction

3.1.1 System requirements

For S7-PLCSIM Advanced to operate efficiently, the following minimum requirements for computer hardware or for a virtual machine must be met.

	Hardware	Virtual machine
Processor	- At least one core Intel® Core™ i7 or comparable per instance started. - At least one additional core for the operating system - At least one additional core for the additional active applications	- One virtual CPU per started instance has to be assigned to the VM. - A corresponding number of processors has to be physically available on the host. - At least one additional core for the operating system - At least one additional core for the additional active applications - At least two cores, if STEP 7 (TIA Portal) is installed on the VM
RAM	1 GB per started instance - At least 4 GB for the Windows operating system - Additional RAM corresponding to the requirements of the remaining active applications	1 GB per started instance - At least 4 GB for the Windows operating system - Additional RAM corresponding to the requirements of the remaining active applications - At least 8 GB, if STEP 7 (TIA Portal) is installed on the VM
Free hard disk space	5 GB	5 GB
Screen resolution	Minimum 1024 x 768	Minimum 1024 x 768

Operating systems and virtualization platforms

S7-PLCSIM Advanced supports the same operating systems, virtualization, and hard disk encryption technology as the corresponding STEP 7 Basic version., with the exception of the Windows Home operating systems. S7-PLCSIM does not support the Windows Home operating systems. See the TIA Portal Information System for a full list of supported technologies.

Refer to online information (<https://support.industry.siemens.com/cs/ww/en/view/78788417>) for installing STEP 7 (TIA Portal) and S7-PLCSIM Advanced on a virtual machine.

3.1.2 Restrictions due to antivirus programs

NOTICE

Restrictions due to virus scanners and Advanced Threat Protection software (ATP software)

Virus scanners and ATP software that monitor the behavior of processes and communication can have a significant influence on the performance of the runtime and communication of S7-PLCSIM Advanced and even prevent S7-PLCSIM Advanced instances from starting.

Solution

You can decrease restrictions during installation and runtime of S7-PLCSIM Advanced. To do so, define exceptions for the virus scanner for secure files and folders. Add the following folders to the exceptions:

- "C:\Program Files\Common Files\Siemens\PLCSIMADV\Drivers"
- "C:\Program Files (x86)\Common Files\Siemens\PLCSIMADV"
- "C:\Program Files (x86)\SIEMENS\Automation\PLCSIMADV\bin"

If the virus scanner only allows files as exceptions, add all files from the listed folders to the exceptions. The procedure is described in the instructions of the respective manufacturer.

NOTE

Refer to the latest readme (<https://support.industry.siemens.com/cs/us/en/view/109824282>) on the Siemens Industry Online Support site for updates. Select the Edition that corresponds to your release version.

Virus scanner and security software support

Refer to "General software and hardware requirements" in the TIA Portal information system for the supported virus scanners and security software.

Siemens recommends Windows Defender that is part of the Windows operating system.

Symantec Endpoint Protection 14.3

Note the following restriction for Symantec Endpoint Protection 14.3 when using TCP/IP Single Adapter or TCP/IP Multiple Adapter:

If you use Npcap with Symantec Endpoint Protection, select one of the following options:

- Uninstall Symantec Endpoint Protection.
- Use Symantec Endpoint Protection with Npcap V1.60 or earlier.

3.1.3 Licenses

Floating license

S7-PLCSIM Advanced is supplied with a floating type license which is version and/or time-dependent. The license can be stored locally and shared for a network.

NOTE**Validity**

A license is valid for two instances within an S7-PLCSIM Advanced installation.
You must use the correct license for your version.

Handling of licenses is described in the Help for SIMATIC Automation License Manager (ALM).

3.1.4 Trial License

A license is available for the limited period of 21 days for S7-PLCSIM Advanced. After this Trial License has elapsed, you can no longer start the instance.

Activating the Trial License

When you start an instance in the Control Panel, the Automation License Manager (ALM) searches the network for a valid license. If a Floating License is available for S7-PLCSIM Advanced, the ALM offers the Trial License for activation.




Figure 3-1 Activating the Trial License

A message at the start of an instance shows the remaining number of days.




Figure 3-2 Trial License

NOTE**Remote access**

With remote access you have to confirm the message on the PC on which the instance was started.

Timeout

If you do not confirm the message for the license in a certain amount of time, the instance is not started and you see an error message.

Start the instance again and confirm the message for the license.

3.1.5 Installation log

The log files contain automatically recorded information on the following installation processes:

- Installation of S7-PLCSIM Advanced
- Change or update of installation of S7-PLCSIM Advanced
- Repair of an existing installation of S7-PLCSIM Advanced
- Uninstallation of S7-PLCSIM Advanced

You can evaluate installation errors and warnings using the log files. You can troubleshoot the installation yourself or contact Siemens Technical Support. Product Support personnel need information from the installation log to analyze the problem. Send the folder with the log files as a ZIP file to Support.

Memory location of the installation log

The memory location of the log file depends on the operating system. To open the folder with the log files, enter the environment variable "%autinstlog%" in the address bar in Windows Explorer. Alternatively, you reach the appropriate folder by entering "cd %autinstlog%" in the command line.

The log files are named as follows:

- "SIA_S7-PLCSIM_Advanced_<version number>@<DATE_TIME>.log"
- "SIA_S7-PLCSIM_Advanced_<version number>@<DATE_TIME>_summary.log"

Setup_Report (CAB file)

The installation log and other required files are stored in a log file. This file can be found at "%autinstlog%\Reports\Setup_report.cab".

A separate CAB file with a date ID is saved for each installation.

If you need help during installation, send this CAB file to Siemens Technical Support for troubleshooting.

3.1.6 Contents of the S7-PLCSIM Advanced package

The S7-PLCSIM Advanced package contains the following software:

- S7-PLCSIM Advanced
- Automation License Manager
- S7-PLCSIM V5.4.x
- .NET Framework
- Npcap

The package is available as a download and on DVD. Floating product licenses and product upgrade licenses are available.

If you installed from a DVD, keep the DVD in a secure, easily accessible place.

Setup program

You can use the Setup program to change, repair, or uninstall your installation, if necessary.

3.2 Installing S7-PLCSIM Advanced

Installation requirements

The Setup program starts automatically with a double-click on the download package or when you insert the DVD in the drive. Make sure that the following conditions are met before you begin the installation process:

- The hardware and software of the computer meet the System requirements [\(Page 26\)](#).
- You have administrator rights on the installation computer.
- No other programs are active. This also applies to the Siemens Automation License Manager and other Siemens applications.
- All TIA Portal versions prior or equal to V14 are uninstalled.

NOTE

Security settings

For licensing via the ALM, you must agree during installation that port 4410 for TCP can be entered as an exception in the Windows Firewall (procedure step 5).

NOTE

Use of virus scanners

Note the information provided in section Restrictions due to antivirus programs [\(Page 27\)](#).

Installing S7-PLCSIM Advanced

To install, follow these steps:

1. Double-click the download package or insert the installation medium into the DVD drive of your computer. The setup program starts up automatically, provided you have not disabled the Autostart function on the computer. If the setup program does not start up automatically, start it manually by double-clicking the "Start.exe" file. The "General settings" window is displayed.
2. Click the "Read installation notes" button. After you have read the notes, close the file.
3. Click the "Read product information" button. After you have read the information, close the file.
4. Click "Next". The window with the products to be installed is displayed.
5. Select the products to be installed.
6. Click the "Browse" button if you want to change the default installation path. The installation path must not exceed 89 characters. The path name must not contain any UNICODE characters. If you select a different installation path than the default installation path, the desktop icon may not be displayed correctly.
7. Click "Next". The window with the security settings is displayed. To continue the installation, select the check box at the bottom of the screen to accept changes to the security and permissions settings of your system.
8. Click "Next". The window with the installation settings is displayed. You can save or print a report of the settings by clicking "Save report" or "Print report". Check the settings for correctness. If you want to make any changes, click "Back" until you reach the point in the installation process where you want to make changes. Once you have completed your changes, click "Next".
9. The overview screen shows your installation details. Click the "Install" button. The installation then starts.
10. After completion of the setup program, you must restart your computer. Select "Yes, I want to restart the computer now" to restart the computer immediately or select "No, I will restart computer later" to restart the computer later.
11. Click "Restart". If the computer is not restarted, click "Finish".

Error during installation of S7-PLCSIM Advanced

The installation of S7-PLCSIM Advanced recognizes an already existing installation of S7-PLCSIM Advanced.

A requirement for the installation of S7-PLCSIM Advanced is that no other S7-PLCSIM installation prior or equal to TIA Portal version V14 is located on the same computer.

Even though no installation of S7-PLCSIM is displayed in the "Programs and Features" list, it is still possible that the computer has an existing installation.

Remedy

Run the setup for S7-PLCSIM prior or equal to TIA Portal version V14 and uninstall S7-PLCSIM.

If the setup is not available, download the setup files for S7-PLCSIM via Siemens Mall

(<https://support.industry.siemens.com/cs/ww/en/view/65601780>).

3.3 Changing an installation

Requirements

The following conditions must be met before you can change the installation:

- The hardware and software of the computer meet the system requirements.
- You have administrator rights on the installation computer.
- No other programs are active.

Procedure

To change your S7-PLCSIM Advanced installation, follow these steps:

1. Double-click the download package or insert the installation medium into the drive. The setup program starts up automatically, provided you have not disabled the Autostart function on the computer. If the setup program does not start up automatically, start it manually by double-clicking the "Start.exe" file.
2. Follow the prompts until you reach the "Configuration" window.
3. Select the "Change upgrade" check box.
4. Follow the remaining prompts to change your installation.
5. Complete the installation operation by restarting your computer.

NOTE

Target directory

You cannot change the target directory because you are changing an existing installation.

3.4 Repairing an installation

Requirements

The following conditions must be met before you can repair S7-PLCSIM Advanced:

- The hardware and software meet the system requirements.
- You have administrator rights on the installation computer.
- No other programs are active.

Procedure

To repair your installation, follow these steps:

1. Double-click the download package or insert the installation medium into the drive. The setup program starts up automatically, provided you have not disabled the Autostart function on the computer. If the setup program does not start up automatically, start it manually by double-clicking the "Start.exe" file.
2. Follow the prompts until you reach the "Configuration" window. Select the "Repair" check box.
3. Follow the remaining prompts to repair your installation.
4. Complete the repair operation by restarting your computer.

3.5 Uninstalling the product

You have two options for uninstalling S7-PLCSIM Advanced:

- Uninstalling the program via the Windows Control Panel
- Uninstalling the entire product via the Setup program

Uninstalling S7-PLCSIM Advanced using the Windows Control Panel

Proceed as follows from the Control Panel:

1. Double-click your S7-PLCSIM Advanced product version in the Programs and Features.
2. Follow the prompts for uninstallation.
3. Complete the uninstallation operation by restarting your computer.

If you do not perform a restart, the Runtime Manager continues running.

If problems occur when uninstalling S7-PLCSIM Advanced using the Windows Control Panel, use the installation medium for uninstalling.

Uninstalling S7-PLCSIM Advanced using the Setup program

Proceed as follows:

1. Double-click the download package or insert the installation medium into the drive. The setup program starts up automatically, provided you have not disabled the Autostart function on the computer. If the setup program does not start up automatically, start it manually by double-clicking the "Start.exe" file.

If you do not perform a restart, the Runtime Manager continues running.

2. Follow the prompts until you reach the "Configuration" window. Your previous installation is detected. Select the "Uninstall" check box.
3. Follow the prompts for uninstallation.
4. Complete the uninstallation operation by restarting your computer.

If you do not perform a restart, the Runtime Manager continues running.

Uninstalling additional software

When you uninstall S7-PLCSIM Advanced via the setup program, the following software from the S7-PLCSIM Advanced package remains installed:

- Automation License Manager
- S7-PLCSIM
- .NET Framework
- Npcap

If you also want to uninstall this software, use the Windows Control Panel.

NOTE

User data, such as instance data, is not removed by the uninstallation.

Communication paths

Local and distributed communication

The following paths are open for communication between STEP 7 V15 or higher and the instances of S7-PLCSIM Advanced user interfaces:

Table 4-1 Local and distributed communication

Communication paths	Local	Local	Distributed
Protocol	Softbus	TCP/IP	TCP/IP
Online access (Page 50) setting in S7-PLCSIM Advanced	PLCSIM	TCP/IP Single Adapter or TCP/IP Multiple Adapter	TCP/IP Single Adapter or TCP/IP Multiple Adapter
STEP 7 and instances	On a PC / VM	On a PC / VM	Distributed
Communication...			
Between STEP 7 and instances	Yes	Yes	Yes
Among instances	Yes	Yes	Yes
Via OPC UA server and Web server	No	Yes	Yes
Between an instance and a real hardware CPU	No	No	Yes
Between an instance and a real HMI V14 and higher	No	No	Yes
Between an instance and a simulated HMI V14 and higher	Yes	Yes	Yes
Secure communication...			
Via Secure Open User Communication (secure TCP communication) V17 and higher	No	Yes	Yes
Via OPC UA Server V17 and higher	No	Yes	Yes
Via HTTPS connections to the Web server TIA Portal version V17 and higher	No	Yes	Yes

PLCSIM online access (Softbus)

Softbus is a communication path via a virtual software interface.

The communication is limited to a local PC or a virtual machine. The advantage here is that no data can be accidentally downloaded to a hardware CPU or communicate with real hardware.

Communication with S7-1500 R/H CPUs

NOTE

Communication with system IP address

Communication with S7-1500 R/H CPUs over the system IP address is possible with a TCP/IP connection. You cannot use the PLCSIM online access setting (Softbus protocol) to reach the system IP address.

Selecting a network mode

You select the network mode for communication in the Control Panel under "Online Access". The setting is valid for all generated instances. The default setting is the communication via "PLCSIM" (Softbus).

Additional network settings are necessary for the distributed communication over a TCP/IP adapter setting, see Network addresses in the simulation [\(Page 59\)](#).

4.1 Local communication

Local communication can be performed via the "PLCSIM" online access point (Softbus protocol) or TCP/IP.

For local communication, the S7-PLCSIM Advanced instance is on the same PC or on the same virtualization platform such as STEP 7 or another communication partner.

Local communication via Softbus

Local communication is performed via Softbus in S7-PLCSIM Advanced by default. You select "PLCSIM" for the online access point on the control panel to use the Softbus protocol.

Local communication via Softbus prevents:

- An accidental download to a hardware CPU
- Communication with real hardware




Figure 4-1 Local communication via Softbus

Local communication via TCP/IP

When you choose TCP/IP Single Adapter or TCP/IP Multiple Adapter for the Online Access point, communication is performed via a simulated network interface that behaves like a real network interface.

NOTE

Local communication via TCP/IP

Make sure that communication is only local and cannot be downloaded to real hardware. For this, you must have no other adapters of your Windows PC configured in the physical network and on the subnet of your simulated PLC instance. Microsoft KB 175767 provides background.




Figure 4-2 Local communication via TCP/IP

4.2 Communication via TCP / IP

4.2.1 Communication via TCP/IP in Single Adapter Network Mode (promiscuous mode)

Distributed communication

Distributed communication via TCP/IP means that the S7-PLCSIM Advanced instances communicate with other devices via the S7-PLCSIM Advanced Virtual Switch. Communication is possible with real or simulated CPUs, real or simulated HMIs.

You must activate the S7-PLCSIM Advanced Virtual Switch in Windows [\(Page 44\)](#) for instances on the network to be visible.

The network interface you configure as the S7-PLCSIM Advanced Virtual Switch must be in the same IP subnet as the IP address of the simulated PLC instance. If the virtual switch is not in the same subnet, you can assign it an IP address that is in the same subnet. Each CPU interface requires an IP address that is unique throughout the entire, accessible network.

Example 1: Distributed communication

In the following example, STEP 7 is on a PC and the S7-PLCSIM Advanced instances are on another PC or a virtual machine. The PCs are connected via their real Ethernet adapter.




Figure 4-3 Distributed communication via Ethernet

Example 2: Distributed communication on a PC

In the following example, STEP 7 is on a PC and the S7-PLCSIM Advanced instances are on a virtual machine on the same PC. The PC and virtual machine are connected via the (virtual) network adapters.




Figure 4-4 Distributed communication via network adapters

Required settings in the "Virtual Machine Settings" dialog using the VMware visualization platform as an example

If you have opened STEP 7 (TIA Portal) and your project within the virtual machine, enable the following options for your online connection as follows:

1. Right-click on the VM and select "Settings" or select the menu "VM > Settings".
2. Open the "Virtual Machine Settings" dialog via the menu command "Player > Manage > Virtual Machine Settings".
3. Then click "Network Adapter" in the "Hardware" tab and activate the following options in the right window:
 - Connected
 - Connect at power on
 - Bridged: Connected directly to the physical network
 - Replicate physical network connection state
4. Click the "Configure Adapters" button and activate your network connection, for example "Intel(R)82574L LM Gigabit Network Connection".
5. Confirm the setting with OK and exit the "Virtual Machine Settings" dialog with OK.

Example 3: Distributed communication

The following example shows a structure with PCs on which distributed STEP 7, S7-PLCSIM Advanced instances and virtual machines with S7-PLCSIM Advanced instances are running.




Figure 4-5 Distributed communications with PCs and virtual machines

4.2.2 Communication via TCP/IP in Multiple Adapter Network Mode (non-promiscuous mode)

In TCP/IP Single Adapter Network Mode (promiscuous mode), the network adapter reads all incoming telegrams. The network adapter also reads telegrams that are not intended for the network adapter. The network adapter then forwards the data to the operating system for processing.

In TCP/IP Multi-Adapter Network Mode (non-promiscuous mode), the evaluation of MAC addresses ensures that only data intended for the network adapter reaches the operating system.

However, on virtualization platforms or corporate networks, it is often not permitted to run the network interface of the PC in TCP/IP Single Adapter Network Mode (promiscuous mode) for security reasons.

Overview

The following figure provides an overview of the possibilities and differences between the following communication options:

- Local TCP/IP communication
- Single Adapter Network Mode (promiscuous mode)
- Multi-Adapter Network Mode (non-promiscuous mode)




Figure 4-6 S7-PLCSIM networking

Applications

The following applications describe how you can also communicate in TCP/IP Multi-Adapter Network Mode (non-promiscuous mode). You communicate in this mode by performing a one-to-one mapping of the MAC addresses between the CPU network interfaces and the network adapters of the PC.

The following applications assume that you are working in an environment where security restrictions apply and you have therefore switched to TCP/IP Multi-Adapter Network Mode (non-promiscuous mode).

Application 1:

You start multiple instances. Each CPU interface is assigned to the MAC address of the respective physical or virtual PC adapter.

Precondition: Each interface of a running instance is assigned to its own physical or virtual PC interface (one-to-one mapping).




Figure 4-7 Application 1

Application 2:

The following application shows the behavior with multiple instances that have the same MAC addresses. Each CPU interface is assigned to the corresponding physical or virtual PC adapter.

The scenario is only valid if only one instance is running at a time.




Figure 4-8 Application 2

Refer to the S7-PLCSIM Advanced API manual for a procedure to perform external communication in TCP/IP Multi-Adapter Network Mode.

4.2.3 Using a Software/Open Controller with a TCP/IP communication interface

If you have selected a TCP/IP communication interface for the online access of a Software/Open Controller, the IP address of your S7-PLCSIM Advanced Instance must match the IP address defined in your TIA Portal project.

In your device configuration, select "Set IP address in the project" and configure a static IP address to the PLC Interface. Do not assign IP addresses with 0.0.0.0 and 192.168.0.1 values.

When you download to your instance, select the appropriate "Direct at slot 1 Xn" variant in the Connection to interface/subnet dropdown in the Extended download to device window. The TIA Portal Load Preview window displays an error message if an IP Address mismatch occurs. In this case, you must cancel the download and re-create your instance.

4.3 Enable distributed communication

By default, the S7-PLCSIM Advanced Virtual Switch is not enabled for communication connection properties. For distributed communication to be possible, that is cross-computer communication, you must activate the S7-PLCSIM Advanced Virtual Switch for a real network adapter.

NOTE

Network adapter

If using TCP/IP Single Adapter mode, make sure that the S7-PLCSIM Advanced Virtual Switch is activated for only one network adapter. The Control Panel of S7-PLCSIM Advanced checks the activation and can report an incorrect configuration (error code -50).

Activating the S7-PLCSIM Advanced Virtual Switch

To make the S7-PLCSIM instances visible on the network and to reach other devices, activate the S7-PLCSIM Advanced Virtual Switch in Windows:

1. To do this, open the "Network and Sharing Center" in the Windows Control Panel.
2. Open the properties of the desired network adapter, for example, for the "Local Area Connection".
3. Select the check box for the "S7-PLCSIM Advanced Virtual Switch" and confirm with OK.




Figure 4-9 Activating the S7-PLCSIM Advanced Virtual Switch

Accessible devices

On the local computer, the S7-PLCSIM Advanced instances are always displayed in the TIA Portal as accessible devices of the Siemens PLCSIM Virtual Ethernet Adapter.

The S7-PLCSIM Advanced instances are not visible locally via the configured network, even if the S7-PLCSIM Advanced Virtual Switch is activated.




Figure 4-10 Accessible devices on the Siemens PLCSIM Virtual Ethernet Adapter

Distributed communication via WLAN

When using distributed communication via WLAN, it can happen that the Npcap program library installed by S7-PLCSIM Advanced does not work with the integrated WLAN adapter of the PC. In this case, no WLAN connection can be established.

Remedy

Use the wired network adapter of the PC/notebook and connect a WLAN adapter upstream.

Simulating

5.1 Simulating a CPU

5.1.1 Basic procedure for the simulation

The following overview shows the basic steps to perform simulation with a simulated PLC instance.

Requirements

The following requirements must be met for starting simulation via local communication:

- STEP 7 (V14 or higher) and S7-PLCSIM Advanced are installed on the same PC.
- The CPU hardware is configured in STEP 7.

NOTE

Enable simulation support

To support simulation [\(Page 20\)](#), select the check box "Support simulation during block compilation" from the "Protection" tab in the properties of the project in STEP 7,

Create and activate an instance via the Control Panel

- Open the S7-PLCSIM Advanced Control Panel. [\(Page 48\)](#)
- Open the "Start Simulated PLC Instance" options.
- Enter a name for an instance. Do not use Unicode characters in the instance name.
- Select the CPU family.
- Create an instance using the "Start" button.

In STEP 7, perform the download and start the simulation

- Download the program [\(Page 55\)](#) to the simulated PLC instance
- Switch the simulated PLC instance to RUN to start the simulation
- Perform diagnostics

5.1.2 Control Panel - User interface

5.1.2.1 S7-PLCSIM Advanced Symbol

After installing S7-PLCSIM Advanced, the following icons are on the Windows desktop:



Figure 5-1 S7-PLCSIM Advanced Symbol

A double-click on the symbol opens the Control Panel for S7-PLCSIM Advanced. If the Control Panel is in the background, it is moved to the foreground with another double-click.

You can use Windows functions to permanently display the icon in the system tray of the taskbar.

Opening the Control Panel or viewing status from the taskbar

Right-clicking the icon in the taskbar opens the Control Panel with the quick view. Double-click to start the Control Panel as a window.

You can use the mouse-over function to display messages about the current status of the instances.




Figure 5-2 Example: Message in the taskbar

5.1.2.2 Control Panel quick view and window

S7-PLCSIM Advanced provides the Control Panel with two views:

- **Control Panel as quick view**

Right-clicking on the icon in the taskbar opens the quick view.

Clicking on an empty area on the desktop minimizes the quick view. The instances are not affected.

- **Control Panel as window**

Double-clicking the icon on the desktop or in the taskbar opens the Control Panel as a window.

Control Panel as window

Unlike the quick view, you can operate the Control Panel with the buttons in the title bar.

You can close this window without exiting the simulation Runtime process.



- ① Stores the Control Panel as icon in the taskbar.
- ② No function. The window size cannot be changed.
- ③ Closes the Control Panel and stores it in the system tray of the taskbar.
The instances and the simulation Runtime process remain active.
This function therefore differs from the Exit function .
The Exit function switches off the local instances, logs them off and closes the Control Panel.
- ④ Pins the Control Panel on the screen so that it remains in the foreground.


Figure 5-3 Control Panel: Title bar

5.1.2.3 S7-PLCSIM Advanced Control Panel

The S7-PLCSIM Advanced Control Panel is only available in English.

Features of the Control Panel

The figure below shows the structure of the S7-PLCSIM Advanced Control Panel.



- ① Online access Selection of the network mode
- ② TCP/IP communication Selection of network adapter for distributed communication

- | | | |
|---|--------------------------------------|---|
| ③ | Virtual time
Scaling | Slider to adjust the scaling factor |
| ④ | Strict Motion
Timing | <p>Check box to disable the overrun detection for Motion Control (OB MC-Servo [OB91]).</p> <p>When you select the check box for Strict Motion Timing, PLC instances detect overruns.</p> <p>You can only change the Strict Motion Timing setting for overrun detection when you have started no PLC instances. All instances that you subsequently start use the Strict Motion Timing setting to either detect or ignore overruns.</p> |
| ⑤ | Start Simu-
lated PLC
Instance | <p>Selector to open and close the input boxes for creating the instance</p> <ul style="list-style-type: none"> • Instance name Unique name for the instance.
Instance names must be between 3 and 64 characters, inclusive. If the name is unique in the network, you can click the "Start" button. • IP address, Subnet mask, Default gateway Input boxes that are visible when you switch the communication interface to a TCP/IP mode. • PLC family PLC family to be simulated • "Start" button Button to start the instance that you selected |
| ⑥ | Buttons | Buttons for operating the selected instances |
| ⑦ | Instance list | List of available local instances, which you can sort by dragging and dropping |
| ⑧ | LEDs | LED indicators, which display a tooltip definition when you move the mouse over them |
| ⑨ | Icons | Icons for operating the instance |
| ⑩ | Runtime Man-
ager Port | Port on the local PC to be opened |
| ⑪ | Virtual
SIMATIC
Memory Card | <p>Clickable region where you open the storage location of the virtual memory card</p> <p>With the "..." Browse icon you can change the path to the virtual memory card.</p> |
| ⑫ | Show Notific-
ations | Check box to disable S7-PLCSIM Advanced messages in the Windows task bar for the duration of the operation. |
| ⑬ | Function
manual | Icon for opening the S7-PLCSIM Advanced Function Manual |
| ⑭ | API manual | Icon for opening the S7-PLCSIM Advanced API Manual |
| ⑮ | Exit | Exit button and bottom region of control panel for logging off all instances and closing the Control Panel |

Online access selection

Choose one of the following for the communication interface to use for all instances you create:

- S7-PLCSIM: Local communication via Softbus (default).
- TCP/IP Single Adapter [\(Page 37\)](#)
- TCP/IP Multiple Adapter [\(Page 40\)](#)

The setting applies to all other instances. The selected communication interface for starting an instance is maintained until all instances are shut down.

When an instance is already started, it sets "its" communication interface as the default for other instances.

To change the communication interface, switch off all instances and enable the other interface.

TCP/IP communication

After you select TCP/IP Single Adapter or TCP/IP Multiple Adapter for the online access, you can select a real network adapter from the drop-down list during operation. You thus activate the S7-PLCSIM Advanced Virtual Switch and establish TCP/IP communication between the instances and the real network.

The <Local> setting deactivates the S7-PLCSIM Advanced Virtual Switch and disconnects the instances from the real network. Only local TCP/IP communication over the virtual adapter is possible in this case.

Virtual time

You must enable the virtual time for each instance using the icon . Use the slider or the mouse wheel to select the scaling factor for the virtual time.

The selected scaling factor applies to the instances for which the virtual time is enabled.

Clicking on "Off" restores the default (1) again. For more information see Virtual and Real Time [\(Page 77\)](#).

Creating a local instance and starting it

To create an instance, enter a unique name under "Instance Name".

The following rules apply to the creation of an instance name:

- The minimum length of an instance name is 3 characters; the maximum length is 29 characters.
- The instance name must not start or end with a dot (.) or a space.
- The instance name can only contain the following:
 - Uppercase letters from A to Z
 - Lowercase letters from a to z
 - Numbers from 0 to 9
 - Special characters: Spaces ., _ - + @ ! ; # ~ ' () [] { } ^ \$ % &

NOTE

If the name already exists in the folder of the Virtual SIMATIC Memory Card, this already existing instance is started.

In the "PLC family" drop-down list, you select a CPU family:

- S7-1500
- S7-1500R/H
- ET 200SP
- ET 200pro
- Software/Open controller

Create the instance with the "Start" button and start this instance.

The instance is initialized with the first download from the TIA Portal.

Instance list

The list contains the instances that have been started and are available locally on the PC or virtualization platform.

To change the operating mode, select one or more instances and click the "RUN" or "STOP" button. To reset memory, select one or more instances and click the "MRES" button.

The LEDs correspond to hardware PLC LEDs and show the status and operating mode of each instance.

You can "operate" the instance with these icons:

-  Enable or disable the virtual time scaling factor
-  Power on/off the instance
-  Power off and unregister instance

Runtime Manager Port

A remote connection can be established to another Runtime Manager via the specified port. The value must be greater than 1024.

If you select the check box, the port value is retained. You can use the remote connection without having to make this setting every time you start the Control Panel. To use this functionality, the Control Panel must be started and running in the background.

Virtual SIMATIC Memory Card

The user program, the hardware configuration, and the retentive data are stored on the Virtual SIMATIC Memory Card. Use the buttons to adapt the path to the virtual memory card or open the previously saved path in an Explorer window.

Showing notifications

Each time the Panel starts, help information and messages relating to the Control Panel are displayed, for example, when changing the IP address or when a license is missing. Disable "Show Notifications" if you do not need the messages.

Exit - Log off all instances

The command switches off all local instances on the PC or the virtual memory card, logs them off from the Runtime Manager, and closes the Control Panel.

This command closes the Runtime Manager if there are no remote connections to other Runtime Managers.

If the Runtime Manager has remote connections to instances on additional PCs, these instances and the Runtime Manager continue to run.

5.1.2.4 Importing instances


Requirement

If you start S7-PLCSIM with "Run as administrator", you cannot import instances as described below. To be able to import instances, do not select "Run as administrator" when starting the control panel.

Importing instances

You can use the drag-and-drop function to import instances from a folder directly into the instance list of the Control Panel.

1. Open a folder with instances, for example, using the "Virtual SIMATIC Memory Card" button.
2. Select one or more instances from the folder and drag them to the "Drop Instances Here" area.



5.1.3 Downloading a STEP 7 project

Requirements

You can download the STEP 7 project to the simulated PLC instance when the following conditions are met:

- The instance is created via the Control Panel.
- The check box "Support simulation during block compilation" is selected in STEP 7.

Selecting the communication interface

In the Download dialog box, select the PG/PC interface:

- "PLCSIM" for download via Softbus
- "Siemens PLCSIM Virtual Ethernet Adapter" for download via TCP/IP
- For distributed communication the real adapter that is connected to the network

Display in the download dialog

The dialog in STEP 7 at the first download of the CPU shows the compatible S7-PLCSIM Advanced instances.

If the instance has not yet been configured after the first download only **one** interface is visible and it appears with the device type "CPU-1500 Simulation".

If the instance has been configured, the number of interfaces visible is determined by the number the CPU type has.

The dialog shows the interfaces of an instance with their IP addresses.

Perform download

To download a project to the simulated PLC instance, follow these steps:

1. Select the PG/PC interface.
2. Click "Download".
 - In the "Load preview" window, STEP 7 shows the message "The downloads are performed on a simulated CPU".
 - After the first download, the S7-PLCSIM Advanced instance displays the CPU type.




Figure 5-4 Example: Download via the "PLCSIM Virtual Ethernet Adapter" (TCP/IP) after naming

Quantity structures

STEP 7 allows you to use the specific allocations for quantity structures and memory usage for an S7-PLCSIM Advanced PLC instance.

To use this feature, you must do the following:

1. Download your STEP 7 project to a simulated S7-PLCSIM Advanced PLC instance.
2. Power cycle the instance after the download.

In STEP 7, the maximum quantity structure for an unconfigured PLC instance is based on the following CPUs:

PLC family	Based on CPU
S7-1500 ET 200SP ET 200Pro	CPU 1518TF-3 PN
Software/Open controller	CPU 1508S TF
S7-1500 R/H	CPU 1518HF-4 PN

For an unconfigured Software/Open controller, use the "NVRAM of the PC system" option for "Retentive memory" in your STEP 7 project.

S7-PLCSIM Advanced does not support "PC mass storage". If you use PC mass storage, S7-PLCSIM Advanced uses the "NVRAM of the PC system".

Downloading to Software/Open controller

Do not select the W1 interface connection when downloading to Software/Open controller.

Additionally, if you change the firmware version of the Software/Open controller in the STEP 7 project after you created a simulated Software/Open controller instance in S7-PLCSIM Advanced, you must delete the simulated PLC instance and simulate a new PLC instance for the changed version. You can then download from the TIA Portal to the new instance.

Going online from STEP 7

Observe the following requirements for user authentication based on the "Online Access" mode:

- In PLCSIM (Softbus) mode, you can go online from STEP 7 with a local project user, but not a central user (global user).
- In either TCP/IP mode, you can go online from STEP 7 with a central user (global user), but only from programming devices that can access the UMC server on which you configured the central users.

Loading an additional CPU to one instance

Example in TIA Portal:

1. Assign an IO device (e.g. IM 153-4 PN) to a CPU (e.g. CPU 1518-4 PN/DP).
2. Add another CPU of the same product family (e.g. CPU 1511-1 PN) to your project.
3. Start the simulation with online access via PLCSIM Virtual Ethernet Adapter.

4. Load the configuration onto the CPU 1518-4 PN/DP with the assigned IO device (IM 153-4 PN) via the interface X1 with TCP/IP.
5. Load the configuration of the other CPU (CPU 1511-1 PN) using the same instance.

If you go online after this scenario and check the entries in the diagnostic buffer under "Online & Diagnostics", the following message appears: "Error: Multi-interface mismatch - Inconsistent parameterization for sending LLDP data)."

To avoid this error scenario, use one of the following solutions:

- In the "General" tab under PROFINET interface [X1] > Advanced options > Interface options, enable "Use IEC V2.2 LLDP mode" for the PROFINET interface [X1] for both CPUs (CPU 1511-1 PN and CPU 1511-1 PN).
- After the second download, log out the instance and log it in again.
- Power cycle the instance.

5.1.4 Network addresses in the simulation

5.1.4.1 Siemens PLCSIM Virtual Ethernet Adapter

IP address

For the PLCSIM Virtual Ethernet Adapter (either TCP/IP Single Adapter or TCP/IP Multiple Adapter ([Page 50](#))), you assign a static IP address in the Windows network settings or obtain an IP address via DHCP (default).

MAC address

The PLCSIM Virtual Ethernet Adapter (either TCP/IP Single Adapter or TCP/IP Multiple Adapter) has its own MAC address.

S7-PLCSIM Advanced only uses MAC addresses that are designated as "locally administered" (bit 2 in LSB) ([Page 60](#)).

The Siemens-specific prefix is: 02-1B-1B. Three bytes follow, which are determined at random.

Storage location

This MAC address is stored in the registry key "PlcsimvminiMacAddress". You can overwrite this value.

5.1.4.2 S7-PLCSIM Advanced instances

Detect CPUs and instances

If Ethernet interfaces of CPUs and S7-PLCSIM Advanced instances are mixed in a network, the instances are recognizable by the "PLCSIM" suffix of the device type during the search for accessible nodes in STEP 7.





Figure 5-5 Search for the devices that are accessible in STEP 7

Structure of the MAC address for an instance

The following figure shows the structure of the dynamically generated, locally managed MAC address:



The MAC address tells you the PC on which an S7-PLCSIM Advanced instance has been started.

Assignment of the Ethernet interfaces

Port configurations of the Ethernet interfaces cannot be simulated in S7-PLCSIM Advanced. Topological interconnection is not supported. A MAC address for a port is reserved internally for each Ethernet interface.

Table 5-1 Assignment of the Ethernet interfaces, for example, for a CPU 1518-4 PN/DP

Ethernet interface	Last digit of the MAC Address
IE 1	0
IE 1 / Port 1	1
IE 2	2
IE 2 / Port 1	3
IE 3	4
IE 3 / Port 1	5

Example

02-C0-A8-00-83-10 means:

02 → locally managed MAC address of an S7-PLCSIM Advanced instance

C0-A8-00-83 → IP of the Siemens PLCSIM Virtual Ethernet adapter = 192.168.0.131

1 → Instance 1

0 → Ethernet interface IE 1

If no Virtual SIMATIC Memory Card is loaded during startup of S7-PLCSIM Advanced, the interfaces of S7-PLCSIM Advanced display instances with their locally managed MAC address.

5.1.5 Simulate communication

5.1.5.1 Communication services that can be simulated

S7-PLCSIM Advanced supports the following communication options:

Table 5-2 Supported communication options

Communications options	Functionality / instructions
PG communication	On commissioning, testing, diagnostics
Open communication using TCP/IP	• TSEND_C / TRCV_C • TSEND / TRCV • TCON¹ • T_DISCON
Secure Open user communication (secure TCP communication)	• TSEND_C / TRCV_C • TCON
Open communication using ISO-on-TCP	• TSEND_C / TRCV_C • TSEND / TRCV • TCON • T_DISCON
Open communication via UDP ²	• TUSEND / TURCV • TCON • T_DISCON
Communication via Modbus TCP ³	• MB_CLIENT • MB_SERVER
E-mail ^{2, 3}	• TMAIL_C
S7 communication	• PUT / GET • BSEND / BRCV • USEND / URCV
OPC UA server ^{2, 3}	Secure data exchange with OPC UA clients
Web server ^{2, 3}	Data exchange via HTTP, HTTPS

¹ When the online access is the "S7-PLCSIM" (Softbus) interface, communication is performed **internally** via ISO-on-TCP.

² Communication is only possible when the online access is TCP/IP Single Adapter or TCP/IP Multiple Adapter, collectively also called the PLCSIM Virtual Ethernet Adapter.

³ "Access to PLC via communications module" is not supported.

Special conditions apply when communicating with TUSEND/TURCV, see Restrictions for communications services (Page 82).

NOTE

Secure Communication

When simulating communication services, also consider the basics of secure data exchange (Secure Communication). For detailed information on Secure Communication, refer to the Communication (<https://support.industry.siemens.com/cs/ww/en/view/59192925>) function manual.

Additional information

For more information on the various communication services, please refer to the Communication function manual (<https://support.industry.siemens.com/cs/ww/en/view/59192925>).

Restrictions for MODBUS communication via Softbus

For communication via Softbus, use the supported Modbus versions shown in the following table or, alternatively, communication via TCP/IP.

Table 5-3 Modbus communication via Softbus

MODBUS TCP Lib	MB_CLIENT	MB_SERVER	SOFTBUS
V6.0	V6.0	V5.3	✓
V5.2	V5.2	V5.2	x
	V5.1	V5.1	x
	V5.0	V5.0	x
V4.2	V4.1	V4.2	x
	V4.1	V4.1	x
	V4.0	V4.0	✓

✓ = Communication possible

x = Communication not possible

TMAIL_C

When the TMAIL_C instruction is used, the mail server might not be located on the same PC as the S7-PLCSIM Advanced instance.

Solution

Make the mail server available via a different PC in the network.

5.1.5.2 Communication between instances

S7-PLCSIM Advanced supports communication between instances. An instance might be a simulation in S7-PLCSIM Advanced or a simulation in WinCC Runtime as of V14.

You can run two instances of S7-PLCSIM Advanced, which then communicate with each other. To enable instances to communicate with each other, they must have a unique IP address.

Each simulated CPU requires a unique IP address

If the CPUs have the same IP address, you cannot run multiple simulations. Each simulated CPU requires a unique IP address.

Make sure that the IP addresses in STEP 7 are unique before you start your simulations.

T-block instructions and UDP

S7-PLCSIM Advanced simulates T-block connections for which the UDP protocol is configured only using the TCP/IP Single Adapter or TCP/IP Multiple Adapter communication interface (PLCSIM Virtual Ethernet Adapter).

T-block instructions and data segmentation

S7-PLCSIM Advanced implements T-block instructions with a data segmentation of 4 KB. A real CPU has data segmentation of 8192 bytes.

If you send more than 4 KB in a single TSEND instruction and receive data in ad hoc mode with a TRCV instruction, the TRCV instruction generates new data with only 4 KB. You must perform the TRCV instruction several times to receive additional bytes.

5.1.6 Provide project data offline for simulation

Simulations regardless of STEP 7

To perform simulations independent of STEP 7, you can save the user program and the hardware configuration in STEP 7 in a folder.

Saving retentive data securely

The retentive data is automatically saved when the simulated PLC instances are shut down.

To save the retentive data safely in the virtual SIMATIC Memory Card, you must log instances off correctly. Use one of the following functions for this:

-  Power on/off the instance
-  Power off and unregister instance
- Exit function  Power off and unregister all running instances

Provide project data offline

1. Create a "User-defined Card Reader" for your project data in the "Card Reader/USB storage" folder in the project tree of STEP 7 for the CPU. Do not use Unicode characters in your card reader name.
2. In the "Load preview" dialog for the target device, select "PLC Simulation Advanced" for the target device.
→ The project is saved to the <Virtual Memory Card>\SIMATIC.S7SIOMSSTORE folder.




Figure 5-6 Preview of download dialog

3. Save the folder "\SIMATIC.S7S" with the project data to a medium of your choice.




Figure 5-7 Add card reader

Provide project data for simulation

1. On the PC on which S7-PLCSIM Advanced is installed, create the folder "\SIMATIC_MC" in the folder in which the instance saves its data.
2. Move the "\SIMATIC.S7S" folder to the folder you have created.

The instances can be started with the project data.

5.2 Simulating a CPU with ODK functionality

Introduction

The ODK is an engineering tool that allows the creation of high-level language applications for S7-1500 CPUs. You use it to generate function libraries that are used in the STEP 7 user program.

The ODK for S7-PLCSIM Advanced supports the C++ programming language.

You can find the description of the ODK in the Programming and Operating Manual "S7-1500 Open Development Kit 1500S", as of V2.5 Edition 12/2017: SIMATIC STEP 7 (TIA Portal) Options ODK 1500S (<https://support.industry.siemens.com/cs/ww/en/ps/13914/man>)

Section 6 "Development of a CPU function library for the real-time environment" is relevant for ODK applications under S7-PLCSIM Advanced.

Supported CPUs

S7-PLCSIM Advanced supports the ODK functionality of the following controllers:

- CPU 1518(F)-4 PN/DP ODK
- CPU 1518(F)-4 PN/DP MFP
- CPU 150XS (P/T/F) (Software/Open Controller family)

5.2.1 Special features of ODK

Simulating CPU with ODK functionality with S7-PLCSIM Advanced

The simulation of a CPU with ODK functionality requires a special start procedure.:

- From the PLC family dropdown list, select the CPU type. For example, for a CPU1518MFP, select S7-1500. For a Software Controller or Open Controller, select Software/Open Controller.
- Start the instances on the Virtual SIMATIC memory card that contain the project data for the CPU with ODK functionality.
- After the first download from the TIA Portal, select the functions "Switch off instance"  and "Shutdown instance"  in the Control Panel.

NOTE

When you perform the first download to a CPU of the "S7-1500" family, for example, via the S7-PLCSIM Advanced Control Panel, no ODK1500S folder is created on the virtual SIMATIC Memory Card. The CPU cannot be switched to RUN. In this case, you will find messages about missing ODK blocks (e.g. SFC 2013) in the diagnostics buffer.

Supported function libraries

S7-PLCSIM Advanced supports the following function libraries for the real-time environment:

- CPU function library: Original Shared Object, SO file as for the hardware CPUs
- S7-PLCSIM Advanced function library (Windows Sync):
 - a 32-bit Windows DLL for ODK Runtime
 - a 64-bit Windows DLL for ODK Runtime

NOTE

Do not mix function libraries

When simulating with S7-PLCSIM Advanced, you cannot load 32-bit and 64-bit function libraries simultaneously. If you want to use one function library, first remove the function library of the other type.

If you want to use function libraries with a different binary format, all others must be unloaded first.

NOTE

Limitations for the execution of CPU function libraries (Windows Sync) with an infinite loop in the class constructor

When the CPU function library (DLL file) contains an object of a class in whose constructor an infinite loop is programmed, the corresponding "ODK client" process gets permanently stuck in this loop when instantiating the object.

Even after reaching the timeout, the infinite loop cannot be interrupted automatically. The S7-PLCSIM Advanced instance remains in RUN even though the entry "Time error - CPU changes to STOP mode" is displayed in the diagnostics buffer.

NOTE

Limitations for traces in the execution of CPU function libraries (Windows Sync)

Avoid using traces when developing a CPU function library (DLL file) in the class constructor (call of the "ODK_TRACE()" function) to prevent trace messages with faulty parameter values.

NOTE

Know-how protection

The SO files for ODK are not know-how-protected.

Debugging an S7-PLCSIM Advanced function library (DLL file)

To debug a function library, attach the Visual Studio Debugger to the corresponding ODK client process that has loaded the respective function library.

S7-PLCSIM Advanced supports versions $\geq$ Visual Studio 2017.

Simulation of the ODK with S7-PLCSIM Advanced

If you have loaded the TIA project on the S7-PLCSIM Advanced and the instruction "<STEP7Prefix>_Load" was called for the first time, each S7-PLCSIM Advanced instance starts another Windows process ("ODK client") in which the ODK application is executed synchronously with the STEP 7 user program.

Which ODK client is started depends on the function library to be loaded:

- "Siemens.Simatic.PlcSim.Vplc1500.ODKClient.so.exe" for an original Shared Object
- "Siemens.Simatic.PlcSim.Vplc1500.ODKClient.x86.exe" for a 32-bit application
- "Siemens.Simatic.PlcSim.Vplc1500.ODKClient.x64.exe" for a 64-bit application

The executable files of these processes are located in the same folders as those of the S7-PLCSIM Advanced Instances ("Siemens.SIMATIC.Simulation.Runtime.Instance.exe").

NOTE

S7-PLCSIM Advanced does not support asynchronous ODK functions.

Error codes

The same error codes as described in the Programming and Operating Manual "S7-1500 Open Development Kit 1500S" apply to the instructions in the real-time environment. Error codes are also available for S7-PLCSIM Advanced because the ODK client processes can be closed unexpectedly and therefore an error handling is required.

Restrictions for stack processing

NOTE

Limitations for stack processing in the version of CPU function libraries for real-time-environment

S7-PLCSIM Advanced ignores the stack size for a CPU function library that is adjusted via the parameter <SyncCallStackSize>. S7-PLCSIM Advanced always provides the maximum stack size of 1 MB.

Additional information may be found in the programming and operating manual S7-1500 Open Development Kit 1500S

(<https://support.industry.siemens.com/cs/ww/en/view/109783714>) . Search for content about CPU function libraries and SyncCallStackSize.

S7-PLCSIM Advanced cannot catch any Exceptions of the type "Stack Overflow" while CPU function libraries for the real-time environment (SO files) are being executed.

When developing a CPU function library (SO file), make sure that the maximum stack size of 1 MB is not exceeded. An overflow of the stack leads to an undefined behavior and can lead to the termination of the ODK client process.

NOTE**Limitations for heap processing in the version of CPU function libraries (Windows Sync)**

If a heap corruption occurs when executing a C/C++ function from a CPU function library (DLL file), then this program error is first ignored and execution of the function continues. Only after fully processing the function is the corresponding error code returned (0x8090).

When developing a CPU function library (DLL file), make sure to avoid heap corruption. This way you ensure that after fully processing a C/C++ function no error code is returned.

5.2.2 Loading functions

Loading functions - Instruction "<STEP7Prefix>_Load"

If you have loaded the TIA project on the S7-PLCSIM Advanced and the instruction "<STEP7Prefix>_Load" was called for the first time, each S7-PLCSIM Advanced instance starts another Windows process. The ODK client then attempts to load the function library that is specified in the SCL file. This is in the folder "<storage path of the instance> \SIMATIC_MC\ODK1500S". The storage path of the instance is the Virtual SIMATIC Memory Card location.

The ODK client process continues until the instruction "<STEP7Prefix>_Unload" is called to unload the last loaded function library or until the process of the S7-PLCSIM Advanced instance ends.

The function call is synchronous and returns after completion of the operation. The output parameter provides information on the progress status.

ODK error code for S7-PLCSIM Advanced

The following table lists the error codes that apply in addition to the error codes that apply to the CPU specifically for ODK applications with S7-PLCSIM Advanced:

Table 5-4 ODK: Output parameter - Load functions

DONE	BUSY	ERROR	STATUS	Description
0	0	1	0x80A4 = -32604	- The ODK client process cannot be started. - A connection to the ODK client cannot be established or has been interrupted.
0	0	1	0x8095 = -32619	The ODK client process that is currently running expects a function library with a different binary format.

5.2.3 Calling functions

Call functions - Instruction "<STEP7Prefix>SampleFunction"

When calling ODK functions, data is exchanged between the simulated PLC instance and the function library.

The execution of a single function can be interrupted by the execution of higher prioritized OBs.

Technically, the execution of a function is an asynchronous instruction because it is executed in another process. However, the processes are synchronized in the simulated PLC instance. This means that the function call does not return before the function returns or the ODK client process is closed during the execution.

ODK error code for S7-PLCSIM Advanced

The following table lists the error codes that apply in addition to the error codes that apply to the CPU specifically for ODK applications with S7-PLCSIM Advanced:

Table 5-5 ODK: Output parameter - Call functions

DONE	BUSY	ERROR	STATUS	Description
0	0	1	0x80A4 = -32604	The connection to the ODK client was interrupted.

5.2.4 Unloading functions

Unload functions - Instruction "<STEP7Prefix>_Unload"

The CPU function library is unloaded by calling the instruction "<STEP7Prefix>_Unload". If no other function library is loaded or if the process of the S7-PLCSIM Advanced instance is closed, then the ODK client process is shut down.

The function call is asynchronous, the call returns immediately. The output parameter informs about the progress status.

Restrictions

S7-PLCSIM Advanced simulates the real CPU but not configured, connected technology modules or other I/O devices.

It is possible to download a STEP 7 project with technology modules for operation of motion control. However, the built-in logic of the technology modules is not part of the simulation. Therefore, the corresponding motion control instructions are not supported.

In contrast to a real CPU, S7-PLCSIM Advanced does not support isochronous mode for centralized I/O in S7-1500 with local send clock.

OB MC-Servo [OB91] and OB MC-Interpolator [OB 92]

If you convert a motion control project that contains OB 91 and OB 92 from STEP 7 V13, then you cannot load this project to a S7-PLCSIM Advanced.

Solution

Delete OB 91 and OB 92 in the project and recompile the project.

The OBs are then created again with the simulation support required for S7-PLCSIM Advanced.

Compilation resets the properties of the blocks to the default values.

Restore the required settings in the properties.

Diagnostic buffer message "Overflow" for OB MC servo [OB91]

If there are overflows of the OB MC-Servo [OB91] in the diagnostic buffer, the time for the application cycle (ms) has been exceeded, because the calculation of this application cycle could not be completed within the required time.

Solution

The overflows of OB MC-Servo [OB91] in the diagnostic buffer decrease under these conditions:

- When fewer additional Windows processes are executed
- When the computing power of the CPU is higher

Overflow detection is activated for S7-PLCSIM Advanced as of V3.0 for exact simulation of the technology objects. If diagnostic buffer overflows occur on your PC for OB MC-Servo [OB91] and your instance goes into the STOP operating state, the following solutions are available to you:

- Use the virtual time of S7-PLCSIM Advanced and start with the lowest possible scaling factor for the virtual clock. Increase the value step-by-step until the first overflows occur in the diagnostic buffer. Repeat this procedure until you have determined the maximum scaling factor for which you do not yet get any overflows in the diagnostic buffer.

Information on the scaling factor can be found in section Speed up and slow down simulation [\(Page 78\)](#).

- Set a longer application cycle (ms) for the OB MC-Servo [OB91] in STEP 7.

NOTE

Load on an S7-PLCSIM Advanced instance is too high

If the load on an S7-PLCSIM Advanced instance becomes too large, the instance may no longer switch to the STOP operating state despite numerous diagnostic buffer overflows.

In such a case, shut down the S7-PLCSIM Advanced instance and follow the workarounds described above.

Simulation with external simulation software

NOTE

In a simulated PLC instance, the technology objects are connected to the process image. Simulation software can thus access the process image and simulate the behavior of the other connected axes.

The simulation mode in STEP 7 is a standard function of the technology objects and is independent of S7-PLCSIM Advanced.

If you want to move an axis in simulation mode, select the "Activate simulation" check box in STEP 7 under "Technology Object > Configuration > Basic Parameters > Simulation". No additional setting is required for a virtual axis.

Feedback of the axis position

The speed setpoint of the simulated drive is integrated into the actual position value with a time delay (PT1). The result of this calculation is returned to the technology object as position actual value of the axis.

Reference point approach of the axis

If you selected "Use zero mark via PROFIdrive frame" in STEP 7 for the reference point approach, S7-PLCSIM Advanced responds immediately to any active (mode 2, 3, 8) or passive (mode 4, 5) reference point approach command (MC_Home). The actual position is predefined as the reference point.

More information

You can find information on the technology functions of the CPU in the S7-1500/S7-1500T Motion Control (<https://support.industry.siemens.com/cs/ww/en/view/109751049>) function manuals.

For more information, refer to the manuals of the supported SIMATIC controllers. (<https://support.industry.siemens.com/cs/ww/en/view/109744173>)

5.3 Simulating the SIMATIC Drive Controller

Introduction

The SIMATIC Drive Controller is a drive-based controller in the SIMATIC S7-1500 range. A SIMATIC Drive Controller combines the following functionalities in a SINAMICS S120 Booksize Compact housing:

- Fail-safe SIMATIC S7-1500 technology CPU with integrated technology I/Os
- SINAMICS S120 drive control

Both components are called "CPU" and "SINAMICS Integrated" in the documentation.

The SIMATIC Drive Controller supports PROFINET and PROFIBUS DP communication.

Supported SIMATIC Drive Controllers

S7-PLCSIM Advanced supports the SIMATIC Drive Controllers as of firmware version V2.9:

- CPU 1504D TF (6ES7615-4DF10-0AB0)
- CPU 1507D TF (6ES7615-7DF10-0AB0)

Special features

Unlike other SIMATIC S7-1500 technology CPUs, the SIMATIC Drive Controllers also have:

- Integrated inputs/outputs (onboard I/O)
- Integrated drive control SINAMICS Integrated

Restrictions

S7-PLCSIM Advanced only simulates the standard CPU functionality of the SIMATIC Drive Controller.

Not simulated are:

- the technology functions of the onboard I/O
- the SINAMICS Integrated
- PROFINET IO
- PROFIBUS DP

The integrated inputs/outputs of the X122, X132 and X142 interfaces can only be simulated as binary inputs/outputs.

Technological functions are not simulated, for example, Timer DI/DQ, Oversampling DI/DQ. Channel parameter assignments, such as signal inversion, input delay and edge detection are not possible.

The functionality of the SINAMICS Integrated is not simulated – but the SINAMICS Integrated is shown as a valid node.

Simulations are possible as with SINAMICS S120 CU320-2 based on the drive telegrams (e.g. by reading and forcing the telegram addresses).

Coupled isochronous mode

In coupled isochronous mode, the relevant clock systems use a shared system clock, for example, from PROFINET IO or the local send clock of the technology I/Os. The leading clock system provides its own system clock to the other clock systems.

NOTE

Leading clock system

Clock synchronization with technology I/Os X142 (local send clock) as leading clock system is not possible with S7-PLCSIM Advanced. In this case, you configure the PROFINET IO interface X150 as leading clock system.

The information provided in the section Simulation of Motion Control (Page 70) still applies.

Additional information

The SIMATIC Drive Controller system manual

(<https://support.industry.siemens.com/cs/ww/en/view/109766665>) describes in detail the configuration, installation, wiring and commissioning of the SIMATIC Drive Controller. The STEP 7 online help supports you in the configuration and programming.

The SIMATIC Drive Controller equipment manual (<https://support.industry.siemens.com/cs/ww/en/view/109766666>) contains a compact description of the module-specific information, such as properties, wiring diagrams, characteristics and technical specifications.

5.4 Simulating a redundant S7-1500R/H system

Introduction

In a redundant S7-1500R/H system, the CPUs are duplicated, in other words, redundant. The two CPUs process the same project data and the same user program in parallel. The two CPUs are synchronized over two redundancy connections. If one CPU fails, the other CPU maintains control of the process.

S7-PLCSIM Advanced supports the R/H CPUs of the redundant S7-1500R/H system as of firmware version V2.9 as described below.

Supported operating and system states

Like standard S7-1500 CPUs, the S7-1500R/H CPUs have the operating states STOP, STARTUP and RUN. For operation as a redundant system, one of the two CPUs can take on an additional operating state, SYNCUP, for synchronizing the two subsystems. The RUN operating state is divided into the following states for redundant systems:

- RUN
- RUN-Syncup
- RUN-Redundant

The system states of the redundant S7-1500R/H system result from the combination of the operating states of the individual CPUs as follows:

- STOP
- STARTUP
- RUN-Solo
- SYNCUP
- RUN-Redundant

NOTE

RUN-Solo system state is supported by S7-PLCSIM Advanced

The simulation of a redundant S7-1500R/H system is possible in the RUN-Solo system state (RUN operating state of the CPU). In the RUN operating state, the (leading) primary CPU behaves just like an S7-1500 standard CPU. The MAINT LED on the CPU is always yellow (maintenance request) because no partner CPU was found for redundant operation.

No simulation is possible with S7-PLCSIM Advanced in redundant system operation.

Unsupported events

The following event is not supported by the R/H CPUs of the redundant S7-1500R/H system:
RackOrStationFault

NOTE

The occurrence of a RackOrStationFault event does not trigger an OnLedChanged event for R/H CPUs. The ERROR LED is not flashing even though a corresponding device fault message is displayed in the diagnostic buffer.

Supported functions as of firmware version V3.0

As of FW version V3.0, the S7-1500H redundant system supports PROFINET system redundancy R1 with the following devices:

- ET 200SP IM 155-6 PN R1
- ET 200SP HA IM 155-6 PN HA
- ET 200iSP IM 152-1 PN

R1 devices are equipped with two interface modules compared to S2 devices. If one interface module fails, the R1 device can still be reached by the H-CPU via the second interface module.

The redundant S7-1500H system thus supports the following additional setup variants:

- Configuration of PROFINET rings with R1 devices
- Line topology configuration with R1 devices, S2 devices, switched S1 devices
- Combined topology configuration with R1 devices and S2 devices

You can load projects consisting of R1 and/or S2 devices in S7-PLCSIM Advanced and simulate them. Reading and writing input and output values of simulated R1 and S2 devices works in the same way as for other simulated IO devices. The simulated R1 and S2 devices support simulation of external events, such as failure of a redundancy connection. Note the removal and insertion of R1 devices is not supported by S7-PLCSIM Advanced.

More information

The Redundant system S7-1500R/H System Manual (<https://support.industry.siemens.com/cs/ww/en/view/109754833>) describes in detail the configuration, installation, wiring and commissioning of the redundant S7-1500R/H system. The STEP 7 online help supports you in the configuration and programming.

The equipment manuals of the R-, H- and HF-CPU contain a compact description of the module-specific information, such as properties, wiring diagrams, characteristics and technical specifications of the CPUs.

See also

[Supported CPUs \(Page 17\)](#)

Virtual time response

The simulated PLC instance uses two types of internal clocks for the simulation: A virtual clock and a real clock. The virtual clock is always the basis for the user program. It is used by components that are relevant for running the STEP 7 user program, such as cyclic OBs, cycle time monitoring, minimum cycle time, virtual system time and time calculations. Also, the time between two cycle control or single step control points is measured in virtual time.

The virtual time can be accelerated or slowed for simulation and optimization purposes.

The real clock always runs unchanged. It is used by components that are not subject to control processes, for example, communication with STEP 7.

Interruption of the process

Since S7-PLCSIM Advanced runs in a Windows environment, Windows might temporarily suspend the simulated PLC instance process. In such a case, both the virtual and the real clock stop in the simulated PLC instance. They only continue to run when Windows resumes processing.

Virtual system time

When you start S7-PLCSIM Advanced, the virtual system time of the instance starts with the system time of Windows.

The virtual system time is based on the virtual clock. If a scaling factor is used, the system time runs correspondingly faster or slower.

All events from the simulated PLC instance provide a time stamp based on the system time.

NOTE

Difference between system time and local time

- System time: UTC $\pm$ 0 with daylight saving / standard time
 - Local time: UTC $\pm$ time zone with daylight saving time / standard time
-

Time offset

NOTE

Keep in mind that the time information of virtual system time and real local time differs by the time offset that is formed in addition to the selected scaling factor from the time zone offset and the daylight saving time/standard time offset.

Scaling factor

Using a scaling factor, you can speed up or slow down the virtual clock of the simulated PLC instance for simulations.

To set the required scaling factor, enable the grayed out icon  on the control panel to the right of your S7-PLCSIM Advanced instance. The symbol then becomes active  and you can use the scaling function.

- The default setting is 1, i.e. the virtual time passes the same as the real time.
- **Fast forward:** A scaling factor greater than 1 accelerates the virtual clock.
Example: Scaling factor 2.0 → The virtual time is running twice as fast.
- **Slow motion:** A scaling factor less than 1 decelerates the virtual clock.
Example: Scaling factor 0.5 → The progress of the virtual time slows down to 50%.

6.1 Speed up and slow down simulation

Influence of fast forward and slow motion

Simulations can be accelerated and slowed down. Fast forward and slow motion only affect time-based components, for example, cyclic OBs. Compared to the real time, they are performed more frequently with fast forward and less frequently with slow motion.

Fast forward and slow motion do not change the execution speed of the CPU machine codes. For example, the speed at which all operations of an OB1 cycle are executed does not change. The execution speed depends on the processor of the PC on which the simulated PLC instance is running. If you change the scaling factor, more or fewer cycle control points are reached in a given period of virtual time.

NOTE

Performance

The performance depends on the size of your project, among other things.

If the scaling factor is too high and the cycle-time monitoring indicates that the PC was incapable of calculating the OB1 or cyclic OBs in the specified time, the simulated PLC instance goes to STOP.

Recommendation: To avoid this, start with a small scaling factor and gradually increase it step-by-step while keeping the simulated PLC instance in RUN.

If an overflow of events occurs, slow down the speed of the simulation. See Monitoring overflow [\(Page 86\)](#).

Fast forward

To speed up the virtual time, select a scaling factor greater than 1.

Slow motion

To slow down the virtual time, select a scaling factor less than 1.

Restrictions, messages, and solution

Certain actions or events can lead to behavior in S7-PLCSIM Advanced or in STEP 7 that deviates from a hardware CPU. Differences, messages, and possible solutions can be found in this chapter on restrictions.

7.1 OPC UA server

With OPC UA, data exchange is performed through an open, standardized and manufacturer-independent communication protocol. The CPU as OPC UA server can communicate with OPC UA clients, for example, with HMI panels and SCADA systems.

Configuring an OPC UA server

In S7-PLCSIM Advanced, start the simulated PLC instances via one of the TCIP/IP adapter online access points, also known as the PLCSIM Virtual Ethernet Adapter".

The OPC UA server functionality is not available if communication takes place via the PLCSIM online access point (Softbus).

User authorization for OPC UA

The S7-PLCSIM Advanced license also contains the user authorization for OPC UA.

The user authorization applies for two simulated PLC instances.

7.2 Web server

The web server integrated in a CPU enables authorized users to monitor and manage the CPU via a network. This permits evaluation and diagnostics over long distances.

Each S7-PLCSIM Advanced instance can simulate its own Web server.

The simulation of the Web server is restricted under S7-PLCSIM Advanced. The freeze state of a simulated PLC instance is not shown as an internal operating state.

Configuring the Web server

In S7-PLCSIM Advanced, start the simulated PLC instances via one of the TCIP/IP adapter online access points, also known as the PLCSIM Virtual Ethernet Adapter".

The Web server functionality is not available if the communication is performed via the PLCSIM online access point (Softbus).

In STEP 7, configure the Web server in the CPU properties.

Restricted Web server functionality

The following Web server features are restricted as follows:

- The information may not be fully displayed on some websites due to different data handling.
- There is no topology information.
- FW updates are not supported.

7.3 Backing up and restoring the configuration of an S7-PLCSIM Advanced instance

Backing up and restoring the configuration

You can backup and restore an S7-PLCSIM Advanced instance.

You can create as many backups as you want and store a variety of configurations for an S7-PLCSIM Advanced instance.

You perform the backup and restore in the TIA Portal as you would in a real CPU.

S7-PLCSIM Advanced supports backup and restore via web servers.

A backup that was created with S7-PLCSIM Advanced can only be used with S7-PLCSIM Advanced.

It is not possible to restore the configuration of a real CPU with a backup from S7-PLCSIM Advanced.

Requirements

- The configuration of an S7-PLCSIM Advanced instance is backed up and restored over the TCP/IP protocol. Softbus is not supported.
- It is only possible to restore the configuration of an S7-PLCSIM Advanced instance with the corresponding backup from S7-PLCSIM Advanced.

7.4 Loading project data of an F-CPU to a standard CPU

You have created an instance using the Control Panel. You have not assigned a password to protect confidential configuration data in STEP 7.

In addition to a standard CPU, you also want to load an F-CPU via Softbus or TCP/IP to an instance.

When you load project data of an F-CPU to a standard CPU, a window is displayed in the "Load preview" dialog with the query of a password for access to the CPU.

NOTE**Loading the project data of an F-CPU to a standard CPU**

Loading project data of an F-CPU to a standard CPU is not possible.

To download project data to an F-CPU, you have the following options:

- Select an unspecified CPU as a new device.
 - Start a new instance with an F-CPU.
-

7.5 Update of a TIA Portal project to a new CPU firmware

NOTE**Password encryption in case of updates**

When a TIA Portal project is updated from CPU firmware version < V2.0 to CPU firmware version ≥ V2.0, the following error message is displayed during a download of the project to S7-PLCSIM Advanced ≥ V4.0:

"Loading of hardware configuration failed (0020 -3 2 0). Please check the diagnostic buffer of the target hardware."

To successfully download such a project to SIMATIC S7-PLCSIM Advanced ≥ V4.0, click the "Update password encryption" button while updating the project. If the "Update password encryption" button is not visible in the settings for the CPU's Protection & Security > Access control, collapse the pane on the right side to make the button visible

7.6 Restrictions for storage paths

Synchronization of the storage path in cloud memory

If the Persistence folder (<...\Persistence\<Instance Name>) is in a path that is synchronized to a cloud storage, this can lead to the following undesirable behavior:

- Instability or disconnection of active TIA Portal online connections
- Problems with TIA Portal downloads

To prevent this behavior from occurring, you have the following options:

- Do not place the folder of the Virtual SIMATIC Memory Card in a path that is synchronized to a memory on the cloud.
- Turn off the synchronization of such a folder.

Inaccessible storage path

If the folder of the Virtual SIMATIC Memory Card is on removable media and you remove the media, S7-PLCSIM Advanced cannot create an instance on the virtual memory card. It also cannot access a runtime instance at that location. The Control Panel displays a notification if it cannot access the path. To correct, replace the media or select a different path for the Virtual SIMATIC Memory Card from the control panel.

Character restrictions

Storage paths must not include Unicode characters.

7.7 Restrictions for instance names

Instance names must not include Unicode characters.

7.8 Restrictions for communications services

TUSEND / TURCV

When you run the UDP blocks TUSEND and TURCV via the "PLCSIM" online access ([Page 50](#)) (Softbus), you get error code 0x80C4 at the transmission end and receiving end:

Temporary communications error. The specified connection is temporarily down.

Solution

Set TCP/IP Single Adapter or TCP/IP Multiple Adapter as the online access in S7-PLCSIM Advanced.

7.9 Restrictions for instructions

S7-PLCSIM Advanced simulates instructions for CPUs S7-1500 and ET 200SP as close to reality as possible. S7-PLCSIM Advanced checks the input parameters for validity and returns outputs that are valid but do not necessarily correspond to those that a real CPU with physical inputs/outputs would return.

Instructions not supported

Unsupported instructions are treated as non-operational. The value of unsupported instructions is always "OK". S7-PLCSIM Advanced does not support the following instructions:

- DP_TOPOLOG
- PORT_CFG
- InitIOSystemSync
- StartIOSystemSync
- GetIOSystemSync
- GetPNWorkingClock

T_CONFIG instruction

The instruction T_CONFIG works in S7-PLCSIM Advanced via TCP/IP, but not via Softbus.

7.10 Restrictions to local communication via Softbus

Identical IP addresses for instances

If you are using the "PLCSIM" (Softbus) communication interface when you create instances through the Control Panel, they all have the same default IP address.

STEP 7, therefore, displays only one instance in the download dialog.

Working with multiple instances

When you are working with instances **without unique IP addresses**, note the following procedure for downloading from TIA Portal via "PLCSIM" (Softbus):

1. Start **only one** instance with the symbol  in the Control Panel.
2. In TIA Portal, download the CPU with its specific IP address to this instance.
3. Repeat the steps until you have created all instances and downloaded all projects.

Online and diagnostics

If the "PLCSIM" (Softbus) communication interface is set, no details are displayed for the "Online and Diagnostics" function under the PROFINET interface (IP address, MAC address, etc.).

7.11 Unknown data records

Support of unknown data records

The S7-1500 hardware CPUs return an error code in case of an unknown data record. The behavior of S7-PLCSIM Advanced differs from the behavior of an S7-1500 hardware CPU. To enable simulation of the program flow, S7-PLCSIM Advanced does not return an error code for an unknown data record (e.g. ID 0x9999), but acknowledges the unknown data record with "OK".

7.12 Messages for communication via TCP/IP

Error codes

If an error occurs, a message with an error code and description appears in the notification area of the taskbar. You can find an overview of possible error messages and their associated error codes in the S7-PLCSIM Advanced API manual in the topic `ERuntimeErrorCode` in the Enumerations chapter.

Messages and remedy

The messages related to TCP/IP communication (Page 50) and corresponding remedies are listed below:

Message

"Siemens PLCSIM Virtual Ethernet Adapter was not found. Please reinstall S7-PLCSIM Advanced."

Remedy

The PLCSIM Virtual Ethernet Adapter cannot be found on the system.

Run the S7-PLCSIM Advanced setup again:

1. Double-click the download package or insert the installation medium into the drive. The setup program starts up automatically, provided you have not disabled the Autostart function on the computer. If the setup program does not start up automatically, start it manually by double-clicking the "Start.exe" file.
2. Follow the prompts until you reach the "Configuration" window. Select the "Repair" check box.
3. Follow the remaining prompts to repair your installation.
4. Complete the repair operation by restarting your computer.

Message

"Siemens PLCSIM Virtual Ethernet Adapter is disabled. Please enable it."

Remedy

The PLCSIM Virtual Ethernet Adapter is deactivated on the system. In the Control Panel, under "Network and Sharing Center" > "Change Adapter Settings" and activate the network adapter.

Message

"Npcap service is not running. When installed start it from elevated command prompt with 'net start npcap'."

Remedy

The Npcap is not active on the system. Open a command line in administrator mode and enter the command "net start npcap".

Message

"You have to set a valid IP address for the Siemens PLCSIM Virtual Ethernet Adapter."

Remedy

Assign a static IP address to the Siemens PLCSIM Virtual Ethernet Adapter or obtain an IP address via DHCP (default setting).

7.13 Time synchronization via NTP mode

Time synchronization via NTP mode with S7-PLCSIM Advanced

You can simulate time synchronization using NTP methods.

7.14 Restrictions of security with VMware vSphere Hypervisor (ESXi)

The following information is only important if you want to communicate with the "outside world". This means when you access a VM on which the TIA Portal is running from another virtualization platform on which an instance is running. The following changes are only necessary if you are not using TCP/IP on the local PC.

- When you use the virtualization platform VMware vSphere Hypervisor (ESXi), you must change the policy exception to communicate over TCP/IP.
- Accept the "Promiscuous mode" and "Forged transmit" options for the Virtual Switch of the ESXi.

Promiscuous mode

In promiscuous mode, the network adapter reads all incoming telegrams, including those that are not intended for the network adapter, and forwards the data to the operating system for processing.

The promiscuous mode is necessary for the simulation with S7-PLCSIM Advanced so that telegrams can be forwarded by the Ethernet adapter to the PC or the VM for processing, for example, data for additional S7-PLCSIM Advanced instances in the network.

NOTICE

Restrictions of security

For security reasons, Promiscuous mode is disabled by default.

If you accept the Promiscuous mode, the real Ethernet adapter even receives telegrams that are not addressed to it.

The following figure shows the "Security" category for selecting the security settings for the virtual switch in VMware vSphere Hypervisor (ESXi).




Figure 7-1 Policy exceptions for VMware vSphere Hypervisor (ESXi)

7.15 Restrictions for Hyper-V

The following information is only important if you want to communicate with the "outside world". Communication with the "outside world" means that you access another VM running TIA Portal from a virtualization platform running an instance. When you are using TCP/IP on the local PC, the following settings are not necessary.

When you use the virtualization platform Hyper-V, you must change the following setting to be able to use the communication over TCP/IP.

1. In the Hyper-V Manager, select the Hyper-V server.
2. Select the VM and its settings via "Settings...".
3. In the "Extended Functions", select "MAC Address Spoofing".

This setting is necessary for the simulation with S7-PLCSIM Advanced so that telegrams can be forwarded by the Ethernet adapter to the PC or the VM for processing, for example, data for additional S7-PLCSIM Advanced instances in the network.

NOTICE
Restrictions of security For security reasons, Promiscuous mode is disabled by default. If you accept the Promiscuous mode, the real Ethernet adapter even receives telegrams that are not addressed to it.

7.16 Restrictions for AWS Cloud

The AWS Cloud Connector does not support Layer2 Communication. S7-PLCSIM Advanced does not fully support cloud-based server use cases within Layer2 communication. Therefore, the TIA Portal cannot find the simulated PLC instance by ARP Request. As a workaround, set the IP Address of the instance before starting the download.

If you use TCP/IP Multiple Adapter network mode, you must map network adapters to CPU interfaces. In case of only the X1 interface, you can use the Control Panel to set the Interface association to the appropriate network adapter.

For a successful download from the TIA Portal, you need to set only the IP address of the simulated PLC instance interface (for example, X1) to which you are downloading.

If you need to adapt additional interfaces, use the API. Refer to the SetNetInterfaceMapping() method in the S7-PLCSIM Advanced API Manual, section "Interfaces for Instances".

7.17 Monitoring overflow

Monitoring of main cycle

The maximum cycle time monitoring for S7-PLCSIM Advanced is one minute.

Monitoring of cyclical events

If your simulation contains cyclic interrupts, the queue of S7-PLCSIM Advanced can overflow for cyclic events. Due to the runtime speed of S7-PLCSIM Advanced compared to real hardware, the time needed to create the diagnostic buffer entry might be longer than the time until the next cyclic interrupt.

In this case, an additional entry is placed in the queue, causing another overflow. In the event of an overflow, S7-PLCSIM Advanced provides diagnostics buffer messages and a red error icon in the project tree in STEP 7.

7.18 Deviating I/O values in the STEP 7 user program

If a watch table in the TIA Portal changes an input value, S7-PLCSIM Advanced does not read the changed value.

7.19 Multiple simulations and possible collision of IP addresses

You can simultaneously simulate multiple CPUs, but each simulated CPU interface requires a unique IP address.

Make sure your CPUs have different IP addresses before starting the simulation.

7.20 Lacking access to an IP address

Special feature of distributed communication

If you use multiple network nodes on the same subnet through different virtual or real adapters, the operating system may search for the node on the wrong adapter.

Remedy

Repeat your requests or enter "arp -d <IP address>" in the command line editor of Windows.

7.21 Simulation in standby mode

When your computer or programming device goes into standby or sleep mode, the simulation may stop. In this case, communication between STEP 7 and S7-PLCSIM Advanced is stopped. When your computer or programming device starts up again, the communication may need to be reestablished. In some cases, it may also be necessary to open the simulation project again.

To prevent this situation, disable the standby mode on your computer or programming device.

7.22 Simulation start of SIMIT with S7-PLCSIM Advanced

Error message during simulation start of SIMIT with S7-PLCSIM Advanced

You have configured an S7-PLCSIM Advanced connection in SIMIT. When starting the simulation, SIMIT aborts and the following error message is returned:
"-14 InstanceNotRunning"

When the error has occurred, you can also no longer open the S7-PLCSIM Advanced instance using TCP/IP Single Adapter or TCP/IP Multiple Adapter (the PLCSIM Virtual Ethernet Adapter).

Solution

You have the following solution options:

- Repair your S7-PLCSIM Advanced installation.
- Install S7-PLCSIM Advanced once again.

The procedures are described in the section Installing [\(Page 26\)](#).

A repair or new installation will install the Npcap program library once again, which solves the problem.

7.23 Known restrictions when operating with a co-simulation, for example, SIMIT

In case of a simulation in S7-PLCSIM Advanced in connection with SIMIT, a TIA Portal download in RUN may result in an MC error (MC message 431: Communication to the device under logical address [...] is disturbed. Sign of life of drive faulty).

This error can occur with the following project settings:

- Bus-synchronous operating mode in SIMIT or event-synchronous operating mode to MC servo process image partition (PIP)
- the S7-PLCSIM Advanced feature "Strict Motion Timing" = true

The error causes the activated axes to be switched off. You can acknowledge the error via an MC_Reset or via the TIA Portal. After that, the axis can be switched on again.

7.24 ET 200SP CPUs: Use of BusAdapters with fiber-optic interface

ET 200SP CPUs: Use of BusAdapters with fiber-optic interface

If you use BusAdapters with fiber-optic interface for connecting fiber-optic cables (e.g. BA 2xLC), then download via TCP/IP is not possible.

Remedy

Use the communication interface "S7-PLCSIM" (Softbus) in S7-PLCSIM Advanced.

7.25 Installing SIMATIC NET

Problems after installing SIMATIC NET PC software products

If you are using one of the following operating systems with S7-PLCSIM Advanced on your PC, problems may arise with the S7-PLCSIM Advanced instances via TCP/IP if you have installed SIMATIC NET PC software products on your PC:

- Windows 10 Pro, Version 1809
- Windows Server 2019

After installing the SIMATIC NET PC software products, you may no longer be able to start the S7-PLCSIM Advanced instances via TCP/IP.

Remedy

Update the operating system on your PC:

- Windows 10, Version $\geq$ 1903 or
- Windows Server version $>$ 2019

7.26 No simulation for configuration control

S7-PLCSIM Advanced does not simulate configuration control, which is also known as option handling. Refer to the TIA Portal information system for details about configuration control.

7.27 Communication interface is not updated on the control panel when using an older API

If you are using an S7-PLCSIM Advanced API version older than V6.0, the communication interface might not display correctly on the S7-PLCSIM Advanced Control Panel.

7.28 Trace jobs with duplicate timestamps for motion OBs

A trace for an isochronous OB, for example, MC Servo, could sporadically have two values with the same timestamp.

7.29 The control panel shows VPNs

When using TCP/IP Single Adapter for online access, the list of adapters can include VPNs. You cannot use these VPNs as network adapters.

7.30 Downloading a central CP with S7-1500R/H CPU family using TCP/IP

If a central CP exists next to an S7-1500R/H CPU and you start download from STEP 7 to a simulated PLC instance with an ISO IP (0.0.0.0) in TCP/IP communication, the download fails. To prevent a failed download, define the IP address of the instance before the download.

If you have already attempted a download, download a second time. The second download will be successful.

7.31 Axis control panel functionality

If you add a large quantity of axis related Technology objects to your TIA Portal project and attempt to simulate the PLC with S7-PLCSIM Advanced, you might encounter issues during commissioning. If you are unable to select "Activate" under Master control or "Enable" under Axis in the Axis control panel, do one or more of the following:

- Increase the cycle time of the MC-Servo OB
- Lower the virtual time scaling of the S7-PLCSIM Advanced instance

Setting a scaling factor less than 1 scales the virtual time proportionately. For example, a scale factor of 0.25 means the virtual time is 4 times slower than the system time.

- Use a higher performance PC

7.32 Cannot locate S7-PLCSIM Advanced Instances

If you are unable to locate your S7-PLCSIM Advanced instances, follow these steps:

1. From your Windows OS, open the Network and Sharing Center.
2. Click the network that corresponds to the "Siemens PLCSIM Virtual Ethernet Adapter".
3. Select Properties.
4. If any of the following services appear in "This connection uses the following items", ensure the checkboxes for these services are deselected for the "Siemens PLCSIM Virtual Ethernet Adapter":
 - Fortinet VPN service
 - Juniper Network Service
 - Reliable Multicast Protocol

7.33 Synchronization of IRT systems

Synchronization of IRT IO-Systems is not supported.

7.34 Simulated PLC will not RUN with local I/O send clock

If you configure an isochronous OB in your STEP 7 project to run with the send clock of the central I/O system, you cannot set the simulated PLC instance to RUN. Synchronization with the central I/O bus-system is not supported. To mitigate this issue, follow these steps:

1. Access the properties of the OB in your STEP 7 project.
2. Under the "General" tab, select "Cycle time".
3. Click the radio button to change the Cycle time to "cyclic".

You can now set the simulated PLC instance to RUN.

7.35 Download error after change to "IP address from DHCP server" in STEP 7

If you change the selection in your STEP 7 project to set "IP address from DHCP server", STEP 7 displays an error the first time you download the new settings to your instance. However, your instance retains the new IP address assigned from the DHCP server.

To resolve the error, download the project to your simulated instance a second time.

7.36 Software PLC interfaces not showing after download

The total number of Software PLC interfaces is limited to two. If your STEP 7 project has more than two Software PLC interfaces configured, some interfaces will not be available after a download.

Software PLC interfaces will appear in the download in the order they were assigned in your STEP 7 project. For example: If you assign the ports of the CP (Communication Processor) card before you assign the X2 interface in the project, then the CP card configures the addresses for these two interfaces.

To ensure the desired Software CPU interface is available after the download, even when the total number of configured interfaces exceeds the limit of two, follow these recommendations:

1. Assign the desired interface first in the TIA project.
2. Add any additional interfaces.
3. Download the new configuration.

List of abbreviations

Abbreviation	Term
ALM	Automation License Manager Tool for managing license keys in STEP 7
API	Application Programming Interface
arp	Address resolution protocol
BCD	Binary Coded Decimal
CPU	Central Processing Unit (Synonym for PLC)
DLL	Dynamic Link Library
HMI	Human Machine Interface user interface
I-device	Intelligent IO device
IE	Industrial Ethernet
GUI	Graphical User Interface
LAN	Local Area Network Computer network that is limited to a local area.
MFP	Multifunctional platform
MRES	Memory Reset
OB	Organization Block
ODK	Open Development Kit
OPC UA	Open Platform Communications Unified Architecture
PA	Process image output (PIQ)
PE	Process image input (PII)
PG	Programming device
PLC	Programmable Logic Controller
PN	PROFINET
RAM	Random Access Memory
RT	Runtime
SO	Shared Object
TCP/IP	Transmission Control Protocol/Internet Protocol
TIA	Totally Integrated Automation
PIP	Process Image Partition
UTC	Coordinated Universal Time
VM	Virtual Machine
WinCC	Windows Control Center