

SIEMENS

Validity

1

Improvements in Update 2

2

Improvements in Update 1

3

SIMATIC

WinCC
Readme Runtime Professional

Readme

Legal information

Warning notice system

This manual contains notices you have to observe in order to ensure your personal safety, as well as to prevent damage to property. The notices referring to your personal safety are highlighted in the manual by a safety alert symbol, notices referring only to property damage have no safety alert symbol. These notices shown below are graded according to the degree of danger.

⚠ DANGER
indicates that death or severe personal injury will result if proper precautions are not taken.

⚠ WARNING
indicates that death or severe personal injury may result if proper precautions are not taken.

⚠ CAUTION
indicates that minor personal injury can result if proper precautions are not taken.

NOTICE
indicates that property damage can result if proper precautions are not taken.

If more than one degree of danger is present, the warning notice representing the highest degree of danger will be used. A notice warning of injury to persons with a safety alert symbol may also include a warning relating to property damage.

Qualified Personnel

The product/system described in this documentation may be operated only by **personnel qualified** for the specific task in accordance with the relevant documentation, in particular its warning notices and safety instructions. Qualified personnel are those who, based on their training and experience, are capable of identifying risks and avoiding potential hazards when working with these products/systems.

Proper use of Siemens products

Note the following:

⚠ WARNING
Siemens products may only be used for the applications described in the catalog and in the relevant technical documentation. If products and components from other manufacturers are used, these must be recommended or approved by Siemens. Proper transport, storage, installation, assembly, commissioning, operation and maintenance are required to ensure that the products operate safely and without any problems. The permissible ambient conditions must be complied with. The information in the relevant documentation must be observed.

Trademarks

All names identified by ® are registered trademarks of Siemens AG. The remaining trademarks in this publication may be trademarks whose use by third parties for their own purposes could violate the rights of the owner.

Disclaimer of Liability

We have reviewed the contents of this publication to ensure consistency with the hardware and software described. Since variance cannot be precluded entirely, we cannot guarantee full consistency. However, the information in this publication is reviewed regularly and any necessary corrections are included in subsequent editions.

Table of contents

- 1 Validity.....5
- 2 Improvements in Update 2.....7
- 3 Improvements in Update 1.....9

Validity

Validity

This update is valid for the following products:

- WinCC Runtime Professional V15

Note

If you modify your system after installing the update with the product DVD, you will have to perform the update again.

Improvements in Update 2

Update 1 contains the following improvements and changes:

Display in Runtime

Picture change in Runtime has been improved

- for pictures with numerous symbolic I/O fields
- for several rapid, consecutive picture changes

The representation of graphics in individualized controls has been improved.

Faceplates

The dynamization of the interface properties of a faceplate with user-defined functions has been improved.

System functions

The method of operation of the system function "TriggerOperatorEvent" has been improved with regard to a tag prefix for screen windows.

WebNavigator

The WebNavigator has been improved with regard to using faceplates.

The routines for printing reports have been improved.

Improvements in Update 1

Update 1 contains the following improvements and changes:

Touch operation

Touch operation of WinCC Runtime Professional has been improved.

Display in Runtime

In Runtime, the display of picture objects on different levels has been improved.

Picture change in Runtime

Picture change times have been optimized.

SetOperationLock system function

The mode of operation of the SetOperationLock system function has been improved in terms of use with nested picture windows.

PLC Code Viewer

The PlcCodeViewerExternalClientAccess interface has been optimized in respect of parallel access.

S7-DOS V9

Do not deactivate the IPv4 protocol in the Ethernet properties for the network adapter or the SIMATIC Ethernet CPs if you want to use all of the functions of the new S7-DOS V9.

